



School without Walls @ Francis Stevens Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008705	4/3/2018	4/3/2019	1	Cooler	In hallway adjacent to southwest stairwell	WF-04032018-008705	12/10/2018	FT-FY19-122018-008705-A	<1	FT-FY19-122018-008705-B	<1
WS- 008706	4/3/2018	4/3/2019	1	Cooler	In hallway adjacent to library	WF-04032018-008706	12/10/2018	FT-FY19-122018-008706-A	<1	FT-FY19-122018-008706-B	<1
WS- 008707	7/24/2018	7/24/2019	1	Bottle Filler	In cafeteria (bottle filler)	WF-07242018-008707	12/10/2018	FT-FY19-122018-008707-A	<1	FT-FY19-122018-008707-B	<1
WS- 008708	7/24/2018	7/24/2019	1	Cooler	In cafeteria High Left	WF-07242018-008708	12/10/2018	FT-FY19-122018-008708-A	<1	FT-FY19-122018-008708-B	<1
WS- 008709	7/24/2018	7/24/2019	1	Cooler	In cafeteria Low Right	WF-07242018-008709	12/10/2018	FT-FY19-122018-008709-A	<1	FT-FY19-122018-008709-B	<1
WS- 008717	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 104	WF-10232018-008717	12/10/2018	FT-FY19-122018-008717-A	<1	FT-FY19-122018-008717-B	<1
WS- 008718	4/3/2018	4/3/2019	1	Cooler	In classroom 104	WF-04032018-008718	12/10/2018	FT-FY19-122018-008718-A	<1	FT-FY19-122018-008718-B	<1
WS- 008719	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 102	WF-10232018-008719	12/10/2018	FT-FY19-122018-008719-A	<1	FT-FY19-122018-008719-B	<1
WS- 008720	4/3/2018	4/3/2019	1	Cooler	In classroom 102	WF-04032018-008720	12/10/2018	FT-FY19-122018-008720-A	<1	FT-FY19-122018-008720-B	<1
WS- 008721	4/3/2018	4/3/2019	1	Cooler	In classroom 101	WF-04032018-008721	12/10/2018	FT-FY19-122018-008721-A	<1	FT-FY19-122018-008721-B	<1
WS- 008722	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 101	WF-10232018-008722	12/10/2018	FT-FY19-122018-008722-A	<1	FT-FY19-122018-008722-B	<1
WS- 008732	4/3/2018	4/3/2019	1	Cooler	In classroom 110	WF-04032018-008732	12/10/2018	FT-FY19-122018-008732-A	<1	FT-FY19-122018-008732-B	<1
WS- 008733	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 110	WF-10232018-008733	12/10/2018	FT-FY19-122018-008733-A	<1	FT-FY19-122018-008733-B	<1
WS- 008734	4/3/2018	4/3/2019	1	Cooler	In classroom 109	WF-04032018-008734	12/10/2018	FT-FY19-122018-008734-A	<1	FT-FY19-122018-008734-B	<1
WS- 008735	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 109	WF-10232018-008735	12/10/2018	FT-FY19-122018-008735-A	<1	FT-FY19-122018-008735-B	<1
WS- 008736	4/3/2018	4/3/2019	2	Cooler	In hallway adjacent to southwest stairwell	WF-04032018-008736	12/10/2018	FT-FY19-122018-008736-A	<1	FT-FY19-122018-008736-B	<1
WS- 008737	4/3/2018	4/3/2019	2	Cooler	In hallway adjacent to room 206	WF-04032018-008737	12/10/2018	FT-FY19-122018-008737-A	<1	FT-FY19-122018-008737-B	<1
WS- 008738	4/3/2018	4/3/2019	2	Health Suite	In health suite 215	WF-04032018-008738	12/10/2018	FT-FY19-122018-008738-A	1	FT-FY19-122018-008738-B	<1
WS- 008739	4/3/2018	4/3/2019	3	Cooler	In hallway adjacent to room 309	WF-04032018-008739	12/10/2018	FT-FY19-122018-008739-A	<1	FT-FY19-122018-008739-B	<1
WS- 008746	4/3/2018	4/3/2019	3	Cooler	In hallway adjacent to room 305	WF-04032018-008746	12/10/2018	FT-FY19-122018-008746-A	<1	FT-FY19-122018-008746-B	<1
WS- 008829	7/24/2018	7/24/2019	2	Cooler	In hallway adjacent to gym High Left	WF-07242018-008829	12/10/2018	FT-FY19-122018-008829-A	<1	FT-FY19-122018-008829-B	<1
WS- 008830	7/24/2018	7/24/2019	2	Cooler	In hallway adjacent to gym Low Right	WF-07242018-008830	12/10/2018	FT-FY19-122018-008830-A	<1	FT-FY19-122018-008830-B	<1
WS- 008831	7/24/2018	7/24/2019	2	Bottle Filler	In hallway adjacent to gym	WF-07242018-008831	12/10/2018	FT-FY19-122018-008831-A	<1	FT-FY19-122018-008831-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008710	1	Food Prep Sink	In kitchen first clockwise from entry door	12/10/2018	FT-FY19-122018-008710-A	<1	FT-FY19-122018-008710-B	<1	
WS- 008712	1	Food Prep Sink	In kitchen second clockwise from entry door	12/10/2018	FT-FY19-122018-008712-A	<1	FT-FY19-122018-008712-B	<1	
WS- 008713	1	Food Prep Sink	In kitchen third clockwise from entry door	12/10/2018	FT-FY19-122018-008713-A	<1	FT-FY19-122018-008713-B	<1	
WS- 008714	1	Food Prep Sink	In kitchen fourth clockwise from entry door	12/10/2018	FT-FY19-122018-008714-A	<1	FT-FY19-122018-008714-B	<1	
WS- 008715	1	Food Prep Sink	In kitchen fifth clockwise from entry door	12/10/2018	FT-FY19-122018-008715-A	<1	FT-FY19-122018-008715-B	<1	