



School w/out Walls @ Francis Stevens Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008705	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent to southwest stairwell	WF-03252019-008705	12/31/2019	FT-FY20-122019-008705-A	<1	FT-FY20-122019-008705-B	<1	
WS- 008707	9/4/2019	9/4/2020	1	Bottle Filler	In cafeteria (bottle filler)	WF-09042019-008707	12/31/2019	FT-FY20-122019-008707-A	<1	FT-FY20-122019-008707-B	<1	
WS- 008708	9/4/2019	9/4/2020	1	Cooler	In cafeteria	High Left	WF-09042019-008708	12/31/2019	FT-FY20-122019-008708-A	<1	FT-FY20-122019-008708-B	<1
WS- 008709	9/4/2019	9/4/2020	1	Cooler	In cafeteria	Low Right	WF-09042019-008709	12/31/2019	FT-FY20-122019-008709-A	<1	FT-FY20-122019-008709-B	<1
WS- 008716	3/25/2019	3/25/2020	1	Ice Maker	In kitchen (ice maker)	WF-03252019-008716	12/31/2019	FT-FY20-122019-008716-A	<1	FT-FY20-122019-008716-B	<1	
WS- 008717	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom 104	WF-10162019-008717	12/31/2019	FT-FY20-122019-008717-A	<1	FT-FY20-122019-008717-B	<1	
WS- 008718	3/25/2019	3/25/2020	1	Cooler	In classroom 104	WF-03252019-008718	12/31/2019	FT-FY20-122019-008718-A	<1	FT-FY20-122019-008718-B	<1	
WS- 008719	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom 102	WF-10162019-008719	12/31/2019	FT-FY20-122019-008719-A	<1	FT-FY20-122019-008719-B	<1	
WS- 008720	3/25/2019	3/25/2020	1	Cooler	In classroom 102	WF-03252019-008720	12/31/2019	FT-FY20-122019-008720-A	<1	FT-FY20-122019-008720-B	<1	
WS- 008721	3/25/2019	3/25/2020	1	Cooler	In classroom 101	WF-03252019-008721	12/31/2019	FT-FY20-122019-008721-A	<1	FT-FY20-122019-008721-B	<1	
WS- 008722	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom 101	WF-10162019-008722	12/31/2019	FT-FY20-122019-008722-A	<1	FT-FY20-122019-008722-B	<1	
WS- 008732	3/25/2019	3/25/2020	1	Cooler	In classroom 110	WF-03252019-008732	12/31/2019	FT-FY20-122019-008732-A	<1	FT-FY20-122019-008732-B	<1	
WS- 008733	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom 110	WF-10162019-008733	12/31/2019	FT-FY20-122019-008733-A	<1	FT-FY20-122019-008733-B	<1	
WS- 008734	3/25/2019	3/25/2020	1	Cooler	In classroom 109	WF-03252019-008734	12/31/2019	FT-FY20-122019-008734-A	<1	FT-FY20-122019-008734-B	<1	
WS- 008735	10/16/2019	10/16/2020	1	Classroom Faucet	In classroom 109	WF-10162019-008735	12/31/2019	FT-FY20-122019-008735-A	<1	FT-FY20-122019-008735-B	<1	
WS- 008736	3/25/2019	3/25/2020	2	Cooler	In hallway adjacent to southwest stairwell	WF-03252019-008736	12/31/2019	FT-FY20-122019-008736-A	1.1	FT-FY20-122019-008736-B	<1	
WS- 008737	3/25/2019	3/25/2020	2	Cooler	In hallway adjacent to room 206	WF-03252019-008737	12/31/2019	FT-FY20-122019-008737-A	<1	FT-FY20-122019-008737-B	<1	
WS- 008738	3/25/2019	3/25/2020	2	Health Suite	In health suite 215	WF-03252019-008738	12/31/2019	FT-FY20-122019-008738-A	<1	FT-FY20-122019-008738-B	<1	
WS- 008739	3/25/2019	3/25/2020	3	Cooler	In hallway adjacent to room 309	WF-03252019-008739	12/31/2019	FT-FY20-122019-008739-A	<1	FT-FY20-122019-008739-B	<1	
WS- 008746	3/25/2019	3/25/2020	3	Cooler	In hallway adjacent to room 305	WF-03252019-008746	12/31/2019	FT-FY20-122019-008746-A	<1	FT-FY20-122019-008746-B	<1	
WS- 008829	9/4/2019	9/4/2020	2	Cooler	In hallway adjacent to gym	High Left	WF-09042019-008829	12/31/2019	FT-FY20-122019-008829-A	<1	FT-FY20-122019-008829-B	<1
WS- 008830	9/4/2019	9/4/2020	2	Cooler	In hallway adjacent to gym	Low Right	WF-09042019-008830	12/31/2019	FT-FY20-122019-008830-A	<1	FT-FY20-122019-008830-B	<1
WS- 008831	9/4/2019	9/4/2020	2	Bottle Filler	In hallway adjacent to gym	WF-09042019-008831	12/31/2019	FT-FY20-122019-008831-A	<1	FT-FY20-122019-008831-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008710	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-07222019-008710	12/31/2019	FT-FY20-122019-008710-A	<1	FT-FY20-122019-008710-B	<1
WS- 008712	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen second clockwise from entry door	WF-07222019-008712	12/31/2019	FT-FY20-122019-008712-A	<1	FT-FY20-122019-008712-B	<1
WS- 008713	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen third clockwise from entry door	WF-07222019-008713	12/31/2019	FT-FY20-122019-008713-A	<1	FT-FY20-122019-008713-B	<1
WS- 008714	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-07222019-008714	12/31/2019	FT-FY20-122019-008714-A	<1	FT-FY20-122019-008714-B	<1
WS- 008715	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen fifth clockwise from entry door	WF-07222019-008715	12/31/2019	FT-FY20-122019-008715-A	<1	FT-FY20-122019-008715-B	<1