



School without Walls High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012081	4/25/2022	4/25/2023	3	Cooler	In hallway adjacent to elevator	High Left	WF-04252022-012081	2/14/2023	FT-FY23-01262023-012081-A	<1	FT-FY23-01262023-012081-B	<1
WS- 012082	4/25/2022	4/25/2023	3	Cooler	In hallway adjacent to elevator	Low Right	WF-04252022-012082	2/14/2023	FT-FY23-01262023-012082-A	<1	FT-FY23-01262023-012082-B	<1
WS- 012084	4/25/2022	4/25/2023	3	Break Room	In break room		WF-04252022-012084	2/14/2023	FT-FY23-01262023-012084-A	<1	FT-FY23-01262023-012084-B	<1
WS- 012086	4/25/2022	4/25/2023	2	Cooler	In hallway adjacent to elevator	High Left	WF-04252022-012086	2/14/2023	FT-FY23-01262023-012086-A	<1	FT-FY23-01262023-012086-B	<1
WS- 012087	4/25/2022	4/25/2023	2	Cooler	In hallway adjacent to elevator	Low Right	WF-04252022-012087	2/14/2023	FT-FY23-01262023-012087-A	<1	FT-FY23-01262023-012087-B	<1
WS- 012089	4/25/2022	4/25/2023	1	Cooler	In hallway adjacent to elevator	Low Right	WF-04252022-012089	2/14/2023	FT-FY23-01262023-012089-A	<1	FT-FY23-01262023-012089-B	<1
WS- 012091	4/25/2022	4/25/2023	1	Health Suite	In health suite		WF-04252022-012091	2/14/2023	FT-FY23-01262023-012091-A	<1	FT-FY23-01262023-012091-B	<1
WS- 012136	4/25/2022	4/25/2023	Basement	Cooler	In hallway adjacent to elevator	High Left	WF-04252022-012136	2/14/2023	FT-FY23-01262023-012136-A	<1	FT-FY23-01262023-012136-B	<1
WS- 012137	4/25/2022	4/25/2023	Basement	Cooler	In hallway adjacent to elevator	Low Right	WF-04252022-012137	2/14/2023	FT-FY23-01262023-012137-A	<1	FT-FY23-01262023-012137-B	<1
WS- 012141	4/25/2022	4/25/2023	3	Bottle Filler	In hallway adjacent to elevator		WF-04252022-012141	2/14/2023	FT-FY23-01262023-012141-A	<1	FT-FY23-01262023-012141-B	<1
WS- 012142	4/25/2022	4/25/2023	2	Bottle Filler	In hallway adjacent to elevator		WF-04252022-012142	2/14/2023	FT-FY23-01262023-012142-A	<1	FT-FY23-01262023-012142-B	<1
WS- 012143	4/25/2022	4/25/2023	1	Bottle Filler	In hallway adjacent to elevator		WF-04252022-012143	2/14/2023	FT-FY23-01262023-012143-A	<1	FT-FY23-01262023-012143-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	2/23/2022	2/23/2023	1	Food Prep Sink	In kitchen		WF-02232022-012090	2/14/2023	FT-FY23-01262023-012090-A	<1	FT-FY23-01262023-012090-B	<1