



School without Walls HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-012081	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to elevator High Left	WF-06042019-012081	1/15/2020	FT-FY20-012020-012081-A	<1	FT-FY20-012020-012081-B	<1
WS-012082	6/4/2019	6/4/2020	3	Cooler	In hallway adjacent to elevator Low Right	WF-06042019-012082	1/15/2020	FT-FY20-012020-012082-A	<1	FT-FY20-012020-012082-B	<1
WS-012084	6/4/2019	6/4/2020	3	Break Room	In break room	WF-06042019-012084	1/15/2020	FT-FY20-012020-012084-A	<1	FT-FY20-012020-012084-B	<1
WS-012086	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to elevator High Left	WF-06042019-012086	1/15/2020	FT-FY20-012020-012086-A	<1	FT-FY20-012020-012086-B	<1
WS-012087	6/4/2019	6/4/2020	2	Cooler	In hallway adjacent to elevator Low Right	WF-06042019-012087	1/15/2020	FT-FY20-012020-012087-A	<1	FT-FY20-012020-012087-B	<1
WS-012088	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to elevator High Left	WF-06042019-012088	1/15/2020	FT-FY20-012020-012088-A	<1	FT-FY20-012020-012088-B	<1
WS-012089	6/4/2019	6/4/2020	1	Cooler	In hallway adjacent to elevator Low Right	WF-06042019-012089	1/15/2020	FT-FY20-012020-012089-A	<1	FT-FY20-012020-012089-B	<1
WS-012091	6/4/2019	6/4/2020	1	Health Suite	In health suite	WF-06042019-012091	1/15/2020	FT-FY20-012020-012091-A	<1	FT-FY20-012020-012091-B	<1
WS-012106	6/5/2019	6/5/2020	Basement	Classroom Faucet	In science lab prep room 013 first clockwise from entry door	WF-06052019-012106	1/15/2020	FT-FY20-012020-012106-A	<1	FT-FY20-012020-012106-B	<1
WS-012136	6/4/2019	6/4/2020	Basement	Cooler	In hallway adjacent to elevator High Left	WF-06042019-012136	1/15/2020	FT-FY20-012020-012136-A	<1	FT-FY20-012020-012136-B	<1
WS-012137	6/4/2019	6/4/2020	Basement	Cooler	In hallway adjacent to elevator Low Right	WF-06042019-012137	1/15/2020	FT-FY20-012020-012137-A	<1	FT-FY20-012020-012137-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-012090	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen	WF-07032019-012090	1/15/2020	FT-FY20-012020-012090-A	<1	FT-FY20-012020-012090-B	<1