



# School without Walls High School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012081	5/4/2021	5/4/2022	3	Cooler	In hallway adjacent to elevator	High Left	WF-05042021-012081	3/9/2022	FT-FY22-02212022-012081-A	<1	FT-FY22-02212022-012081-B	<1
WS- 012082	5/4/2021	5/4/2022	3	Cooler	In hallway adjacent to elevator	Low Right	WF-05042021-012082	3/9/2022	FT-FY22-02212022-012082-A	<1	FT-FY22-02212022-012082-B	<1
WS- 012084	5/4/2021	5/4/2022	3	Break Room	In break room		WF-05042021-012084	3/9/2022	FT-FY22-02212022-012084-A	<1	FT-FY22-02212022-012084-B	<1
WS- 012086	5/4/2021	5/4/2022	2	Cooler	In hallway adjacent to elevator	High Left	WF-05042021-012086	3/9/2022	FT-FY22-02212022-012086-A	<1	FT-FY22-02212022-012086-B	<1
WS- 012087	5/4/2021	5/4/2022	2	Cooler	In hallway adjacent to elevator	Low Right	WF-05042021-012087	3/9/2022	FT-FY22-02212022-012087-A	<1	FT-FY22-02212022-012087-B	<1
WS- 012088	5/4/2021	5/4/2022	1	Cooler	In hallway adjacent to elevator	High Left	WF-05042021-012088	3/9/2022	FT-FY22-02212022-012088-A	<1	FT-FY22-02212022-012088-B	<1
WS- 012089	5/4/2021	5/4/2022	1	Cooler	In hallway adjacent to elevator	Low Right	WF-05042021-012089	3/9/2022	FT-FY22-02212022-012089-A	<1	FT-FY22-02212022-012089-B	<1
WS- 012091	5/4/2021	5/4/2022	1	Health Suite	In health suite		WF-05042021-012091	3/9/2022	FT-FY22-02212022-012091-A	<1	FT-FY22-02212022-012091-B	<1
WS- 012136	5/4/2021	5/4/2022	Basement	Cooler	In hallway adjacent to elevator	High Left	WF-05042021-012136	3/9/2022	FT-FY22-02212022-012136-A	<1	FT-FY22-02212022-012136-B	<1
WS- 012137	5/4/2021	5/4/2022	Basement	Cooler	In hallway adjacent to elevator	Low Right	WF-05042021-012137	3/9/2022	FT-FY22-02212022-012137-A	<1	FT-FY22-02212022-012137-B	<1
WS- 012141	5/4/2021	5/4/2022	3	Bottle Filler	In hallway adjacent to elevator		WF-05042021-012141	3/9/2022	FT-FY22-02212022-012141-A	<1	FT-FY22-02212022-012141-B	<1
WS- 012143	5/4/2021	5/4/2022	1	Bottle Filler	In hallway adjacent to elevator		WF-05042021-012143	3/9/2022	FT-FY22-02212022-012143-A	<1	FT-FY22-02212022-012143-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	4/8/2021	4/8/2022	1	Food Prep Sink	In kitchen		WF-04082021-012090	3/9/2022	FT-FY22-02212022-012090-A	<1	FT-FY22-02212022-012090-B	<1