



School without Walls High School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012084	6/2/2020	6/2/2021	3	Break Room	In break room	WF-06022020-012084	4/2/2021	FT-FY21-032021-012084-A	<1	FT-FY21-032021-012084-B	<1
WS- 012091	6/2/2020	6/2/2021	1	Health Suite	In health suite	WF-06022020-012091	4/2/2021	FT-FY21-032021-012091-A	<1	FT-FY21-032021-012091-B	<1
WS- 012136	6/2/2020	6/2/2021	Basement	Cooler	In hallway adjacent to elevator High Left	WF-06022020-012136	4/2/2021	FT-FY21-032021-012136-A	<1	FT-FY21-032021-012136-B	<1
WS- 012137	6/2/2020	6/2/2021	Basement	Cooler	In hallway adjacent to elevator Low Right	WF-06022020-012137	4/2/2021	FT-FY21-032021-012137-A	<1	FT-FY21-032021-012137-B	<1
WS- 012141	6/2/2020	6/2/2021	3	Bottle Filler	In hallway adjacent to elevator	WF-06022020-012141	4/2/2021	FT-FY21-032021-012141-A	<1	FT-FY21-032021-012141-B	<1
WS- 012143	6/2/2020	6/2/2021	1	Bottle Filler	In hallway adjacent to elevator	WF-06022020-012143	4/2/2021	FT-FY21-032021-012143-A	<1	FT-FY21-032021-012143-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	2/22/2021	2/22/2022	1	Food Prep Sink	In kitchen	WF-02222021-012090	4/2/2021	FT-FY21-032021-012090-A	25.0	FT-FY21-032021-012090-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	4/8/2021	4/8/2022	1	Food Prep Sink	In kitchen	WF-04082021-012090	4/22/2021	FT-FY21-042021-012090-A	<1	FT-FY21-042021-012090-B	<1