



School Without Walls HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012081	6/8/2018	6/8/2019	3	Cooler	In hallway adjacent to elevator	High Left	WF-06082018-012081	1/14/2019	FT-FY19-012019-012081-A	<1	FT-FY19-012019-012081-B	<1
WS- 012082	6/8/2018	6/8/2019	3	Cooler	In hallway adjacent to elevator	Low Right	WF-06082018-012082	1/14/2019	FT-FY19-012019-012082-A	<1	FT-FY19-012019-012082-B	<1
WS- 012084	6/8/2018	6/8/2019	3	Break Room	In break room		WF-06082018-012084	1/14/2019	FT-FY19-012019-012084-A	<1	FT-FY19-012019-012084-B	<1
WS- 012086	6/8/2018	6/8/2019	2	Cooler	In hallway adjacent to elevator	High Left	WF-06082018-012086	1/14/2019	FT-FY19-012019-012086-A	<1	FT-FY19-012019-012086-B	<1
WS- 012087	6/8/2018	6/8/2019	2	Cooler	In hallway adjacent to elevator	Low Right	WF-06082018-012087	1/14/2019	FT-FY19-012019-012087-A	<1	FT-FY19-012019-012087-B	<1
WS- 012088	6/8/2018	6/8/2019	1	Cooler	In hallway adjacent to elevator	High Left	WF-06082018-012088	1/14/2019	FT-FY19-012019-012088-A	<1	FT-FY19-012019-012088-B	<1
WS- 012089	6/8/2018	6/8/2019	1	Cooler	In hallway adjacent to elevator	Low Right	WF-06082018-012089	1/14/2019	FT-FY19-012019-012089-A	<1	FT-FY19-012019-012089-B	<1
WS- 012091	6/8/2018	6/8/2019	1	Health Suite	In health suite		WF-06082018-012091	1/14/2019	FT-FY19-012019-012091-A	<1	FT-FY19-012019-012091-B	<1
WS- 012136	6/8/2018	6/8/2019	Basement	Cooler	In hallway adjacent to elevator	High Left	WF-06082018-012136	1/14/2019	FT-FY19-012019-012136-A	<1	FT-FY19-012019-012136-B	<1
WS- 012137	6/8/2018	6/8/2019	Basement	Cooler	In hallway adjacent to elevator	Low Right	WF-06082018-012137	1/14/2019	FT-FY19-012019-012137-A	<1	FT-FY19-012019-012137-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	1	Food Prep Sink	In kitchen		1/14/2019	FT-FY19-012019-012090-A	<1	FT-FY19-012019-012090-B	<1