



# Seaton Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002498	11/23/2020	11/23/2021	1	Bottle Filler	In gym/cafeteria	WF-11232020-002498	2/25/2021	FT-FY21-022021-002498-A	<1	FT-FY21-022021-002498-B	<1	
WS- 002501	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to room 106	Right	WF-06092020-002501	2/25/2021	FT-FY21-022021-002501-A	<1	FT-FY21-022021-002501-B	<1
WS- 002502	6/9/2020	6/9/2021	1	Cooler	In hallway adjacent to room 106	Left	WF-06092020-002502	2/25/2021	FT-FY21-022021-002502-A	<1	FT-FY21-022021-002502-B	<1
WS- 002503	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 109	Left	WF-09102020-002503	2/25/2021	FT-FY21-022021-002503-A	<1	FT-FY21-022021-002503-B	<1
WS- 002504	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 109	Right	WF-06092020-002504	2/25/2021	FT-FY21-022021-002504-A	<1	FT-FY21-022021-002504-B	<1
WS- 002505	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 111	Left	WF-09102020-002505	2/25/2021	FT-FY21-022021-002505-A	<1	FT-FY21-022021-002505-B	<1
WS- 002506	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 111	Right	WF-06092020-002506	2/25/2021	FT-FY21-022021-002506-A	<1	FT-FY21-022021-002506-B	<1
WS- 002507	6/9/2020	6/9/2021	1	Health Suite	In health suite in restroom		WF-06092020-002507	2/25/2021	FT-FY21-022021-002507-A	<1	FT-FY21-022021-002507-B	<1
WS- 002508	9/10/2020	9/10/2021	1	Classroom Faucet	In classroom 113		WF-09102020-002508	2/25/2021	FT-FY21-022021-002508-A	<1	FT-FY21-022021-002508-B	<1
WS- 002509	11/23/2020	11/23/2021	1	Cooler	In gym/cafeteria		WF-11232020-002509	2/25/2021	FT-FY21-022021-002509-A	<1	FT-FY21-022021-002509-B	<1
WS- 002514	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 122	Left	WF-09102020-002514	2/25/2021	FT-FY21-022021-002514-A	<1	FT-FY21-022021-002514-B	<1
WS- 002515	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 122	Right	WF-06092020-002515	2/25/2021	FT-FY21-022021-002515-A	<1	FT-FY21-022021-002515-B	<1
WS- 002516	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 125	Left	WF-09102020-002516	2/25/2021	FT-FY21-022021-002516-A	<1	FT-FY21-022021-002516-B	<1
WS- 002517	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 125	Right	WF-06092020-002517	2/25/2021	FT-FY21-022021-002517-A	<1	FT-FY21-022021-002517-B	<1
WS- 002518	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 124	Left	WF-09102020-002518	2/25/2021	FT-FY21-022021-002518-A	<1	FT-FY21-022021-002518-B	1.1
WS- 002519	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 124	Right	WF-06092020-002519	2/25/2021	FT-FY21-022021-002519-A	<1	FT-FY21-022021-002519-B	<1
WS- 002520	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 127	Left	WF-09102020-002520	2/25/2021	FT-FY21-022021-002520-A	<1	FT-FY21-022021-002520-B	<1
WS- 002521	6/9/2020	6/9/2021	1	Combo Fountain	In classroom 127	Right	WF-06092020-002521	2/25/2021	FT-FY21-022021-002521-A	<1	FT-FY21-022021-002521-B	<1
WS- 002522	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to room 206	Left	WF-06092020-002522	2/25/2021	FT-FY21-022021-002522-A	<1	FT-FY21-022021-002522-B	<1
WS- 002523	6/9/2020	6/9/2021	2	Cooler	In hallway adjacent to room 206	Right	WF-06092020-002523	2/25/2021	FT-FY21-022021-002523-A	<1	FT-FY21-022021-002523-B	<1
WS- 002524	6/9/2020	6/9/2021	2	Break Room	In staff lounge 204		WF-06092020-002524	2/25/2021	FT-FY21-022021-002524-A	<1	FT-FY21-022021-002524-B	<1
WS- 002525	9/10/2020	9/10/2021	2	Classroom Faucet	In classroom 210	Left	WF-09102020-002525	2/25/2021	FT-FY21-022021-002525-A	<1	FT-FY21-022021-002525-B	<1
WS- 002527	6/9/2020	6/9/2021	3	Cooler	In hallway adjacent to room 306	Left	WF-06092020-002527	2/25/2021	FT-FY21-022021-002527-A	<1	FT-FY21-022021-002527-B	<1
WS- 002528	6/9/2020	6/9/2021	3	Cooler	In hallway adjacent to room 306	Right	WF-06092020-002528	2/25/2021	FT-FY21-022021-002528-A	<1	FT-FY21-022021-002528-B	<1
WS- 002529	9/10/2020	9/10/2021	3	Combo Faucet	In classroom 307	Left	WF-09102020-002529	2/25/2021	FT-FY21-022021-002529-A	3.2	FT-FY21-022021-002529-B	<1
WS- 002530	6/9/2020	6/9/2021	3	Combo Fountain	In classroom 307	Right	WF-06092020-002530	2/25/2021	FT-FY21-022021-002530-A	<1	FT-FY21-022021-002530-B	<1
WS- 002531	9/10/2020	9/10/2021	3	Combo Faucet	In classroom 309	Left	WF-09102020-002531	2/25/2021	FT-FY21-022021-002531-A	<1	FT-FY21-022021-002531-B	<1
WS- 002532	6/9/2020	6/9/2021	3	Combo Fountain	In classroom 309	Right	WF-06092020-002532	2/25/2021	FT-FY21-022021-002532-A	<1	FT-FY21-022021-002532-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002510	2/19/2021	2/19/2022	1	Food Prep Sink	In kitchen	Right	WF-02192021-002510	2/25/2021	FT-FY21-022021-002510-A	<1	FT-FY21-022021-002510-B	<1
WS- 002511	2/19/2021	2/19/2022	1	Food Prep Sink	In kitchen	Mid	WF-02192021-002511	2/25/2021	FT-FY21-022021-002511-A	<1	FT-FY21-022021-002511-B	<1