



Seaton Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002498	9/11/2024	9/11/2025	1	Bottle Filler	In gym/cafeteria	WF-09112024-002498	1/8/2025	FT-FY25-12042024-002498-A	<2	FT-FY25-12042024-002498-B	<2	
WS- 002501	4/24/2024	4/24/2025	1	Cooler	In hallway adjacent to room 106	Right	WF-04242024-002501	1/8/2025	FT-FY25-12042024-002501-A	<2	FT-FY25-12042024-002501-B	<2
WS- 002502	4/24/2024	4/24/2025	1	Cooler	In hallway adjacent to room 106	Left	WF-04242024-002502	1/8/2025	FT-FY25-12042024-002502-A	<2	FT-FY25-12042024-002502-B	<2
WS- 002503	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 109	Left	WF-08152024-002503	1/8/2025	FT-FY25-12042024-002503-A	<2	FT-FY25-12042024-002503-B	<2
WS- 002504	4/24/2024	4/24/2025	1	Combo Fountain	In classroom 109	Right	WF-04242024-002504	1/8/2025	FT-FY25-12042024-002504-A	<2	FT-FY25-12042024-002504-B	<2
WS- 002505	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 111	Left	WF-08152024-002505	1/8/2025	FT-FY25-12042024-002505-A	<2	FT-FY25-12042024-002505-B	<2
WS- 002506	4/24/2024	4/24/2025	1	Combo Fountain	In classroom 111	Right	WF-04242024-002506	1/8/2025	FT-FY25-12042024-002506-A	<2	FT-FY25-12042024-002506-B	<2
WS- 002507	4/24/2024	4/24/2025	1	Health Suite	In health suite in restroom		WF-04242024-002507	1/8/2025	FT-FY25-12042024-002507-A	<2	FT-FY25-12042024-002507-B	<2
WS- 002508	8/15/2024	8/15/2025	1	Classroom Faucet	In classroom 113		WF-08152024-002508	1/8/2025	FT-FY25-12042024-002508-A	<2	FT-FY25-12042024-002508-B	<2
WS- 002509	9/11/2024	9/11/2025	1	Cooler	In gym/cafeteria		WF-09112024-002509	1/8/2025	FT-FY25-12042024-002509-A	<2	FT-FY25-12042024-002509-B	<2
WS- 002514	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 122	Left	WF-08152024-002514	1/8/2025	FT-FY25-12042024-002514-A	<2	FT-FY25-12042024-002514-B	<2
WS- 002516	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 125	Left	WF-08152024-002516	1/8/2025	FT-FY25-12042024-002516-A	<2	FT-FY25-12042024-002516-B	<2
WS- 002517	4/24/2024	4/24/2025	1	Combo Fountain	In classroom 125	Right	WF-04242024-002517	1/8/2025	FT-FY25-12042024-002517-A	<2	FT-FY25-12042024-002517-B	<2
WS- 002518	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 124	Left	WF-08152024-002518	1/8/2025	FT-FY25-12042024-002518-A	<2	FT-FY25-12042024-002518-B	<2
WS- 002519	4/24/2024	4/24/2025	1	Combo Fountain	In classroom 124	Right	WF-04242024-002519	1/8/2025	FT-FY25-12042024-002519-A	<2	FT-FY25-12042024-002519-B	<2
WS- 002520	8/15/2024	8/15/2025	1	Combo Faucet	In classroom 127	Left	WF-08152024-002520	1/8/2025	FT-FY25-12042024-002520-A	<2	FT-FY25-12042024-002520-B	<2
WS- 002521	4/24/2024	4/24/2025	1	Combo Fountain	In classroom 127	Right	WF-04242024-002521	1/8/2025	FT-FY25-12042024-002521-A	<2	FT-FY25-12042024-002521-B	<2
WS- 002522	4/24/2024	4/24/2025	2	Cooler	In hallway adjacent to room 206	Left	WF-04242024-002522	1/8/2025	FT-FY25-12042024-002522-A	<2	FT-FY25-12042024-002522-B	<2
WS- 002523	4/24/2024	4/24/2025	2	Cooler	In hallway adjacent to room 206	Right	WF-04242024-002523	1/8/2025	FT-FY25-12042024-002523-A	<2	FT-FY25-12042024-002523-B	<2
WS- 002524	4/24/2024	4/24/2025	2	Break Room	In staff lounge 204		WF-04242024-002524	1/8/2025	FT-FY25-12042024-002524-A	<2	FT-FY25-12042024-002524-B	<2
WS- 002525	8/15/2024	8/15/2025	2	Classroom Faucet	In classroom 210	Left	WF-08152024-002525	1/8/2025	FT-FY25-12042024-002525-A	<2	FT-FY25-12042024-002525-B	<2
WS- 002527	4/24/2024	4/24/2025	3	Cooler	In hallway adjacent to room 306	Left	WF-04242024-002527	1/8/2025	FT-FY25-12042024-002527-A	<2	FT-FY25-12042024-002527-B	<2
WS- 002528	4/24/2024	4/24/2025	3	Cooler	In hallway adjacent to room 306	Right	WF-04242024-002528	1/8/2025	FT-FY25-12042024-002528-A	<2	FT-FY25-12042024-002528-B	<2
WS- 002529	8/15/2024	8/15/2025	3	Combo Faucet	In classroom 307	Left	WF-08152024-002529	1/8/2025	FT-FY25-12042024-002529-A	<2	FT-FY25-12042024-002529-B	<2
WS- 002530	4/24/2024	4/24/2025	3	Combo Fountain	In classroom 307	Right	WF-04242024-002530	1/8/2025	FT-FY25-12042024-002530-A	<2	FT-FY25-12042024-002530-B	<2
WS- 002532	4/24/2024	4/24/2025	3	Combo Fountain	In classroom 309	Right	WF-04242024-002532	1/8/2025	FT-FY25-12042024-002532-A	<2	FT-FY25-12042024-002532-B	<2
WS- 002496	4/24/2024	4/24/2025	Ground Floor	Exterior Fountain	Outside on the playground	Left	WF-04242024-002496	1/8/2025	FT-FY25-12042024-002496-A	<2	FT-FY25-12042024-002496-B	<2
WS- 002497	4/24/2024	4/24/2025	Ground Floor	Exterior Fountain	Outside on the playground	Right	WF-04242024-002497	1/8/2025	FT-FY25-12042024-002497-A	<2	FT-FY25-12042024-002497-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002510	12/30/2024	12/30/2025	1	Food Prep Sink	In kitchen	Right	WF-12302024-002510	1/8/2025	FT-FY25-12042024-002510-A	<2	FT-FY25-12042024-002510-B	<2
WS- 002511	12/30/2024	12/30/2025	1	Food Prep Sink	In kitchen	Mid	WF-12302024-002511	1/8/2025	FT-FY25-12042024-002511-A	<2	FT-FY25-12042024-002511-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.