



Seaton ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002501	4/17/2025	4/17/2026	1	Cooler	In hallway adjacent to room 106	Right	WF-04172025-002501	1/20/2026	FT-FY26-12302025-002501-A	<2	FT-FY26-12302025-002501-B	<2
WS- 002502	4/17/2025	4/17/2026	1	Cooler	In hallway adjacent to room 106	Left	WF-04172025-002502	1/20/2026	FT-FY26-12302025-002502-A	<2	FT-FY26-12302025-002502-B	<2
WS- 002503	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 109	Left	WF-08072025-002503	1/20/2026	FT-FY26-12302025-002503-A	<2	FT-FY26-12302025-002503-B	<2
WS- 002504	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 109	Right	WF-04172025-002504	1/20/2026	FT-FY26-12302025-002504-A	<2	FT-FY26-12302025-002504-B	<2
WS- 002505	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 111	Left	WF-08072025-002505	1/20/2026	FT-FY26-12302025-002505-A	<2	FT-FY26-12302025-002505-B	<2
WS- 002506	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 111	Right	WF-04172025-002506	1/20/2026	FT-FY26-12302025-002506-A	<2	FT-FY26-12302025-002506-B	<2
WS- 002507	4/17/2025	4/17/2026	1	Health Suite	In health suite in restroom		WF-04172025-002507	1/20/2026	FT-FY26-12302025-002507-A	2.2	FT-FY26-12302025-002507-B	<2
WS- 002508	8/7/2025	8/7/2026	1	Classroom Faucet	In classroom 113		WF-08072025-002508	1/20/2026	FT-FY26-12302025-002508-A	<2	FT-FY26-12302025-002508-B	<2
WS- 002509	5/30/2025	5/30/2026	1	Cooler	In gym/cafeteria		WF-05302025-002509	1/20/2026	FT-FY26-12302025-002509-A	<2	FT-FY26-12302025-002509-B	<2
WS- 002514	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 122	Left	WF-08072025-002514	1/20/2026	FT-FY26-12302025-002514-A	<2	FT-FY26-12302025-002514-B	<2
WS- 002515	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 122	Right	WF-04172025-002515	1/20/2026	FT-FY26-12302025-002515-A	<2	FT-FY26-12302025-002515-B	<2
WS- 002516	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 125	Left	WF-08072025-002516	1/20/2026	FT-FY26-12302025-002516-A	<2	FT-FY26-12302025-002516-B	<2
WS- 002517	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 125	Right	WF-04172025-002517	1/20/2026	FT-FY26-12302025-002517-A	<2	FT-FY26-12302025-002517-B	<2
WS- 002518	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 124	Left	WF-08072025-002518	1/20/2026	FT-FY26-12302025-002518-A	<2	FT-FY26-12302025-002518-B	<2
WS- 002519	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 124	Right	WF-04172025-002519	1/20/2026	FT-FY26-12302025-002519-A	<2	FT-FY26-12302025-002519-B	<2
WS- 002520	8/7/2025	8/7/2026	1	Combo Faucet	In classroom 127	Left	WF-08072025-002520	1/20/2026	FT-FY26-12302025-002520-A	<2	FT-FY26-12302025-002520-B	<2
WS- 002521	4/17/2025	4/17/2026	1	Combo Fountain	In classroom 127	Right	WF-04172025-002521	1/20/2026	FT-FY26-12302025-002521-A	<2	FT-FY26-12302025-002521-B	<2
WS- 002522	4/17/2025	4/17/2026	2	Cooler	In hallway adjacent to room 206	Left	WF-04172025-002522	1/20/2026	FT-FY26-12302025-002522-A	<2	FT-FY26-12302025-002522-B	<2
WS- 002523	4/17/2025	4/17/2026	2	Cooler	In hallway adjacent to room 206	Right	WF-04172025-002523	1/20/2026	FT-FY26-12302025-002523-A	<2	FT-FY26-12302025-002523-B	<2
WS- 002524	4/17/2025	4/17/2026	2	Break Room	In staff lounge 204		WF-04172025-002524	1/20/2026	FT-FY26-12302025-002524-A	<2	FT-FY26-12302025-002524-B	<2
WS- 002527	4/17/2025	4/17/2026	3	Cooler	In hallway adjacent to room 306	Left	WF-04172025-002527	1/20/2026	FT-FY26-12302025-002527-A	<2	FT-FY26-12302025-002527-B	<2
WS- 002528	4/17/2025	4/17/2026	3	Cooler	In hallway adjacent to room 306	Right	WF-04172025-002528	1/20/2026	FT-FY26-12302025-002528-A	<2	FT-FY26-12302025-002528-B	<2
WS- 002529	8/7/2025	8/7/2026	3	Combo Faucet	In classroom 307	Left	WF-08072025-002529	1/20/2026	FT-FY26-12302025-002529-A	<2	FT-FY26-12302025-002529-B	<2
WS- 002530	4/17/2025	4/17/2026	3	Combo Fountain	In classroom 307	Right	WF-04172025-002530	1/20/2026	FT-FY26-12302025-002530-A	<2	FT-FY26-12302025-002530-B	<2
WS- 002531	8/7/2025	8/7/2026	3	Combo Faucet	In classroom 309	Left	WF-08072025-002531	1/20/2026	FT-FY26-12302025-002531-A	<2	FT-FY26-12302025-002531-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002510	12/4/2025	12/4/2026	1	Food Prep Sink	In kitchen	Right	WF-12042025-002510	1/20/2026	FT-FY26-12302025-002510-A	<2	FT-FY26-12302025-002510-B	<2
WS- 002511	12/4/2025	12/4/2026	1	Food Prep Sink	In kitchen	Mid	WF-12042025-002511	1/20/2026	FT-FY26-12302025-002511-A	<2	FT-FY26-12302025-002511-B	<2

FY26 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002525	8/7/2025	8/7/2026	2	Classroom Faucet	In classroom 210	Left	WF-08072025-002525	1/20/2026	FT-FY26-12302025-002525-A	5.2	FT-FY26-12302025-002525-B	<2

First Re-Test (After Plumbing Check)

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002525	2/6/2026	2/6/2027	2	Classroom Faucet	In classroom 210	Left	WF-02062026-002525	2/20/2026	FT-FY26-02172026-002525-A	<2	FT-FY26-02172026-002525-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.