



SEATON ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SEATON ELEMENTARY SCHOOL	WS- 002501	8/24/2016	1	Cooler	In hallway adjacent to room 106	Right	FT-72016-002501-A	< 1	FT-72016-002501-B	< 1
2	SEATON ELEMENTARY SCHOOL	WS- 002502	8/24/2016	1	Cooler	In hallway adjacent to room 106	Left	FT-72016-002502-A	< 1	FT-72016-002502-B	< 1
3	SEATON ELEMENTARY SCHOOL	WS- 002504	8/24/2016	1	Fountain	In classroom 109	Right	FT-72016-002504-A	< 1	FT-72016-002504-B	< 1
4	SEATON ELEMENTARY SCHOOL	WS- 002506	8/24/2016	1	Fountain	In classroom 111	Right	FT-72016-002506-A	< 1	FT-72016-002506-B	< 1
5	SEATON ELEMENTARY SCHOOL	WS- 002507	8/24/2016	1	Health Suite	In health suite in restroom		FT-82016-002507-A	< 1	FT-82016-002507-B	< 1
6	SEATON ELEMENTARY SCHOOL	WS- 002509	8/24/2016	1	Cooler	In gym/cafeteria		FT-72016-002509-A	< 1	FT-72016-002509-B	< 1
7	SEATON ELEMENTARY SCHOOL	WS- 002511	8/24/2016	1	Kitchen	In kitchen	Mid	FT-82016-002511-A	< 1	FT-82016-002511-B	< 1
8	SEATON ELEMENTARY SCHOOL	WS- 002513	8/24/2016	1	Food Prep Sink	In kitchen	Left	FT-82016-002513-A	< 1	FT-82016-002513-B	< 1
9	SEATON ELEMENTARY SCHOOL	WS- 002515	8/24/2016	1	Fountain	In classroom 122	Right	FT-72016-002515-A	< 1	FT-72016-002515-B	< 1
10	SEATON ELEMENTARY SCHOOL	WS- 002517	8/24/2016	1	Fountain	In classroom 125	Right	FT-72016-002517-A	< 1	FT-72016-002517-B	< 1
11	SEATON ELEMENTARY SCHOOL	WS- 002519	8/24/2016	1	Fountain	In classroom 124	Right	FT-72016-002519-A	< 1	FT-72016-002519-B	< 1
12	SEATON ELEMENTARY SCHOOL	WS- 002521	8/24/2016	1	Fountain	In classroom 127	Right	FT-82016-002521-A	< 1	FT-82016-002521-B	< 1
13	SEATON ELEMENTARY SCHOOL	WS- 002522	8/24/2016	2	Cooler	In hallway adjacent to room 206	Left	FT-72016-002522-A	< 1	FT-72016-002522-B	< 1
14	SEATON ELEMENTARY SCHOOL	WS- 002523	8/24/2016	2	Cooler	In hallway adjacent to room 206	Right	FT-72016-002523-A	< 1	FT-72016-002523-B	< 1
15	SEATON ELEMENTARY SCHOOL	WS- 002527	8/24/2016	3	Cooler	In hallway adjacent to room 306	Left	FT-72016-002527-A	< 1	FT-72016-002527-B	< 1
16	SEATON ELEMENTARY SCHOOL	WS- 002528	8/24/2016	3	Cooler	In hallway adjacent to room 306	Right	FT-72016-002528-A	< 1	FT-72016-002528-B	< 1
17	SEATON ELEMENTARY SCHOOL	WS- 002530	8/24/2016	3	Fountain	In classroom 307	Right	FT-72016-002530-A	< 1	FT-72016-002530-B	< 1
18	SEATON ELEMENTARY SCHOOL	WS- 002532	8/24/2016	3	Fountain	In classroom 309	Right	FT-72016-002532-A	< 1	FT-72016-002532-B	< 1