



# SEATON LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002499	Utility	Basement	In boiler room utility sink (water source)	WT-042916-2516- A	5.9	WT-042916-2516- B	< 1				
2 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002500	Classroom	1	In library room 103-105	WT-042916-2517- A	3	WT-042916-2517- B	< 1				
3 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002501	Cooler	1	In hallway adjacent to room 106	Right	WT-042916-2518- A	< 1	WT-042916-2518- B	< 1			
4 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002502	Cooler	1	In hallway adjacent to room 106	Left	WT-042916-2519- A	1.1	WT-042916-2519- B	< 1			
5 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002503	Classroom	1	In classroom 109	Left	WT-042916-2520- A	< 1	WT-042916-2520- B	< 1			
6 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002504	Fountain	1	In classroom 109	Right	WT-042916-2521- A	< 1	WT-042916-2521- B	< 1			
7 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002505	Classroom	1	In room 111	Left	WT-042916-2522- A	< 1	WT-042916-2522- B	< 1			
8 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002506	Fountain	1	In room 111	Right	WT-042916-2523- A	< 1	WT-042916-2523- B	< 1			
9 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002507	Health Suite	1	In health suit	WT-042916-2524- A	1.5	WT-042916-2524- B	< 1				
10 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002508	Classroom	1	In room 113	WT-042916-2525- A	6.6	WT-042916-2525- B	3.8				
11 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002509	Cooler	1	In gym/cafeteria	WT-042916-2526- A	< 1	WT-042916-2526- B	< 1				
12 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002510	Kitchen	1	In kitchen	Right	WT-042916-2527- A	< 1	WT-042916-2527- B	< 1			
13 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002511	Kitchen	1	In kitchen	Mid	WT-042916-2528- A	< 1	WT-042916-2528- B	< 1			
14 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002513	Kitchen	1	In kitchen	Left	WT-042916-2530- A	< 1	WT-042916-2530- B	< 1			
15 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002514	Classroom	1	In room 122	Left	WT-042916-2531- A	< 1	WT-042916-2531- B	< 1			
16 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002515	Fountain	1	In room 122	Right	WT-042916-2532- A	< 1	WT-042916-2532- B	< 1			
17 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002516	Classroom	1	In classroom 125	Left	WT-042916-2533- A	< 1	WT-042916-2533- B	< 1			
18 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002517	Fountain	1	In classroom 125	Right	WT-042916-2534- A	< 1	WT-042916-2534- B	< 1			
19 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002518	Classroom	1	In room 124	Left	WT-042916-2535- A	< 1	WT-042916-2535- B	< 1			
20 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002519	Fountain	1	In room 124	Right	WT-042916-2536- A	< 1	WT-042916-2536- B	< 1			
21 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002520	Classroom	1	In classroom 127	Left	WT-042916-2537- A	< 1	WT-042916-2537- B	< 1			
22 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002521	Fountain	1	In classroom 127	Right	WT-042916-2538- A	< 1	WT-042916-2538- B	< 1			
23 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002522	Cooler	2	In hallway adjacent to room 206	Left	WT-042916-2539- A	< 1	WT-042916-2539- B	< 1			
24 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002523	Cooler	2	In hallway adjacent to room 206	Right	WT-042916-2540- A	< 1	WT-042916-2540- B	< 1			
25 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002524	Classroom	2	In room 204	WT-042916-2541- A	1.2	WT-042916-2541- B	< 1				
26 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002525	Classroom	2	In classroom 210	Left	WT-042916-2542- A	< 1	WT-042916-2542- B	< 1			
27 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002526	Other	2	In classroom 210 (spray hose)	Right	WT-042916-2543- A	1	WT-042916-2543- B	1.1			
28 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002527	Fountain	3	In hallway adjacent to girls restroom	Left	WT-042916-2544- A	< 1	WT-042916-2544- B	< 1			
29 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002528	Fountain	3	In hallway adjacent to room 306	Right	WT-042916-2545- A	< 1	WT-042916-2545- B	< 1			
30 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002529	Classroom	3	In room 307	Left	WT-042916-2546- A	< 1	WT-042916-2546- B	< 1			
31 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002530	Fountain	3	In room 307	Right	WT-042916-2547- A	< 1	WT-042916-2547- B	< 1			
32 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002531	Classroom	3	In room 309	Left	WT-042916-2548- A	< 1	WT-042916-2548- B	< 1			
33 SEATON ELEMENTARY SCHOOL	5/4/2016	WS- 002532	Fountain	3	In room 309	Right	WT-042916-2549- A	< 1	WT-042916-2549- B	< 1			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.