



Seaton ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002505	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 111	Left	WF-102017-002505	11/2/2017	FT-FY18-102017-002505-A	<1	FT-FY18-102017-002505-B	<1
WS- 002514	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 122	Left	WF-102017-002514	11/2/2017	FT-FY18-102017-002514-A	<1	FT-FY18-102017-002514-B	<1
WS- 002515	6/30/2017	6/30/2018	1	Combo Fountain	In classroom 122	Right	WF-72017-002515	11/2/2017	FT-FY18-102017-002515-A	<1	FT-FY18-102017-002515-B	<1
WS- 002518	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 124	Left	WF-102017-002518	11/2/2017	FT-FY18-102017-002518-A	<1	FT-FY18-102017-002518-B	<1
WS- 002520	10/19/2017	10/19/2018	1	Combo Faucet	In classroom 127	Left	WF-102017-002520	11/2/2017	FT-FY18-102017-002520-A	<1	FT-FY18-102017-002520-B	<1
WS- 002522	6/30/2017	6/30/2018	2	Cooler	In hallway adjacent to room 206	Left	WF-72017-002522	11/2/2017	FT-FY18-102017-002522-A	<1	FT-FY18-102017-002522-B	<1
WS- 002529	10/19/2017	10/19/2018	3	Combo Faucet	In classroom 307	Left	WF-102017-002529	11/2/2017	FT-FY18-102017-002529-A	<1	FT-FY18-102017-002529-B	<1
WS- 002530	6/30/2017	6/30/2018	3	Combo Fountain	In classroom 307	Right	WF-72017-002530	11/2/2017	FT-FY18-102017-002530-A	<1	FT-FY18-102017-002530-B	<1
WS- 002531	10/19/2017	10/19/2018	3	Combo Faucet	In classroom 309	Left	WF-102017-002531	11/2/2017	FT-FY18-102017-002531-A	<1	FT-FY18-102017-002531-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002513	1	Food Prep Sink	In kitchen	Left		11/2/2017	FT-FY18-102017-002513-A	<1	FT-FY18-102017-002513-B	<1