



Seaton ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002498	5/1/2018	5/1/2019	1	Bottle Filler	In gym/cafeteria	WF-05012018-002498	11/3/2018	FT-FY19-102018-002498-A	< 1	FT-FY19-102018-002498-B	< 1
WS- 002501	5/1/2018	5/1/2019	1	Cooler	In hallway adjacent to room 106 Right	WF-05012018-002501	11/3/2018	FT-FY19-102018-002501-A	< 1	FT-FY19-102018-002501-B	< 1
WS- 002502	5/1/2018	5/1/2019	1	Cooler	In hallway adjacent to room 106 Left	WF-05012018-002502	11/3/2018	FT-FY19-102018-002502-A	< 1	FT-FY19-102018-002502-B	< 1
WS- 002503	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 109 Left	WF-09252018-002503	11/3/2018	FT-FY19-102018-002503-A	< 1	FT-FY19-102018-002503-B	< 1
WS- 002504	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 109 Right	WF-05012018-002504	11/3/2018	FT-FY19-102018-002504-A	< 1	FT-FY19-102018-002504-B	< 1
WS- 002505	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 111 Left	WF-09252018-002505	11/3/2018	FT-FY19-102018-002505-A	< 1	FT-FY19-102018-002505-B	< 1
WS- 002506	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 111 Right	WF-05012018-002506	11/3/2018	FT-FY19-102018-002506-A	< 1	FT-FY19-102018-002506-B	< 1
WS- 002507	5/1/2018	5/1/2019	1	Health Suite	In health suite in restroom	WF-05012018-002507	11/3/2018	FT-FY19-102018-002507-A	< 1	FT-FY19-102018-002507-B	< 1
WS- 002508	9/25/2018	9/25/2019	1	Classroom Faucet	In classroom 113	WF-09252018-002508	11/3/2018	FT-FY19-102018-002508-A	< 1	FT-FY19-102018-002508-B	< 1
WS- 002509	5/1/2018	5/1/2019	1	Cooler	In gym/cafeteria	WF-05012018-002509	11/3/2018	FT-FY19-102018-002509-A	< 1	FT-FY19-102018-002509-B	< 1
WS- 002514	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 122 Left	WF-09252018-002514	11/3/2018	FT-FY19-102018-002514-A	< 1	FT-FY19-102018-002514-B	< 1
WS- 002515	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 122 Right	WF-05012018-002515	11/3/2018	FT-FY19-102018-002515-A	< 1	FT-FY19-102018-002515-B	< 1
WS- 002516	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 125 Left	WF-09252018-002516	11/3/2018	FT-FY19-102018-002516-A	< 1	FT-FY19-102018-002516-B	< 1
WS- 002517	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 125 Right	WF-05012018-002517	11/3/2018	FT-FY19-102018-002517-A	< 1	FT-FY19-102018-002517-B	< 1
WS- 002518	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 124 Left	WF-09252018-002518	11/3/2018	FT-FY19-102018-002518-A	< 1	FT-FY19-102018-002518-B	< 1
WS- 002519	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 124 Right	WF-05012018-002519	11/3/2018	FT-FY19-102018-002519-A	< 1	FT-FY19-102018-002519-B	< 1
WS- 002520	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 127 Left	WF-09252018-002520	11/3/2018	FT-FY19-102018-002520-A	< 1	FT-FY19-102018-002520-B	< 1
WS- 002521	5/1/2018	5/1/2019	1	Combo Fountain	In classroom 127 Right	WF-05012018-002521	11/3/2018	FT-FY19-102018-002521-A	< 1	FT-FY19-102018-002521-B	< 1
WS- 002522	5/1/2018	5/1/2019	2	Cooler	In hallway adjacent to room 206 Left	WF-05012018-002522	11/3/2018	FT-FY19-102018-002522-A	< 1	FT-FY19-102018-002522-B	< 1
WS- 002523	5/1/2018	5/1/2019	2	Cooler	In hallway adjacent to room 206 Right	WF-05012018-002523	11/3/2018	FT-FY19-102018-002523-A	< 1	FT-FY19-102018-002523-B	< 1
WS- 002524	5/1/2018	5/1/2019	2	Break Room	In staff lounge 204	WF-05012018-002524	11/3/2018	FT-FY19-102018-002524-A	< 1	FT-FY19-102018-002524-B	< 1
WS- 002525	9/25/2018	9/25/2019	2	Classroom Faucet	In classroom 210 Left	WF-09252018-002525	11/3/2018	FT-FY19-102018-002525-A	< 1	FT-FY19-102018-002525-B	< 1
WS- 002527	5/1/2018	5/1/2019	3	Cooler	In hallway adjacent to room 306 Left	WF-05012018-002527	11/3/2018	FT-FY19-102018-002527-A	< 1	FT-FY19-102018-002527-B	< 1
WS- 002528	5/1/2018	5/1/2019	3	Cooler	In hallway adjacent to room 306 Right	WF-05012018-002528	11/3/2018	FT-FY19-102018-002528-A	< 1	FT-FY19-102018-002528-B	< 1
WS- 002529	9/25/2018	9/25/2019	3	Combo Faucet	In classroom 307 Left	WF-09252018-002529	11/3/2018	FT-FY19-102018-002529-A	< 1	FT-FY19-102018-002529-B	< 1
WS- 002530	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 307 Right	WF-05012018-002530	11/3/2018	FT-FY19-102018-002530-A	< 1	FT-FY19-102018-002530-B	< 1
WS- 002531	9/25/2018	9/25/2019	3	Combo Faucet	In classroom 309 Left	WF-09252018-002531	11/3/2018	FT-FY19-102018-002531-A	< 1	FT-FY19-102018-002531-B	< 1
WS- 002532	5/1/2018	5/1/2019	3	Combo Fountain	In classroom 309 Right	WF-05012018-002532	11/3/2018	FT-FY19-102018-002532-A	< 1	FT-FY19-102018-002532-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002510	1	Food Prep Sink	In kitchen Right	11/3/2018	FT-FY19-102018-002510-A	< 1	FT-FY19-102018-002510-B	< 1