



SHARPE HEALTH LEAD WATER TEST RESULTS

May 24th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008562	Cooler	1	In hallway adjacent to principal office	WT-042916-8579- A	< 1	WT-042916-8579- B	< 1				
2	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008563	Cooler	1	In hallway adjacent to book storage	WT-042916-8580- A	< 1	WT-042916-8580- B	< 1				
3	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008564	Classroom	1	In room 202	WT-042916-8581- A	2.3	WT-042916-8581- B	< 1				
4	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008565	Cooler	1	In hallway adjacent to 207	WT-042916-8582- A	< 1	WT-042916-8582- B	< 1				
5	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008566	Classroom	1	Sharp, room 207	WT-042916-8583- A	171	WT-042916-8583- B	26.5	Filter will be installed and then retested			
6	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008567	Break Room	1	Sharpe, in homemaking room	WT-042916-8584- A	4.4	WT-042916-8584- B	3.6				
7	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008568	Classroom	1	Sharp, room 208 Right	WT-042916-8585- A	9.6	WT-042916-8585- B	22.9	Filter will be installed and then retested			
8	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008569	Classroom	1	In room 208 Left	WT-042916-8586- A	2	WT-042916-8586- B	< 1				
9	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008570	Classroom	1	Sharp, room 209	WT-042916-8587- A	7	WT-042916-8587- B	6				
10	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008571	Classroom	1	Sharp, room 211	WT-042916-8588- A	6	WT-042916-8588- B	12.8				
11	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008572	Classroom	1	In sharp, in room 210	WT-042916-8589- A	3.8	WT-042916-8589- B	3.2				
12	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008575	Cooler	1	In dining room	WT-042916-8592- A	< 1	WT-042916-8592- B	< 1				
13	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008576	Classroom	1	In classroom 117	WT-042916-8593- A	1.4	WT-042916-8593- B	< 1				
14	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008577	Cooler	1	In hallway adjacent to room 117	WT-042916-8594- A	< 1	WT-042916-8594- B	< 1				
15	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008580	Cooler	1	In hallway adjacent to locker room	WT-042916-8597- A	< 1	WT-042916-8597- B	< 1				
16	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008581	Classroom	1	Room kindergarten	WT-042916-8598- A	1.6	WT-042916-8598- B	< 1				
17	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008582	Health Suite	1	In health suite Left	WT-042916-8599- A	2.6	WT-042916-8599- B	1				
18	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008583	Health Suite	1	In health suite Mid	WT-042916-8600- A	22.5	WT-042916-8600- B	6.9	Filter will be installed and then retested			
19	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008584	Health Suite	1	In health suite Right	WT-042916-8601- A	17.3	WT-042916-8601- B	3.1	Filter will be installed and then retested			
20	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008585	Cooler	1	In hallway adjacent to pool room	WT-042916-8602- A	< 1	WT-042916-8602- B	< 1				
21	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008586	Classroom	1	In room 111	WT-042916-8603- A	31.2	WT-042916-8603- B	38.7	Filter will be installed and then retested			
22	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008587	Classroom	1	In classroom 2c	WT-042916-8604- A	< 1	WT-042916-8604- B	< 1				
23	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008588	Classroom	1	In room 109	WT-042916-8605- A	< 1	WT-042916-8605- B	< 1				
24	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008593	Cooler	1	In hallway adjacent to 2C	WT-042916-8610- A	< 1	WT-042916-8610- B	< 1				
25	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008594	Classroom	1	In room 108	WT-042916-8611- A	< 1	WT-042916-8611- B	1.8				
26	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008595	Classroom	1	In room 107	WT-042916-8612- A	< 1	WT-042916-8612- B	< 1				
27	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008596	Classroom	1	In physical therapy room	WT-042916-8613- A	3.5	WT-042916-8613- B	3.8				
28	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008597	Classroom	1	In art room	WT-042916-8614- A	2.3	WT-042916-8614- B	1.3				
29	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008599	Cooler	1	In hallway adjacent to room 105	WT-042916-8616- A	< 1	WT-042916-8616- B	< 1				
30	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008600	Classroom	Ground Floor	In classroom 105	WT-042916-8617- A	< 1	WT-042916-8617- B	< 1				
31	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008601	Classroom	1	In room 104	WT-042916-8618- A	< 1	WT-042916-8618- B	< 1				
32	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008602	Cooler	1	In hallway adjacent to room 105	WT-042916-8619- A	< 1	WT-042916-8619- B	< 1				
33	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008603	Classroom	1	In room 14	WT-042916-8620- A	< 1	WT-042916-8620- B	< 1				
34	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008604	Classroom	1	In room 15	WT-042916-8621- A	< 1	WT-042916-8621- B	< 1				
35	SHARPE HEALTH SPECIAL EDUCATION SCHOOL	5/10/2016	WS- 008605	Utility	Basement	In boiler room (water source)	WT-042916-8622- A	3.6	WT-042916-8622- B	1.1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.