



Sharpe Health Swing Space Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002690	3/20/2023	3/20/2024	1	Bottle Filler	In hallway adjacent to room 105	WF-03202023-002690	8/21/2023	FT-FY24-08082023-002690-A	<1	FT-FY24-08082023-002690-B	<1
WS- 002692	3/20/2023	3/20/2024	1	Bottle Filler	In hallway adjacent to classroom 119	WF-03202023-002692	8/21/2023	FT-FY24-08082023-002692-A	<1	FT-FY24-08082023-002692-B	<1
WS- 005252	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 101 High Left	WF-08022023-005252	8/21/2023	FT-FY24-08082023-005252-A	<1	FT-FY24-08082023-005252-B	<1
WS- 005253	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 101 Low Right	WF-08022023-005253	8/21/2023	FT-FY24-08082023-005253-A	<1	FT-FY24-08082023-005253-B	<1
WS- 005255	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 102 High Left	WF-08022023-005255	8/21/2023	FT-FY24-08082023-005255-A	<1	FT-FY24-08082023-005255-B	<1
WS- 005256	8/2/2023	8/2/2024	1	Combo Faucet	In classroom 102 Low Right	WF-08022023-005256	8/21/2023	FT-FY24-08082023-005256-A	<1	FT-FY24-08082023-005256-B	<1
WS- 005257	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 102 Low Right	WF-08022023-005257	8/21/2023	FT-FY24-08082023-005257-A	<1	FT-FY24-08082023-005257-B	<1
WS- 005258	8/2/2023	8/2/2024	1	Combo Faucet	In classroom 103 Low Left	WF-08022023-005258	8/21/2023	FT-FY24-08082023-005258-A	<1	FT-FY24-08082023-005258-B	<1
WS- 005259	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 103 Low Left	WF-08022023-005259	8/21/2023	FT-FY24-08082023-005259-A	<1	FT-FY24-08082023-005259-B	<1
WS- 005261	8/2/2023	8/2/2024	1	Combo Fountain	In classroom 103 High Right	WF-08022023-005261	8/21/2023	FT-FY24-08082023-005261-A	<1	FT-FY24-08082023-005261-B	<1
WS- 008562	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to room 301	WF-03202023-008562	8/21/2023	FT-FY24-08082023-008562-A	<1	FT-FY24-08082023-008562-B	<1
WS- 008565	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to room 314	WF-03202023-008565	8/21/2023	FT-FY24-08082023-008565-A	<1	FT-FY24-08082023-008565-B	<1
WS- 008580	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to room 213	WF-03202023-008580	8/21/2023	FT-FY24-08082023-008580-A	<1	FT-FY24-08082023-008580-B	<1
WS- 008586	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 116	WF-09262022-008586	8/21/2023	FT-FY24-08082023-008586-A	<1	FT-FY24-08082023-008586-B	<1
WS- 008587	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 121	WF-09262022-008587	8/21/2023	FT-FY24-08082023-008587-A	<1	FT-FY24-08082023-008587-B	<1
WS- 008588	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 114	WF-09262022-008588	8/21/2023	FT-FY24-08082023-008588-A	<1	FT-FY24-08082023-008588-B	<1
WS- 008593	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to classroom 119	WF-03202023-008593	8/21/2023	FT-FY24-08082023-008593-A	<1	FT-FY24-08082023-008593-B	<1
WS- 008595	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 112	WF-09262022-008595	8/21/2023	FT-FY24-08082023-008595-A	<1	FT-FY24-08082023-008595-B	<1
WS- 008600	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 108	WF-09262022-008600	8/21/2023	FT-FY24-08082023-008600-A	<1	FT-FY24-08082023-008600-B	<1
WS- 008601	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 105	WF-09262022-008601	8/21/2023	FT-FY24-08082023-008601-A	<1	FT-FY24-08082023-008601-B	<1
WS- 008602	3/20/2023	3/20/2024	1	Cooler	In hallway adjacent to room 105	WF-03202023-008602	8/21/2023	FT-FY24-08082023-008602-A	<1	FT-FY24-08082023-008602-B	<1
WS- 008850	3/20/2023	3/20/2024	1	Break Room	In room 111 in back of school	WF-03202023-008850	8/21/2023	FT-FY24-08082023-008850-A	<1	FT-FY24-08082023-008850-B	<1
WS- 008853	3/20/2023	3/20/2024	1	Bottle Filler	In hallway adjacent to room 314	WF-03202023-008853	8/21/2023	FT-FY24-08082023-008853-A	<1	FT-FY24-08082023-008853-B	<1
WS- 008859	3/20/2023	3/20/2024	1	Bottle Filler	In hallway adjacent to room 301	WF-03202023-008859	8/21/2023	FT-FY24-08082023-008859-A	<1	FT-FY24-08082023-008859-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008574	1/3/2023	1/3/2024	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-01032023-008574	8/21/2023	FT-FY24-08082023-008574-A	<1	FT-FY24-08082023-008574-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005251	8/2/2023	8/2/2024	1	Combo Faucet	In classroom 101 Low Right	WF-08022023-005251	8/21/2023	FT-FY24-08082023-005251-A	26.9	FT-FY24-08082023-005251-B	16.1