



# Sharpe Health Swing Space Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008562	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 301	WF-04122021-008562	12/15/2021	FT-FY22-12012021-008562-A	<1	FT-FY22-12012021-008562-B	<1
WS- 008563	4/12/2021	4/12/2022	1	Cooler	In hallway across classroom 307	WF-04122021-008563	12/15/2021	FT-FY22-12012021-008563-A	<1	FT-FY22-12012021-008563-B	<1
WS- 008565	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 314	WF-04122021-008565	12/15/2021	FT-FY22-12012021-008565-A	<1	FT-FY22-12012021-008565-B	<1
WS- 008577	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 205	WF-04122021-008577	12/15/2021	FT-FY22-12012021-008577-A	<1	FT-FY22-12012021-008577-B	<1
WS- 008580	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 213	WF-04122021-008580	12/15/2021	FT-FY22-12012021-008580-A	<1	FT-FY22-12012021-008580-B	<1
WS- 008585	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to pool room	WF-04122021-008585	12/15/2021	FT-FY22-12012021-008585-A	<1	FT-FY22-12012021-008585-B	<1
WS- 008586	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 116	WF-10042021-008586	12/15/2021	FT-FY22-12012021-008586-A	<1	FT-FY22-12012021-008586-B	<1
WS- 008587	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 121	WF-10042021-008587	12/15/2021	FT-FY22-12012021-008587-A	<1	FT-FY22-12012021-008587-B	<1
WS- 008588	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 114	WF-10042021-008588	12/15/2021	FT-FY22-12012021-008588-A	<1	FT-FY22-12012021-008588-B	<1
WS- 008593	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to classroom 119	WF-04122021-008593	12/15/2021	FT-FY22-12012021-008593-A	<1	FT-FY22-12012021-008593-B	<1
WS- 008595	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 112	WF-10042021-008595	12/15/2021	FT-FY22-12012021-008595-A	<1	FT-FY22-12012021-008595-B	<1
WS- 008599	4/12/2021	4/12/2022	1	Cooler	In hallway across room 113	WF-04122021-008599	12/15/2021	FT-FY22-12012021-008599-A	<1	FT-FY22-12012021-008599-B	<1
WS- 008600	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 108	WF-10042021-008600	12/15/2021	FT-FY22-12012021-008600-A	<1	FT-FY22-12012021-008600-B	<1
WS- 008601	10/4/2021	10/4/2022	1	Classroom Faucet	In classroom 105	WF-10042021-008601	12/15/2021	FT-FY22-12012021-008601-A	<1	FT-FY22-12012021-008601-B	<1
WS- 008602	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to room 105	WF-04122021-008602	12/15/2021	FT-FY22-12012021-008602-A	<1	FT-FY22-12012021-008602-B	<1
WS- 008850	4/12/2021	4/12/2022	1	Break Room	In room 111 in back of school	WF-04122021-008850	12/15/2021	FT-FY22-12012021-008850-A	<1	FT-FY22-12012021-008850-B	<1
WS- 009168	4/12/2021	4/12/2022	1	Health Suite	In health suite 202	WF-04122021-009168	12/15/2021	FT-FY22-12012021-009168-A	<1	FT-FY22-12012021-009168-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008574	2/3/2021	2/3/2022	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-02032021-008574	12/15/2021	FT-FY22-12012021-008574-A	<1	FT-FY22-12012021-008574-B	<1