



Sharpe Health Swing Space Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002690	3/11/2024	3/11/2025	1	Bottle Filler	In hallway adjacent to room 105	WF-03112024-002690	12/3/2024	FT-FY25-10312024-002690-A	<2	FT-FY25-10312024-002690-B	<2	
WS-002692	3/11/2024	3/11/2025	1	Bottle Filler	In hallway adjacent to classroom 119	WF-03112024-002692	12/3/2024	FT-FY25-10312024-002692-A	<2	FT-FY25-10312024-002692-B	<2	
WS-002693	3/11/2024	3/11/2025	1	Bottle Filler	In hallway across classroom 307	WF-03112024-002693	12/3/2024	FT-FY25-10312024-002693-A	<2	FT-FY25-10312024-002693-B	<2	
WS-005252	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 101	High Left	WF-03112024-005252	12/3/2024	FT-FY25-10312024-005252-A	<2	FT-FY25-10312024-005252-B	<2
WS-005253	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 101	Low Right	WF-03112024-005253	12/3/2024	FT-FY25-10312024-005253-A	<2	FT-FY25-10312024-005253-B	<2
WS-005255	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 102	High Left	WF-03112024-005255	12/3/2024	FT-FY25-10312024-005255-A	<2	FT-FY25-10312024-005255-B	<2
WS-005256	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 102	Low Right	WF-09162024-005256	12/3/2024	FT-FY25-10312024-005256-A	2.0	FT-FY25-10312024-005256-B	<2
WS-005257	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 102	Low Right	WF-03112024-005257	12/3/2024	FT-FY25-10312024-005257-A	<2	FT-FY25-10312024-005257-B	<2
WS-005259	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 103	Low Left	WF-03112024-005259	12/3/2024	FT-FY25-10312024-005259-A	<2	FT-FY25-10312024-005259-B	<2
WS-005261	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 103	High Right	WF-03112024-005261	12/3/2024	FT-FY25-10312024-005261-A	<2	FT-FY25-10312024-005261-B	<2
WS-005263	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 104	High Left	WF-03112024-005263	12/3/2024	FT-FY25-10312024-005263-A	<2	FT-FY25-10312024-005263-B	<2
WS-005264	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 104	Low Right	WF-09162024-005264	12/3/2024	FT-FY25-10312024-005264-A	<2	FT-FY25-10312024-005264-B	<2
WS-005265	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 104	Low Right	WF-03112024-005265	12/3/2024	FT-FY25-10312024-005265-A	<2	FT-FY25-10312024-005265-B	<2
WS-005266	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 105	Low Left	WF-09162024-005266	12/3/2024	FT-FY25-10312024-005266-A	<2	FT-FY25-10312024-005266-B	<2
WS-005267	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 105	Low Left	WF-03112024-005267	12/3/2024	FT-FY25-10312024-005267-A	<2	FT-FY25-10312024-005267-B	<2
WS-005269	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 105	High Right	WF-03112024-005269	12/3/2024	FT-FY25-10312024-005269-A	<2	FT-FY25-10312024-005269-B	<2
WS-005271	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 328	Low Left	WF-03112024-005271	12/3/2024	FT-FY25-10312024-005271-A	<2	FT-FY25-10312024-005271-B	<2
WS-005273	3/11/2024	3/11/2025	1	Combo Fountain	In classroom 328	High Right	WF-03112024-005273	12/3/2024	FT-FY25-10312024-005273-A	<2	FT-FY25-10312024-005273-B	<2
WS-007183	3/11/2024	3/11/2025	1	Bottle Filler	In hallway adjacent to teachers restroom	WF-03112024-007183	12/3/2024	FT-FY25-10312024-007183-A	<2	FT-FY25-10312024-007183-B	<2	
WS-007258	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to teachers restroom	WF-03112024-007258	12/3/2024	FT-FY25-10312024-007258-A	<2	FT-FY25-10312024-007258-B	<2	
WS-008562	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to room 301	WF-03112024-008562	12/3/2024	FT-FY25-10312024-008562-A	<2	FT-FY25-10312024-008562-B	<2	
WS-008565	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to room 314	WF-03112024-008565	12/3/2024	FT-FY25-10312024-008565-A	<2	FT-FY25-10312024-008565-B	<2	
WS-008577	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to room 205	WF-03112024-008577	12/3/2024	FT-FY25-10312024-008577-A	<2	FT-FY25-10312024-008577-B	<2	
WS-008580	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to room 213	WF-03112024-008580	12/3/2024	FT-FY25-10312024-008580-A	<2	FT-FY25-10312024-008580-B	<2	
WS-008586	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 116	WF-09162024-008586	12/3/2024	FT-FY25-10312024-008586-A	<2	FT-FY25-10312024-008586-B	<2	
WS-008587	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 121	WF-09162024-008587	12/3/2024	FT-FY25-10312024-008587-A	<2	FT-FY25-10312024-008587-B	<2	
WS-008588	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 114	WF-09162024-008588	12/3/2024	FT-FY25-10312024-008588-A	<2	FT-FY25-10312024-008588-B	<2	
WS-008593	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to classroom 119	WF-03112024-008593	12/3/2024	FT-FY25-10312024-008593-A	<2	FT-FY25-10312024-008593-B	<2	
WS-008595	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 112	WF-09162024-008595	12/3/2024	FT-FY25-10312024-008595-A	<2	FT-FY25-10312024-008595-B	<2	
WS-008600	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 108	WF-09162024-008600	12/3/2024	FT-FY25-10312024-008600-A	2.0	FT-FY25-10312024-008600-B	<2	
WS-008601	9/16/2024	9/16/2025	1	Classroom Faucet	In classroom 105	WF-09162024-008601	12/3/2024	FT-FY25-10312024-008601-A	<2	FT-FY25-10312024-008601-B	<2	
WS-008602	3/11/2024	3/11/2025	1	Cooler	In hallway adjacent to room 105	WF-03112024-008602	12/3/2024	FT-FY25-10312024-008602-A	<2	FT-FY25-10312024-008602-B	<2	
WS-008850	3/11/2024	3/11/2025	1	Break Room	In room 111 in back of school	WF-03112024-008850	12/3/2024	FT-FY25-10312024-008850-A	<2	FT-FY25-10312024-008850-B	<2	

WS- 008853	3/11/2024	3/11/2025	1	Bottle Filler	In hallway adjacent to room 314	WF-03112024-008853	12/3/2024	FT-FY25-10312024-008853-A	<2	FT-FY25-10312024-008853-B	<2
WS- 008859	3/11/2024	3/11/2025	1	Bottle Filler	In hallway adjacent to room 301	WF-03112024-008859	12/3/2024	FT-FY25-10312024-008859-A	<2	FT-FY25-10312024-008859-B	<2
WS- 009168	3/11/2024	3/11/2025	1	Health Suite	In health suite 202	WF-03112024-009168	12/3/2024	FT-FY25-10312024-009168-A	<2	FT-FY25-10312024-009168-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008574	1/8/2024	1/8/2025	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-01082024-008574	12/3/2024	FT-FY25-10312024-008574-A	3.6	FT-FY25-10312024-008574-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005251	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 101 Low Right	WF-09162024-005251	12/3/2024	FT-FY25-10312024-005251-A	5.0	FT-FY25-10312024-005251-B	<2
WS- 005258	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 103 Low Left	WF-09162024-005258	12/3/2024	FT-FY25-10312024-005258-A	7.6	FT-FY25-10312024-005258-B	<2
WS- 005270	9/16/2024	9/16/2025	1	Combo Faucet	In classroom 328 Low Left	WF-09162024-005270	12/3/2024	FT-FY25-10312024-005270-A	9.1	FT-FY25-10312024-005270-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.