



Sharpe Health Swing Space Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002690	3/29/2022	3/29/2023	1	Bottle Filler	In hallway adjacent to room 105	WF-03292022-002690	1/5/2023	FT-FY23-11182022-002690-A	<1	FT-FY23-11182022-002690-B	1.3
WS- 002692	3/29/2022	3/29/2023	1	Bottle Filler	In hallway adjacent to classroom 119	WF-03292022-002692	1/5/2023	FT-FY23-11182022-002692-A	<1	FT-FY23-11182022-002692-B	<1
WS- 002693	3/29/2022	3/29/2023	1	Bottle Filler	In hallway across classroom 307	WF-03292022-002693	1/5/2023	FT-FY23-11182022-002693-A	<1	FT-FY23-11182022-002693-B	<1
WS- 008565	3/29/2022	3/29/2023	1	Cooler	In hallway adjacent to room 314	WF-03292022-008565	1/5/2023	FT-FY23-11182022-008565-A	<1	FT-FY23-11182022-008565-B	<1
WS- 008580	3/29/2022	3/29/2023	1	Cooler	In hallway adjacent to room 213	WF-03292022-008580	1/5/2023	FT-FY23-11182022-008580-A	<1	FT-FY23-11182022-008580-B	<1
WS- 008585	3/29/2022	3/29/2023	1	Cooler	In hallway adjacent to pool room	WF-03292022-008585	1/5/2023	FT-FY23-11182022-008585-A	<1	FT-FY23-11182022-008585-B	<1
WS- 008586	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 116	WF-09262022-008586	1/5/2023	FT-FY23-11182022-008586-A	<1	FT-FY23-11182022-008586-B	<1
WS- 008587	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 121	WF-09262022-008587	1/5/2023	FT-FY23-11182022-008587-A	<1	FT-FY23-11182022-008587-B	<1
WS- 008588	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 114	WF-09262022-008588	1/5/2023	FT-FY23-11182022-008588-A	1.7	FT-FY23-11182022-008588-B	<1
WS- 008595	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 112	WF-09262022-008595	1/5/2023	FT-FY23-11182022-008595-A	2.2	FT-FY23-11182022-008595-B	<1
WS- 008600	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 108	WF-09262022-008600	1/5/2023	FT-FY23-11182022-008600-A	1.7	FT-FY23-11182022-008600-B	<1
WS- 008601	9/26/2022	9/26/2023	1	Classroom Faucet	In classroom 105	WF-09262022-008601	1/5/2023	FT-FY23-11182022-008601-A	<1	FT-FY23-11182022-008601-B	<1
WS- 008602	3/29/2022	3/29/2023	1	Cooler	In hallway adjacent to room 105	WF-03292022-008602	1/5/2023	FT-FY23-11182022-008602-A	<1	FT-FY23-11182022-008602-B	<1
WS- 008853	3/29/2022	3/29/2023	1	Bottle Filler	In hallway adjacent to room 314	WF-03292022-008853	1/5/2023	FT-FY23-11182022-008853-A	<1	FT-FY23-11182022-008853-B	<1
WS- 008859	3/29/2022	3/29/2023	1	Bottle Filler	In hallway adjacent to room 301	WF-03292022-008859	1/5/2023	FT-FY23-11182022-008859-A	<1	FT-FY23-11182022-008859-B	<1
WS- 009168	3/29/2022	3/29/2023	1	Health Suite	In health suite 202	WF-03292022-009168	1/5/2023	FT-FY23-11182022-009168-A	<1	FT-FY23-11182022-009168-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008574	1/24/2022	1/24/2023	1	Food Prep Sink	In kitchen 2nd clockwise from entry	WF-01242022-008574	1/5/2023	FT-FY23-11182022-008574-A	<1	FT-FY23-11182022-008574-B	<1