



# Shepherd ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000608	9/24/2019	9/24/2020	Basement	Classroom Faucet	In classroom BG05	WF-09242019-000608	12/19/2019	FT-FY20-112019-000608-A	<1	FT-FY20-112019-000608-B	<1
WS- 000610	4/16/2019	4/16/2020	Basement	Cooler	In hallway adjacent to room AG06 High Left	WF-04162019-000610	12/19/2019	FT-FY20-112019-000610-A	<1	FT-FY20-112019-000610-B	<1
WS- 000611	4/16/2019	4/16/2020	Basement	Cooler	In hallway adjacent to room AG06 Low Right	WF-04162019-000611	12/19/2019	FT-FY20-112019-000611-A	<1	FT-FY20-112019-000611-B	<1
WS- 000612	4/16/2019	4/16/2020	Basement	Break Room	In staff lounge AG06	WF-04162019-000612	12/19/2019	FT-FY20-112019-000612-A	<1	FT-FY20-112019-000612-B	<1
WS- 000614	4/16/2019	4/16/2020	Basement	Cooler	In cafeteria	WF-04162019-000614	12/19/2019	FT-FY20-112019-000614-A	<1	FT-FY20-112019-000614-B	<1
WS- 000615	6/26/2019	6/26/2020	Basement	Food Prep Sink	In kitchen Low	WF-06262019-000615	12/19/2019	FT-FY20-112019-000615-A	<1	FT-FY20-112019-000615-B	<1
WS- 000618	4/16/2019	4/16/2020	1	Combo Fountain	In classroom A106 Right	WF-04162019-000618	12/19/2019	FT-FY20-112019-000618-A	<1	FT-FY20-112019-000618-B	<1
WS- 000619	9/24/2019	9/24/2020	1	Combo Faucet	In classroom A106 Left	WF-09242019-000619	12/19/2019	FT-FY20-112019-000619-A	<1	FT-FY20-112019-000619-B	<1
WS- 000620	4/16/2019	4/16/2020	1	Cooler	In hallway adjacent to room A106	WF-04162019-000620	12/19/2019	FT-FY20-112019-000620-A	<1	FT-FY20-112019-000620-B	<1
WS- 000621	9/24/2019	9/24/2020	1	Combo Faucet	In classroom A103 Left	WF-09242019-000621	12/19/2019	FT-FY20-112019-000621-A	<1	FT-FY20-112019-000621-B	<1
WS- 000622	4/16/2019	4/16/2020	1	Combo Fountain	In classroom A103 Right	WF-04162019-000622	12/19/2019	FT-FY20-112019-000622-A	<1	FT-FY20-112019-000622-B	<1
WS- 000623	4/16/2019	4/16/2020	1	Cooler	In hallway adjacent to room A101	WF-04162019-000623	12/19/2019	FT-FY20-112019-000623-A	<1	FT-FY20-112019-000623-B	<1
WS- 000624	9/24/2019	9/24/2020	1	Combo Faucet	In classroom A101 Left	WF-09242019-000624	12/19/2019	FT-FY20-112019-000624-A	<1	FT-FY20-112019-000624-B	<1
WS- 000625	4/16/2019	4/16/2020	1	Combo Fountain	In classroom A101 Right	WF-04162019-000625	12/19/2019	FT-FY20-112019-000625-A	<1	FT-FY20-112019-000625-B	<1
WS- 000626	9/24/2019	9/24/2020	1	Combo Faucet	In classroom A102 Left	WF-09242019-000626	12/19/2019	FT-FY20-112019-000626-A	<1	FT-FY20-112019-000626-B	<1
WS- 000627	4/16/2019	4/16/2020	1	Combo Fountain	In classroom A102 Right	WF-04162019-000627	12/19/2019	FT-FY20-112019-000627-A	<1	FT-FY20-112019-000627-B	<1
WS- 000633	4/16/2019	4/16/2020	1	Cooler	In hallway adjacent to room C109 High Left	WF-04162019-000633	12/19/2019	FT-FY20-112019-000633-A	<1	FT-FY20-112019-000633-B	<1
WS- 000634	4/16/2019	4/16/2020	1	Cooler	In hallway adjacent to room C109 Low Right	WF-04162019-000634	12/19/2019	FT-FY20-112019-000634-A	<1	FT-FY20-112019-000634-B	<1
WS- 000635	4/16/2019	4/16/2020	1	Health Suite	In health suite C108B Left	WF-04162019-000635	12/19/2019	FT-FY20-112019-000635-A	<1	FT-FY20-112019-000635-B	<1
WS- 000637	4/16/2019	4/16/2020	1	Combo Fountain	In health suite C108B Right	WF-04162019-000637	12/19/2019	FT-FY20-112019-000637-A	<1	FT-FY20-112019-000637-B	<1
WS- 000638	4/16/2019	4/16/2020	1	Combo Fountain	In classroom C111 Right	WF-04162019-000638	12/19/2019	FT-FY20-112019-000638-A	<1	FT-FY20-112019-000638-B	<1
WS- 000639	9/24/2019	9/24/2020	1	Combo Faucet	In classroom C111 Left	WF-09242019-000639	12/19/2019	FT-FY20-112019-000639-A	<1	FT-FY20-112019-000639-B	<1
WS- 000640	9/24/2019	9/24/2020	1	Combo Faucet	In classroom C110 Left	WF-09242019-000640	12/19/2019	FT-FY20-112019-000640-A	<1	FT-FY20-112019-000640-B	<1
WS- 000641	4/16/2019	4/16/2020	1	Combo Fountain	In classroom C110 Right	WF-04162019-000641	12/19/2019	FT-FY20-112019-000641-A	<1	FT-FY20-112019-000641-B	<1
WS- 000642	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room C211 High Left	WF-04162019-000642	12/19/2019	FT-FY20-112019-000642-A	<1	FT-FY20-112019-000642-B	<1
WS- 000643	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room C211 Low Right	WF-04162019-000643	12/19/2019	FT-FY20-112019-000643-A	<1	FT-FY20-112019-000643-B	<1
WS- 000644	9/24/2019	9/24/2020	2	Combo Faucet	In classroom C204 Left	WF-09242019-000644	12/19/2019	FT-FY20-112019-000644-A	<1	FT-FY20-112019-000644-B	<1
WS- 000645	4/16/2019	4/16/2020	2	Combo Fountain	In classroom C204 Right	WF-04162019-000645	12/19/2019	FT-FY20-112019-000645-A	<1	FT-FY20-112019-000645-B	<1
WS- 000646	9/24/2019	9/24/2020	2	Combo Faucet	In classroom C203 Left	WF-09242019-000646	12/19/2019	FT-FY20-112019-000646-A	<1	FT-FY20-112019-000646-B	<1
WS- 000647	4/16/2019	4/16/2020	2	Combo Fountain	In classroom C203 Right	WF-04162019-000647	12/19/2019	FT-FY20-112019-000647-A	<1	FT-FY20-112019-000647-B	<1
WS- 000648	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room C203 High Left	WF-04162019-000648	12/19/2019	FT-FY20-112019-000648-A	<1	FT-FY20-112019-000648-B	<1
WS- 000649	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room C203 Low Right	WF-04162019-000649	12/19/2019	FT-FY20-112019-000649-A	<1	FT-FY20-112019-000649-B	<1
WS- 000650	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room A210	WF-04162019-000650	12/19/2019	FT-FY20-112019-000650-A	<1	FT-FY20-112019-000650-B	<1

WS- 000651	9/24/2019	9/24/2020	2	Combo Faucet	In classroom A205	Left	WF-09242019-000651	12/19/2019	FT-FY20-112019-000651-A	<1	FT-FY20-112019-000651-B	<1
WS- 000652	4/16/2019	4/16/2020	2	Combo Fountain	In classroom A205		WF-04162019-000652	12/19/2019	FT-FY20-112019-000652-A	<1	FT-FY20-112019-000652-B	<1
WS- 000653	4/16/2019	4/16/2020	2	Cooler	In hallway adjacent to room A201		WF-04162019-000653	12/19/2019	FT-FY20-112019-000653-A	<1	FT-FY20-112019-000653-B	<1
WS- 002561	4/16/2019	4/16/2020	2	Cooler	in hallway adjacent to room B205	High Left	WF-04162019-002561	12/19/2019	FT-FY20-112019-002561-A	<1	FT-FY20-112019-002561-B	<1
WS- 002562	4/16/2019	4/16/2020	2	Cooler	in hallway adjacent to room B205	Low Right	WF-04162019-002562	12/19/2019	FT-FY20-112019-002562-A	<1	FT-FY20-112019-002562-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000615	6/26/2019	6/26/2020	Basement	Food Prep Sink	In kitchen	Low	WF-06262019-000615	12/19/2019	FT-FY20-112019-000615-A	<1	FT-FY20-112019-000615-B	<1