



# Shepherd Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000601	3/10/2022	3/10/2023	Basement	Bottle Filler	In hallway adjacent to room 111 all gender restroom	WF-03102022-000601	1/7/2023	FT-FY23-11182022-000601-A	<1	FT-FY23-11182022-000601-B	<1
WS- 000602	3/10/2022	3/10/2023	Basement	Cooler	In hallway adjacent to room 111 all gender restroom High Left	WF-03102022-000602	1/7/2023	FT-FY23-11182022-000602-A	<1	FT-FY23-11182022-000602-B	<1
WS- 000603	3/10/2022	3/10/2023	Basement	Cooler	In hallway adjacent to room 111 all gender restroom Low Right	WF-03102022-000603	1/7/2023	FT-FY23-11182022-000603-A	<1	FT-FY23-11182022-000603-B	<1
WS- 000604	3/10/2022	3/10/2023	Basement	Bottle Filler	In cafeteria	WF-03102022-000604	1/7/2023	FT-FY23-11182022-000604-A	<1	FT-FY23-11182022-000604-B	<1
WS- 000605	3/10/2022	3/10/2023	Basement	Cooler	In cafeteria High Left	WF-03102022-000605	1/7/2023	FT-FY23-11182022-000605-A	<1	FT-FY23-11182022-000605-B	<1
WS- 000606	3/10/2022	3/10/2023	Basement	Cooler	In cafeteria Low Right	WF-03102022-000606	1/7/2023	FT-FY23-11182022-000606-A	<1	FT-FY23-11182022-000606-B	<1
WS- 000607	3/10/2022	3/10/2023	1	Bottle Filler	In hallway adjacent to room B105	WF-03102022-000607	1/7/2023	FT-FY23-11182022-000607-A	<1	FT-FY23-11182022-000607-B	<1
WS- 000608	9/6/2022	9/6/2023	Basement	Classroom Faucet	In classroom BG05	WF-09062022-000608	1/7/2023	FT-FY23-11182022-000608-A	<1	FT-FY23-11182022-000608-B	<1
WS- 000612	3/30/2021	3/30/2022	Basement	Break Room	In staff lounge AG06	WF-03302021-000612	1/7/2023	FT-FY23-11182022-000612-A	<1	FT-FY23-11182022-000612-B	<1
WS- 000618	3/10/2022	3/10/2023	1	Combo Fountain	In classroom A106 Right	WF-03102022-000618	1/7/2023	FT-FY23-11182022-000618-A	<1	FT-FY23-11182022-000618-B	<1
WS- 000619	9/6/2022	9/6/2023	1	Combo Faucet	In classroom A106 Left	WF-09062022-000619	1/7/2023	FT-FY23-11182022-000619-A	<1	FT-FY23-11182022-000619-B	<1
WS- 000620	3/10/2022	3/10/2023	1	Cooler	In hallway adjacent to room A106	WF-03102022-000620	1/7/2023	FT-FY23-11182022-000620-A	<1	FT-FY23-11182022-000620-B	<1
WS- 000621	9/6/2022	9/6/2023	1	Combo Faucet	In classroom A103 Left	WF-09062022-000621	1/7/2023	FT-FY23-11182022-000621-A	1.5	FT-FY23-11182022-000621-B	<1
WS- 000622	3/10/2022	3/10/2023	1	Combo Fountain	In classroom A103 Right	WF-03102022-000622	1/7/2023	FT-FY23-11182022-000622-A	<1	FT-FY23-11182022-000622-B	<1
WS- 000623	3/10/2022	3/10/2023	1	Cooler	In hallway adjacent to room A101	WF-03102022-000623	1/7/2023	FT-FY23-11182022-000623-A	<1	FT-FY23-11182022-000623-B	<1
WS- 000624	9/6/2022	9/6/2023	1	Combo Faucet	In classroom A101 Left	WF-09062022-000624	1/7/2023	FT-FY23-11182022-000624-A	<1	FT-FY23-11182022-000624-B	<1
WS- 000625	3/10/2022	3/10/2023	1	Combo Fountain	In classroom A101 Right	WF-03102022-000625	1/7/2023	FT-FY23-11182022-000625-A	<1	FT-FY23-11182022-000625-B	<1
WS- 000626	9/6/2022	9/6/2023	1	Combo Faucet	In classroom A102 Left	WF-09062022-000626	1/7/2023	FT-FY23-11182022-000626-A	<1	FT-FY23-11182022-000626-B	<1
WS- 000627	3/10/2022	3/10/2023	1	Combo Fountain	In classroom A102 Right	WF-03102022-000627	1/7/2023	FT-FY23-11182022-000627-A	<1	FT-FY23-11182022-000627-B	<1
WS- 000633	3/10/2022	3/10/2023	1	Cooler	In hallway adjacent to room C109 High Left	WF-03102022-000633	1/7/2023	FT-FY23-11182022-000633-A	<1	FT-FY23-11182022-000633-B	<1
WS- 000634	3/10/2022	3/10/2023	1	Cooler	In hallway adjacent to room C109 Low Right	WF-03102022-000634	1/7/2023	FT-FY23-11182022-000634-A	<1	FT-FY23-11182022-000634-B	<1
WS- 000635	3/10/2022	3/10/2023	1	Health Suite	In health suite C108B Left	WF-03102022-000635	1/7/2023	FT-FY23-11182022-000635-A	<1	FT-FY23-11182022-000635-B	<1
WS- 000637	3/10/2022	3/10/2023	1	Combo Fountain	In health suite C108B Right	WF-03102022-000637	1/7/2023	FT-FY23-11182022-000637-A	<1	FT-FY23-11182022-000637-B	<1
WS- 000638	3/10/2022	3/10/2023	1	Combo Fountain	In classroom C111 Right	WF-03102022-000638	1/7/2023	FT-FY23-11182022-000638-A	<1	FT-FY23-11182022-000638-B	<1
WS- 000639	9/6/2022	9/6/2023	1	Combo Faucet	In classroom C111 Left	WF-09062022-000639	1/7/2023	FT-FY23-11182022-000639-A	<1	FT-FY23-11182022-000639-B	<1
WS- 000642	3/10/2022	3/10/2023	2	Cooler	In hallway adjacent to room C211 High Left	WF-03102022-000642	1/7/2023	FT-FY23-11182022-000642-A	<1	FT-FY23-11182022-000642-B	<1
WS- 000643	3/10/2022	3/10/2023	2	Cooler	In hallway adjacent to room C211 Low Right	WF-03102022-000643	1/7/2023	FT-FY23-11182022-000643-A	<1	FT-FY23-11182022-000643-B	<1
WS- 000644	9/6/2022	9/6/2023	2	Combo Faucet	In classroom C204 Left	WF-09062022-000644	1/7/2023	FT-FY23-11182022-000644-A	1.9	FT-FY23-11182022-000644-B	<1
WS- 000645	3/10/2022	3/10/2023	2	Combo Fountain	In classroom C204 Right	WF-03102022-000645	1/7/2023	FT-FY23-11182022-000645-A	<1	FT-FY23-11182022-000645-B	<1
WS- 000646	9/6/2022	9/6/2023	2	Combo Faucet	In classroom C203 Left	WF-09062022-000646	1/7/2023	FT-FY23-11182022-000646-A	<1	FT-FY23-11182022-000646-B	<1
WS- 000647	3/10/2022	3/10/2023	2	Combo Fountain	In classroom C203 Right	WF-03102022-000647	1/7/2023	FT-FY23-11182022-000647-A	1.7	FT-FY23-11182022-000647-B	<1
WS- 000648	3/10/2022	3/10/2023	2	Cooler	In hallway adjacent to room C203 High Left	WF-03102022-000648	1/7/2023	FT-FY23-11182022-000648-A	<1	FT-FY23-11182022-000648-B	<1
WS- 000649	3/10/2022	3/10/2023	2	Cooler	In hallway adjacent to room C203 Low Right	WF-03102022-000649	1/7/2023	FT-FY23-11182022-000649-A	<1	FT-FY23-11182022-000649-B	<1
WS- 000650	8/23/2022	8/23/2023	2	Cooler	In hallway adjacent to room A210	WF-08232022-000650	1/7/2023	FT-FY23-11182022-000650-A	<1	FT-FY23-11182022-000650-B	<1
WS- 000651	9/6/2022	9/6/2023	2	Combo Faucet	In classroom A205 Left	WF-09062022-000651	1/7/2023	FT-FY23-11182022-000651-A	1.6	FT-FY23-11182022-000651-B	<1

WS- 000653	8/23/2022	8/23/2023	2	Cooler	In hallway adjacent to room A201		WF-08232022-000653	1/7/2023	FT-FY23-11182022-000653-A	<1	FT-FY23-11182022-000653-B	<1
WS- 002561	3/10/2022	3/10/2023	2	Cooler	in hallway adjacent to room B205	High Left	WF-03102022-002561	1/7/2023	FT-FY23-11182022-002561-A	<1	FT-FY23-11182022-002561-B	<1
WS- 002562	3/10/2022	3/10/2023	2	Cooler	in hallway adjacent to room B205	Low Right	WF-03102022-002562	1/7/2023	FT-FY23-11182022-002562-A	<1	FT-FY23-11182022-002562-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000615	2/23/2022	2/23/2023	Basement	Food Prep Sink	In kitchen	Low	WF-02232022-000615	1/7/2023	FT-FY23-11182022-000615-A	<1	FT-FY23-11182022-000615-B	<1