



Shepherd ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000601	2/20/2025	2/20/2026	Basement	Bottle Filler	In hallway adjacent to room 111 all gender restroom	WF-02202025-000601	11/24/2025	FT-FY26-10172025-000601-A	<2	FT-FY26-10172025-000601-B	<2
WS- 000602	2/20/2025	2/20/2026	Basement	Cooler	In hallway adjacent to room 111 all gender restroom High Left	WF-02202025-000602	11/24/2025	FT-FY26-10172025-000602-A	<2	FT-FY26-10172025-000602-B	<2
WS- 000603	2/20/2025	2/20/2026	Basement	Cooler	In hallway adjacent to room 111 all gender restroom Low Right	WF-02202025-000603	11/24/2025	FT-FY26-10172025-000603-A	<2	FT-FY26-10172025-000603-B	<2
WS- 000604	2/20/2025	2/20/2026	Basement	Bottle Filler	In cafeteria	WF-02202025-000604	11/24/2025	FT-FY26-10172025-000604-A	<2	FT-FY26-10172025-000604-B	<2
WS- 000605	2/20/2025	2/20/2026	Basement	Cooler	In cafeteria High Left	WF-02202025-000605	11/24/2025	FT-FY26-10172025-000605-A	<2	FT-FY26-10172025-000605-B	<2
WS- 000606	2/20/2025	2/20/2026	Basement	Cooler	In cafeteria Low Right	WF-02202025-000606	11/24/2025	FT-FY26-10172025-000606-A	<2	FT-FY26-10172025-000606-B	<2
WS- 000607	2/20/2025	2/20/2026	1	Bottle Filler	In hallway adjacent to room B105	WF-02202025-000607	11/24/2025	FT-FY26-10172025-000607-A	<2	FT-FY26-10172025-000607-B	<2
WS- 000610	2/20/2025	2/20/2026	Basement	Cooler	In hallway adjacent to room AG06 High Left	WF-02202025-000610	11/24/2025	FT-FY26-10172025-000610-A	<2	FT-FY26-10172025-000610-B	<2
WS- 000611	2/20/2025	2/20/2026	Basement	Cooler	In hallway adjacent to room AG06 Low Right	WF-02202025-000611	11/24/2025	FT-FY26-10172025-000611-A	<2	FT-FY26-10172025-000611-B	<2
WS- 000612	2/20/2025	2/20/2026	Basement	Break Room	In staff lounge AG06	WF-02202025-000612	11/24/2025	FT-FY26-10172025-000612-A	<2	FT-FY26-10172025-000612-B	<2
WS- 000618	2/20/2025	2/20/2026	1	Combo Fountain	In classroom A106 Right	WF-02202025-000618	11/24/2025	FT-FY26-10172025-000618-A	<2	FT-FY26-10172025-000618-B	<2
WS- 000619	8/19/2025	8/19/2026	1	Combo Faucet	In classroom A106 Left	WF-08192025-000619	11/24/2025	FT-FY26-10172025-000619-A	<2	FT-FY26-10172025-000619-B	<2
WS- 000620	2/20/2025	2/20/2026	1	Cooler	In hallway adjacent to room A106	WF-02202025-000620	11/24/2025	FT-FY26-10172025-000620-A	<2	FT-FY26-10172025-000620-B	<2
WS- 000621	8/19/2025	8/19/2026	1	Combo Faucet	In classroom A103 Left	WF-08192025-000621	11/24/2025	FT-FY26-10172025-000621-A	<2	FT-FY26-10172025-000621-B	<2
WS- 000623	2/20/2025	2/20/2026	1	Cooler	In hallway adjacent to room A101	WF-02202025-000623	11/24/2025	FT-FY26-10172025-000623-A	<2	FT-FY26-10172025-000623-B	<2
WS- 000624	8/19/2025	8/19/2026	1	Combo Faucet	In classroom A101 Left	WF-08192025-000624	11/24/2025	FT-FY26-10172025-000624-A	<2	FT-FY26-10172025-000624-B	<2
WS- 000625	2/20/2025	2/20/2026	1	Combo Fountain	In classroom A101 Right	WF-02202025-000625	11/24/2025	FT-FY26-10172025-000625-A	<2	FT-FY26-10172025-000625-B	<2
WS- 000626	8/19/2025	8/19/2026	1	Combo Faucet	In classroom A102 Left	WF-08192025-000626	11/24/2025	FT-FY26-10172025-000626-A	<2	FT-FY26-10172025-000626-B	<2
WS- 000627	2/20/2025	2/20/2026	1	Combo Fountain	In classroom A102 Right	WF-02202025-000627	11/24/2025	FT-FY26-10172025-000627-A	<2	FT-FY26-10172025-000627-B	<2
WS- 000628	2/20/2025	2/20/2026	1	Cooler	In hallway adjacent to room B105 High Left	WF-02202025-000628	11/24/2025	FT-FY26-10172025-000628-A	<2	FT-FY26-10172025-000628-B	<2
WS- 000629	2/20/2025	2/20/2026	1	Cooler	In hallway adjacent to room B105 Low Right	WF-02202025-000629	11/24/2025	FT-FY26-10172025-000629-A	<2	FT-FY26-10172025-000629-B	<2
WS- 000633	2/20/2025	2/20/2026	1	Cooler	In hallway adjacent to room C109 High Left	WF-02202025-000633	11/24/2025	FT-FY26-10172025-000633-A	<2	FT-FY26-10172025-000633-B	<2
WS- 000635	2/20/2025	2/20/2026	1	Health Suite	In health suite C108B Left	WF-02202025-000635	11/24/2025	FT-FY26-10172025-000635-A	<2	FT-FY26-10172025-000635-B	<2
WS- 000637	2/20/2025	2/20/2026	1	Combo Fountain	In health suite C108B Right	WF-02202025-000637	11/24/2025	FT-FY26-10172025-000637-A	<2	FT-FY26-10172025-000637-B	<2
WS- 000638	2/20/2025	2/20/2026	1	Combo Fountain	In classroom C111 Right	WF-02202025-000638	11/24/2025	FT-FY26-10172025-000638-A	<2	FT-FY26-10172025-000638-B	<2
WS- 000639	8/19/2025	8/19/2026	1	Combo Faucet	In classroom C111 Left	WF-08192025-000639	11/24/2025	FT-FY26-10172025-000639-A	<2	FT-FY26-10172025-000639-B	<2
WS- 000640	8/19/2025	8/19/2026	1	Combo Faucet	In classroom C110 Left	WF-08192025-000640	11/24/2025	FT-FY26-10172025-000640-A	<2	FT-FY26-10172025-000640-B	<2
WS- 000641	2/20/2025	2/20/2026	1	Combo Fountain	In classroom C110 Right	WF-02202025-000641	11/24/2025	FT-FY26-10172025-000641-A	<2	FT-FY26-10172025-000641-B	<2
WS- 000642	2/20/2025	2/20/2026	2	Cooler	In hallway adjacent to room C211 High Left	WF-02202025-000642	11/24/2025	FT-FY26-10172025-000642-A	<2	FT-FY26-10172025-000642-B	<2
WS- 000643	2/20/2025	2/20/2026	2	Cooler	In hallway adjacent to room C211 Low Right	WF-02202025-000643	11/24/2025	FT-FY26-10172025-000643-A	<2	FT-FY26-10172025-000643-B	<2
WS- 000644	8/19/2025	8/19/2026	2	Combo Faucet	In classroom C204 Left	WF-08192025-000644	11/24/2025	FT-FY26-10172025-000644-A	<2	FT-FY26-10172025-000644-B	<2
WS- 000645	2/20/2025	2/20/2026	2	Combo Fountain	In classroom C204 Right	WF-02202025-000645	11/24/2025	FT-FY26-10172025-000645-A	<2	FT-FY26-10172025-000645-B	<2
WS- 000646	8/19/2025	8/19/2026	2	Combo Faucet	In classroom C203 Left	WF-08192025-000646	11/24/2025	FT-FY26-10172025-000646-A	<2	FT-FY26-10172025-000646-B	<2
WS- 000647	2/20/2025	2/20/2026	2	Combo Fountain	In classroom C203 Right	WF-02202025-000647	11/24/2025	FT-FY26-10172025-000647-A	<2	FT-FY26-10172025-000647-B	<2

WS- 000648	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room C203	High Left	WF-02202025-000648	11/24/2025	FT-FY26-10172025-000648-A	<2	FT-FY26-10172025-000648-B	<2
WS- 000649	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room C203	Low Right	WF-02202025-000649	11/24/2025	FT-FY26-10172025-000649-A	<2	FT-FY26-10172025-000649-B	<2
WS- 000650	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room A210		WF-02202025-000650	11/24/2025	FT-FY26-10172025-000650-A	<2	FT-FY26-10172025-000650-B	<2
WS- 000651	8/19/2025	8/19/2026	2	Combo Faucet	in classroom A205	Left	WF-08192025-000651	11/24/2025	FT-FY26-10172025-000651-A	<2	FT-FY26-10172025-000651-B	<2
WS- 000653	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room A201		WF-02202025-000653	11/24/2025	FT-FY26-10172025-000653-A	<2	FT-FY26-10172025-000653-B	<2
WS- 002561	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room B205	High Left	WF-02202025-002561	11/24/2025	FT-FY26-10172025-002561-A	<2	FT-FY26-10172025-002561-B	<2
WS- 002562	2/20/2025	2/20/2026	2	Cooler	in hallway adjacent to room B205	Low Right	WF-02202025-002562	11/24/2025	FT-FY26-10172025-002562-A	<2	FT-FY26-10172025-002562-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000615	12/9/2024	12/9/2025	Basement	Food Prep Sink	in kitchen	Low	WF-12092024-000615	11/24/2025	FT-FY26-10172025-000615-A	<2	FT-FY26-10172025-000615-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.