



SHEPHERD ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SHEPHERD ELEMENTARY SCHOOL	WS-000610	8/18/2016	Basement	Cooler	In hallway adjacent to room AG06 High Left	FT-82016-000610-A	< 1	FT-82016-000610-B	< 1
2	SHEPHERD ELEMENTARY SCHOOL	WS-000611	8/18/2016	Basement	Cooler	In hallway adjacent to room AG06 Low Right	FT-72016-000611-A	< 1	FT-72016-000611-B	< 1
3	SHEPHERD ELEMENTARY SCHOOL	WS-000614	8/18/2016	Basement	Cooler	In cafeteria	FT-72016-000614-A	< 1	FT-72016-000614-B	< 1
4	SHEPHERD ELEMENTARY SCHOOL	WS-000615	8/18/2016	Basement	Food Prep Sink	In kitchen Low	FT-72016-000615-A	< 1	FT-72016-000615-B	< 1
5	SHEPHERD ELEMENTARY SCHOOL	WS-000618	8/18/2016	1	Fountain	In classroom A106 Right	FT-72016-000618-A	< 1	FT-72016-000618-B	< 1
6	SHEPHERD ELEMENTARY SCHOOL	WS-000620	8/18/2016	1	Cooler	In hallway adjacent to room A106	FT-72016-000620-A	< 1	FT-72016-000620-B	< 1
7	SHEPHERD ELEMENTARY SCHOOL	WS-000622	8/18/2016	1	Fountain	In classroom A103 Right	FT-72016-000622-A	< 1	FT-72016-000622-B	< 1
8	SHEPHERD ELEMENTARY SCHOOL	WS-000623	8/18/2016	1	Cooler	In hallway adjacent to room A101	FT-72016-000623-A	< 1	FT-72016-000623-B	< 1
9	SHEPHERD ELEMENTARY SCHOOL	WS-000625	8/18/2016	1	Fountain	In classroom A101 Right	FT-72016-000625-A	< 1	FT-72016-000625-B	< 1
10	SHEPHERD ELEMENTARY SCHOOL	WS-000627	8/18/2016	1	Fountain	In classroom A102 Right	FT-72016-000627-A	< 1	FT-72016-000627-B	< 1
11	SHEPHERD ELEMENTARY SCHOOL	WS-000628	8/18/2016	1	Cooler	In hallway adjacent to room B105 High Left	FT-82016-000628-A	< 1	FT-82016-000628-B	< 1
12	SHEPHERD ELEMENTARY SCHOOL	WS-000629	8/18/2016	1	Cooler	In hallway adjacent to room B105 Low Right	FT-72016-000629-A	< 1	FT-72016-000629-B	< 1
13	SHEPHERD ELEMENTARY SCHOOL	WS-000633	8/18/2016	1	Cooler	In hallway adjacent to room C109 High Left	FT-82016-000633-A	< 1	FT-82016-000633-B	< 1
14	SHEPHERD ELEMENTARY SCHOOL	WS-000634	8/18/2016	1	Cooler	In hallway adjacent to room C109 Low Right	FT-72016-000634-A	< 1	FT-72016-000634-B	< 1
15	SHEPHERD ELEMENTARY SCHOOL	WS-000635	8/18/2016	1	Health Suite	In health suite C108B Left	FT-82016-000635-A	< 1	FT-82016-000635-B	< 1
16	SHEPHERD ELEMENTARY SCHOOL	WS-000637	8/18/2016	1	Fountain	In health suite C108B Right	FT-72016-000637-A	< 1	FT-72016-000637-B	< 1
17	SHEPHERD ELEMENTARY SCHOOL	WS-000638	8/18/2016	1	Fountain	In classroom C111 Right	FT-72016-000638-A	< 1	FT-72016-000638-B	< 1
18	SHEPHERD ELEMENTARY SCHOOL	WS-000641	8/18/2016	1	Fountain	In classroom C110 Right	FT-72016-000641-A	< 1	FT-72016-000641-B	< 1
19	SHEPHERD ELEMENTARY SCHOOL	WS-000642	8/18/2016	2	Cooler	In hallway adjacent to room C211 High Left	FT-72016-000642-A	< 1	FT-72016-000642-B	< 1
20	SHEPHERD ELEMENTARY SCHOOL	WS-000643	8/18/2016	2	Cooler	In hallway adjacent to room C211 Low Right	FT-72016-000643-A	< 1	FT-72016-000643-B	< 1
21	SHEPHERD ELEMENTARY SCHOOL	WS-000645	8/18/2016	2	Fountain	In classroom C204 Right	FT-72016-000645-A	< 1	FT-72016-000645-B	< 1
22	SHEPHERD ELEMENTARY SCHOOL	WS-000647	8/18/2016	2	Fountain	In classroom C203 Right	FT-72016-000647-A	< 1	FT-72016-000647-B	< 1
23	SHEPHERD ELEMENTARY SCHOOL	WS-000648	8/18/2016	2	Cooler	In hallway adjacent to room C203 High Left	FT-72016-000648-A	< 1	FT-72016-000648-B	< 1
24	SHEPHERD ELEMENTARY SCHOOL	WS-000649	8/18/2016	2	Cooler	In hallway adjacent to room C203 Low Right	FT-72016-000649-A	< 1	FT-72016-000649-B	< 1
25	SHEPHERD ELEMENTARY SCHOOL	WS-000650	8/18/2016	2	Cooler	In hallway adjacent to room A210	FT-72016-000650-A	< 1	FT-72016-000650-B	< 1
26	SHEPHERD ELEMENTARY SCHOOL	WS-000652	8/18/2016	2	Fountain	In classroom A205	FT-72016-000652-A	< 1	FT-72016-000652-B	< 1
27	SHEPHERD ELEMENTARY SCHOOL	WS-000653	8/18/2016	2	Cooler	In hallway adjacent to room A201	FT-72016-000653-A	< 1	FT-72016-000653-B	< 1
28	SHEPHERD ELEMENTARY SCHOOL	WS-002561	8/18/2016	2	Cooler	In hallway adjacent to room B205 High Left	FT-82016-002561-A	< 1	FT-82016-002561-B	< 1
29	SHEPHERD ELEMENTARY SCHOOL	WS-002562	8/18/2016	2	Cooler	In hallway adjacent to room B205 Low Right	FT-82016-002562-A	< 1	FT-82016-002562-B	< 1