



SHEPHERD ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	SHEPHERD ELEMENTARY SCHOOL	WS- 000612	12/20/2016	Basement	Break Room	In staff lounge AG06	FT-102016-000612-A	< 1	FT-102016-000612-B	< 1
2	SHEPHERD ELEMENTARY SCHOOL	WS- 000624	12/20/2016	1	Combo Faucet	In classroom A101 Left	FT-122016-000624-A	< 1	FT-122016-000624-B	< 1
3	SHEPHERD ELEMENTARY SCHOOL	WS- 000621	12/20/2016	1	Combo Faucet	In classroom A103 Left	FT-122016-000621-A	< 1	FT-122016-000621-B	< 1
4	SHEPHERD ELEMENTARY SCHOOL	WS- 000626	12/20/2016	1	Combo Faucet	In classroom A102 Left	FT-122016-000626-A	< 1	FT-122016-000626-B	< 1
5	SHEPHERD ELEMENTARY SCHOOL	WS- 000619	12/20/2016	1	Combo Faucet	In classroom A106 Left	FT-122016-000619-A	< 1	FT-122016-000619-B	< 1
6	SHEPHERD ELEMENTARY SCHOOL	WS- 000644	12/20/2016	2	Combo Faucet	In classroom C204 Left	FT-122016-000644-A	< 1	FT-122016-000644-B	< 1
7	SHEPHERD ELEMENTARY SCHOOL	WS- 000646	12/20/2016	2	Combo Faucet	In classroom C203 Left	FT-122016-000646-A	< 1	FT-122016-000646-B	< 1
8	SHEPHERD ELEMENTARY SCHOOL	WS- 000639	12/20/2016	1	Combo Faucet	In classroom C111 Left	FT-122016-000639-A	< 1	FT-122016-000639-B	< 1
9	SHEPHERD ELEMENTARY SCHOOL	WS- 000640	12/20/2016	1	Combo Faucet	In classroom C110 Left	FT-122016-000640-A	< 1	FT-122016-000640-B	< 1
10	SHEPHERD ELEMENTARY SCHOOL	WS- 000651	12/20/2016	2	Combo Faucet	In classroom A205 Left	FT-122016-000651-A	< 1	FT-122016-000651-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb