



Shepherd Park CC Lead in Water Test Results

FY25 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|--|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 004851 | 3/1/2024 | 3/1/2025 | 1 | Bottle Filler | In hallway between restrooms | WF-03012024-004851 | 2/25/2025 | FT-FY25-01082025-004851-A | <2 | FT-FY25-01082025-004851-B | <2 |
| WS- 004852 | 3/1/2024 | 3/1/2025 | 1 | Cooler | In hallway between restrooms High Left | WF-03012024-004852 | 2/25/2025 | FT-FY25-01082025-004852-A | <2 | FT-FY25-01082025-004852-B | <2 |
| WS- 004853 | 3/1/2024 | 3/1/2025 | 1 | Cooler | In hallway between restrooms Low Right | WF-03012024-004853 | 2/25/2025 | FT-FY25-01082025-004853-A | <2 | FT-FY25-01082025-004853-B | <2 |
| WS- 004854 | 12/24/2024 | 12/24/2025 | 1 | Food Prep Sink | In kitchenette 107 | WF-12242024-004854 | 2/25/2025 | FT-FY25-01082025-004854-A | <2 | FT-FY25-01082025-004854-B | <2 |

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.