



Shepherd ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000610	11/26/2018	11/26/2019	Basement	Cooler	In hallway adjacent to room AG06 High Left	WF-11262018-000610	12/3/2018	FT-FY19-112018-000610-A	<1	FT-FY19-112018-000610-B	<1
WS-000611	11/26/2018	11/26/2019	Basement	Cooler	In hallway adjacent to room AG06 Low Right	WF-11262018-000611	12/3/2018	FT-FY19-112018-000611-A	<1	FT-FY19-112018-000611-B	<1
WS-000612	4/26/2018	4/26/2019	Basement	Break Room	In staff lounge AG06	WF-04262018-000612	12/3/2018	FT-FY19-112018-000612-A	<1	FT-FY19-112018-000612-B	<1
WS-000614	4/26/2018	4/26/2019	Basement	Cooler	In cafeteria	WF-04262018-000614	12/3/2018	FT-FY19-112018-000614-A	<1	FT-FY19-112018-000614-B	<1
WS-000618	4/26/2018	4/26/2019	1	Combo Fountain	In classroom A106 Right	WF-04262018-000618	12/3/2018	FT-FY19-112018-000618-A	<1	FT-FY19-112018-000618-B	<1
WS-000619	10/4/2018	10/4/2019	1	Combo Faucet	In classroom A106 Left	WF-10042018-000619	12/3/2018	FT-FY19-112018-000619-A	<1	FT-FY19-112018-000619-B	<1
WS-000620	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room A106	WF-04262018-000620	12/3/2018	FT-FY19-112018-000620-A	<1	FT-FY19-112018-000620-B	<1
WS-000621	10/4/2018	10/4/2019	1	Combo Faucet	In classroom A103 Left	WF-10042018-000621	12/3/2018	FT-FY19-112018-000621-A	<1	FT-FY19-112018-000621-B	<1
WS-000622	4/26/2018	4/26/2019	1	Combo Fountain	In classroom A103 Right	WF-04262018-000622	12/3/2018	FT-FY19-112018-000622-A	<1	FT-FY19-112018-000622-B	<1
WS-000623	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room A101	WF-04262018-000623	12/3/2018	FT-FY19-112018-000623-A	<1	FT-FY19-112018-000623-B	<1
WS-000624	10/4/2018	10/4/2019	1	Combo Faucet	In classroom A101 Left	WF-10042018-000624	12/3/2018	FT-FY19-112018-000624-A	<1	FT-FY19-112018-000624-B	<1
WS-000625	4/26/2018	4/26/2019	1	Combo Fountain	In classroom A101 Right	WF-04262018-000625	12/3/2018	FT-FY19-112018-000625-A	<1	FT-FY19-112018-000625-B	<1
WS-000626	10/4/2018	10/4/2019	1	Combo Faucet	In classroom A102 Left	WF-10042018-000626	12/3/2018	FT-FY19-112018-000626-A	<1	FT-FY19-112018-000626-B	<1
WS-000627	4/26/2018	4/26/2019	1	Combo Fountain	In classroom A102 Right	WF-04262018-000627	12/3/2018	FT-FY19-112018-000627-A	<1	FT-FY19-112018-000627-B	<1
WS-000628	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room B105 High Left	WF-04262018-000628	12/3/2018	FT-FY19-112018-000628-A	<1	FT-FY19-112018-000628-B	<1
WS-000629	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room B105 Low Right	WF-04262018-000629	12/3/2018	FT-FY19-112018-000629-A	<1	FT-FY19-112018-000629-B	<1
WS-000633	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room C109 High Left	WF-04262018-000633	12/3/2018	FT-FY19-112018-000633-A	<1	FT-FY19-112018-000633-B	<1
WS-000634	4/26/2018	4/26/2019	1	Cooler	In hallway adjacent to room C109 Low Right	WF-04262018-000634	12/3/2018	FT-FY19-112018-000634-A	<1	FT-FY19-112018-000634-B	<1
WS-000635	4/26/2018	4/26/2019	1	Health Suite	In health suite C108B Left	WF-04262018-000635	12/3/2018	FT-FY19-112018-000635-A	<1	FT-FY19-112018-000635-B	<1
WS-000637	4/26/2018	4/26/2019	1	Combo Fountain	In health suite C108B Right	WF-04262018-000637	12/3/2018	FT-FY19-112018-000637-A	<1	FT-FY19-112018-000637-B	<1
WS-000638	4/26/2018	4/26/2019	1	Combo Fountain	In classroom C111 Right	WF-04262018-000638	12/3/2018	FT-FY19-112018-000638-A	<1	FT-FY19-112018-000638-B	<1
WS-000639	10/4/2018	10/4/2019	1	Combo Faucet	In classroom C111 Left	WF-10042018-000639	12/3/2018	FT-FY19-112018-000639-A	<1	FT-FY19-112018-000639-B	<1
WS-000640	10/4/2018	10/4/2019	1	Combo Faucet	In classroom C110 Left	WF-10042018-000640	12/3/2018	FT-FY19-112018-000640-A	<1	FT-FY19-112018-000640-B	<1
WS-000641	4/26/2018	4/26/2019	1	Combo Fountain	In classroom C110 Right	WF-04262018-000641	12/3/2018	FT-FY19-112018-000641-A	<1	FT-FY19-112018-000641-B	<1
WS-000642	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room C211 High Left	WF-04262018-000642	12/3/2018	FT-FY19-112018-000642-A	<1	FT-FY19-112018-000642-B	<1
WS-000643	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room C211 Low Right	WF-04262018-000643	12/3/2018	FT-FY19-112018-000643-A	<1	FT-FY19-112018-000643-B	<1
WS-000644	10/4/2018	10/4/2019	2	Combo Faucet	In classroom C204 Left	WF-10042018-000644	12/3/2018	FT-FY19-112018-000644-A	<1	FT-FY19-112018-000644-B	<1
WS-000645	4/26/2018	4/26/2019	2	Combo Fountain	In classroom C204 Right	WF-04262018-000645	12/3/2018	FT-FY19-112018-000645-A	<1	FT-FY19-112018-000645-B	<1
WS-000646	10/4/2018	10/4/2019	2	Combo Faucet	In classroom C203 Left	WF-10042018-000646	12/3/2018	FT-FY19-112018-000646-A	<1	FT-FY19-112018-000646-B	<1
WS-000647	4/26/2018	4/26/2019	2	Combo Fountain	In classroom C203 Right	WF-04262018-000647	12/3/2018	FT-FY19-112018-000647-A	<1	FT-FY19-112018-000647-B	<1
WS-000648	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room C203 High Left	WF-04262018-000648	12/3/2018	FT-FY19-112018-000648-A	<1	FT-FY19-112018-000648-B	<1
WS-000649	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room C203 Low Right	WF-04262018-000649	12/3/2018	FT-FY19-112018-000649-A	<1	FT-FY19-112018-000649-B	<1

WS- 000650	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room A210		WF-04262018-000650	12/3/2018	FT-FY19-112018-000650-A	<1	FT-FY19-112018-000650-B	<1
WS- 000651	10/4/2018	10/4/2019	2	Combo Faucet	In classroom A205	Left	WF-10042018-000651	12/3/2018	FT-FY19-112018-000651-A	<1	FT-FY19-112018-000651-B	<1
WS- 000652	4/26/2018	4/26/2019	2	Combo Fountain	In classroom A205		WF-04262018-000652	12/3/2018	FT-FY19-112018-000652-A	<1	FT-FY19-112018-000652-B	<1
WS- 000653	4/26/2018	4/26/2019	2	Cooler	In hallway adjacent to room A201		WF-04262018-000653	12/3/2018	FT-FY19-112018-000653-A	<1	FT-FY19-112018-000653-B	<1
WS- 002561	4/26/2018	4/26/2019	2	Cooler	in hallway adjacent to room B205	High Left	WF-04262018-002561	12/3/2018	FT-FY19-112018-002561-A	<1	FT-FY19-112018-002561-B	<1
WS- 002562	4/26/2018	4/26/2019	2	Cooler	in hallway adjacent to room B205	Low Right	WF-04262018-002562	12/3/2018	FT-FY19-112018-002562-A	<1	FT-FY19-112018-002562-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000615	Basement	Food Prep Sink	In kitchen		Low	12/3/2018	FT-FY19-112018-000615-A	<1	FT-FY19-112018-000615-B	<1