



Sherwood RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005782	6/12/17	6/12/18	1	Cooler	In hallway adjacent to restrooms Right Low	WF-62017-005782	2/15/18	FT-FY18--62017-005782-A	<1	FT-FY18--62017-005782-B	<1
WS-005783	6/12/17	6/12/18	2	Cooler	In hallway adjacent to restrooms Left High	WF-62017-005783	2/15/18	FT-FY18--62017-005783-A	<1	FT-FY18--62017-005783-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005785	6/12/17	6/12/18	2	Food Prep Sink	In pantry room 206	WF-62017-005785	2/15/18	FT-FY18--62017-005785-A	<1	FT-FY18--62017-005785-B	<1