



Sherwood RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005781	3/27/2019	3/27/2020	1	Cooler	In hallway adjacent to restrooms	High Left	WF-03272019-005781	3/3/2020	FT-FY20-012020-005781-A	<1	FT-FY20-012020-005781-B	<1
WS-005783	3/27/2019	3/27/2020	2	Cooler	In hallway adjacent to restrooms	High Left	WF-03272019-005783	3/3/2020	FT-FY20-012020-005783-A	<1	FT-FY20-012020-005783-B	<1
WS-005784	3/27/2019	3/27/2020	2	Cooler	In hallway adjacent to restrooms	Low Right	WF-03272019-005784	3/3/2020	FT-FY20-012020-005784-A	<1	FT-FY20-012020-005784-B	<1
WS-005785	3/27/2019	3/27/2020	2	Food Prep Sink	In pantry room 206		WF-03272019-005785	3/3/2020	FT-FY20-012020-005785-A	<1	FT-FY20-012020-005785-B	<1