



Sherwood RC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005781	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to restrooms	High	Left	WF-03162021-005781	3/8/2022	FT-FY22-02092022-005781-A	<1	FT-FY22-02092022-005781-B	<1
WS- 005782	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to restrooms	Low	Right	WF-03162021-005782	3/8/2022	FT-FY22-02092022-005782-A	<1	FT-FY22-02092022-005782-B	<1
WS- 005783	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to restrooms	High	Left	WF-03162021-005783	3/8/2022	FT-FY22-02092022-005783-A	<1	FT-FY22-02092022-005783-B	<1
WS- 005784	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to restrooms	Low	Right	WF-03162021-005784	3/8/2022	FT-FY22-02092022-005784-A	<1	FT-FY22-02092022-005784-B	<1
WS- 005785	2/1/2022	2/1/2023	2	Food Prep Sink	In pantry room 206			WF-02012022-005785	3/8/2022	FT-FY22-02092022-005785-A	<1	FT-FY22-02092022-005785-B	<1