



# Sherwood Recreation Center Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005781	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to restrooms High Left	WF-03142022-005781	3/2/2023	FT-FY23-02022023-005781-A	<1	FT-FY23-02022023-005781-B	<1
WS- 005782	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to restrooms Low Right	WF-03142022-005782	3/2/2023	FT-FY23-02022023-005782-A	<1	FT-FY23-02022023-005782-B	<1
WS- 005783	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to restrooms High Left	WF-03142022-005783	3/2/2023	FT-FY23-02022023-005783-A	<1	FT-FY23-02022023-005783-B	<1
WS- 005784	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to restrooms Low Right	WF-03142022-005784	3/2/2023	FT-FY23-02022023-005784-A	<1	FT-FY23-02022023-005784-B	<1
WS- 005785	1/9/2023	1/9/2024	2	Food Prep Sink	In pantry room 206	WF-01092023-005785	3/2/2023	FT-FY23-02022023-005785-A	<1	FT-FY23-02022023-005785-B	<1