



Sherwood Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005782	3/1/2024	3/1/2025	1	Cooler	In hallway adjacent to restrooms Low Right	WF-03012024-005782	3/18/2024	FT-FY24-03052024-005782-A	<1	FT-FY24-03052024-005782-B	<1
WS-005783	3/1/2024	3/1/2025	2	Cooler	In hallway adjacent to restrooms High Left	WF-03012024-005783	3/18/2024	FT-FY24-03052024-005783-A	<1	FT-FY24-03052024-005783-B	<1
WS-005784	3/1/2024	3/1/2025	2	Cooler	In hallway adjacent to restrooms Low Right	WF-03012024-005784	3/18/2024	FT-FY24-03052024-005784-A	<1	FT-FY24-03052024-005784-B	<1
WS-005785	12/6/2023	12/6/2024	2	Food Prep Sink	In pantry room 206	WF-12062023-005785	3/18/2024	FT-FY24-03052024-005785-A	<1	FT-FY24-03052024-005785-B	<1