



SHERWOOD REC LEAD WATER TEST RESULTS



Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1 SHERWOOD RECREATION CENTER	WS- 005781	9/22/2016	1	Cooler	In hallway adjacent to restrooms High Left	FT-82016-005781-A	< 1	FT-82016-005781-B	< 1
2 SHERWOOD RECREATION CENTER	WS- 005782	9/22/2016	1	Cooler	In hallway adjacent to restrooms Low Right	FT-82016-005782-A	< 1	FT-82016-005782-B	< 1
3 SHERWOOD RECREATION CENTER	WS- 005783	9/22/2016	2	Cooler	In hallway adjacent to restrooms High Left	FT-82016-005783-A	< 1	FT-82016-005783-B	< 1
4 SHERWOOD RECREATION CENTER	WS- 005784**	9/22/2016	2	Cooler	In hallway adjacent to restrooms Low Right	FT-82016-005784-A	< 1	FT-82016-005784-B	1.4
		10/7/2016				Re-test A	< 1	Re-test B	< 1
5 SHERWOOD RECREATION CENTER	WS- 005785	9/22/2016	2	Food Prep Sink	In pantry room 206	FT-82016-005785-A	< 1	FT-82016-005785-B	< 1

**Filters and plumbing checked and filters re-tested.