



# Simon Elementary School Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010293	4/15/2025	4/15/2026	1	Cooler	In hallway adjacent to room 105	WF-04152025-010293	12/3/2025	FT-FY26-10172025-010293-A	<2	FT-FY26-10172025-010293-B	<2
WS- 010294	4/15/2025	4/15/2026	1	Cooler	In hallway adjacent to room 116	WF-04152025-010294	12/3/2025	FT-FY26-10172025-010294-A	<2	FT-FY26-10172025-010294-B	<2
WS- 010297	8/25/2025	8/25/2026	1	Combo Faucet	In classroom 114	WF-08252025-010297	12/3/2025	FT-FY26-10172025-010297-A	<2	FT-FY26-10172025-010297-B	<2
WS- 010298	4/15/2025	4/15/2026	1	Combo Fountain	In classroom 114	WF-04152025-010298	12/3/2025	FT-FY26-10172025-010298-A	<2	FT-FY26-10172025-010298-B	<2
WS- 010299	4/15/2025	4/15/2026	2	Cooler	In hallway adjacent to room 211	WF-04152025-010299	12/3/2025	FT-FY26-10172025-010299-A	<2	FT-FY26-10172025-010299-B	<2
WS- 010300	4/15/2025	4/15/2026	2	Cooler	In hallway adjacent to room 205	WF-04152025-010300	12/3/2025	FT-FY26-10172025-010300-A	<2	FT-FY26-10172025-010300-B	<2
WS- 010302	4/15/2025	4/15/2026	3	Cooler	In hallway adjacent to room 305	WF-04152025-010302	12/3/2025	FT-FY26-10172025-010302-A	<2	FT-FY26-10172025-010302-B	<2
WS- 010303	4/15/2025	4/15/2026	3	Cooler	In hallway adjacent to room 309	WF-04152025-010303	12/3/2025	FT-FY26-10172025-010303-A	<2	FT-FY26-10172025-010303-B	<2
WS- 010304	4/15/2025	4/15/2026	Ground Floor	Cooler	In hallway adjacent to room 013	WF-04152025-010304	12/3/2025	FT-FY26-10172025-010304-A	<2	FT-FY26-10172025-010304-B	<2
WS- 010305	8/25/2025	8/25/2026	Ground Floor	Combo Faucet	In classroom 014	WF-08252025-010305	12/3/2025	FT-FY26-10172025-010305-A	<2	FT-FY26-10172025-010305-B	<2
WS- 010308	8/25/2025	8/25/2026	Ground Floor	Combo Faucet	In classroom 015	WF-08252025-010308	12/3/2025	FT-FY26-10172025-010308-A	<2	FT-FY26-10172025-010308-B	<2
WS- 010309	4/15/2025	4/15/2026	Ground Floor	Health Suite	In health suite 013	WF-04152025-010309	12/3/2025	FT-FY26-10172025-010309-A	<2	FT-FY26-10172025-010309-B	<2
WS- 010313	4/15/2025	4/15/2026	Ground Floor	Cooler	In hallway adjacent to room 003	WF-04152025-010313	12/3/2025	FT-FY26-10172025-010313-A	<2	FT-FY26-10172025-010313-B	<2
WS- 010314	4/15/2025	4/15/2026	Ground Floor	Break Room	In staff lounge	WF-04152025-010314	12/3/2025	FT-FY26-10172025-010314-A	<2	FT-FY26-10172025-010314-B	<2
WS- 010316	4/15/2025	4/15/2026	Ground Floor	Combo Fountain	In classroom 001	WF-04152025-010316	12/3/2025	FT-FY26-10172025-010316-A	<2	FT-FY26-10172025-010316-B	<2
WS- 010317	8/25/2025	8/25/2026	Ground Floor	Combo Faucet	In classroom 001	WF-08252025-010317	12/3/2025	FT-FY26-10172025-010317-A	<2	FT-FY26-10172025-010317-B	<2
WS- 010487	4/15/2025	4/15/2026	Ground Floor	Bottle Filler	In hallway adjacent to room 003	WF-04152025-010487	12/3/2025	FT-FY26-10172025-010487-A	<2	FT-FY26-10172025-010487-B	<2

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010311	12/9/2024	12/9/2025	Ground Floor	Food Prep Sink	In kitchen	WF-12092024-010311	12/3/2025	FT-FY26-10172025-010311-A	<2	FT-FY26-10172025-010311-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.