



Simon Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010293	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 105	WF-05172021-010293	2/18/2022	FT-FY22-01182022-010293-A	<1	FT-FY22-01182022-010293-B	<1
WS- 010294	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 116	WF-05172021-010294	2/18/2022	FT-FY22-01182022-010294-A	<1	FT-FY22-01182022-010294-B	<1
WS- 010295	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 115	WF-09212021-010295	2/18/2022	FT-FY22-01182022-010295-A	<1	FT-FY22-01182022-010295-B	<1
WS- 010296	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 115	WF-05172021-010296	2/18/2022	FT-FY22-01182022-010296-A	<1	FT-FY22-01182022-010296-B	<1
WS- 010297	9/21/2021	9/21/2022	1	Combo Faucet	In classroom 114	WF-09212021-010297	2/18/2022	FT-FY22-01182022-010297-A	<1	FT-FY22-01182022-010297-B	<1
WS- 010298	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 114	WF-05172021-010298	2/18/2022	FT-FY22-01182022-010298-A	<1	FT-FY22-01182022-010298-B	<1
WS- 010299	5/17/2021	5/17/2022	2	Cooler	In hallway adjacent to room 211	WF-05172021-010299	2/18/2022	FT-FY22-01182022-010299-A	<1	FT-FY22-01182022-010299-B	<1
WS- 010300	5/17/2021	5/17/2022	2	Cooler	In hallway adjacent to room 205	WF-05172021-010300	2/18/2022	FT-FY22-01182022-010300-A	<1	FT-FY22-01182022-010300-B	<1
WS- 010302	5/17/2021	5/17/2022	3	Cooler	In hallway adjacent to room 305	WF-05172021-010302	2/18/2022	FT-FY22-01182022-010302-A	<1	FT-FY22-01182022-010302-B	<1
WS- 010303	5/17/2021	5/17/2022	3	Cooler	In hallway adjacent to room 309	WF-05172021-010303	2/18/2022	FT-FY22-01182022-010303-A	<1	FT-FY22-01182022-010303-B	<1
WS- 010304	5/17/2021	5/17/2022	Ground Floor	Cooler	In hallway adjacent to room 013	WF-05172021-010304	2/18/2022	FT-FY22-01182022-010304-A	<1	FT-FY22-01182022-010304-B	<1
WS- 010305	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom 014	WF-09212021-010305	2/18/2022	FT-FY22-01182022-010305-A	<1	FT-FY22-01182022-010305-B	<1
WS- 010306	5/17/2021	5/17/2022	Ground Floor	Combo Fountain	In classroom 014	WF-05172021-010306	2/18/2022	FT-FY22-01182022-010306-A	<1	FT-FY22-01182022-010306-B	<1
WS- 010307	5/17/2021	5/17/2022	Ground Floor	Combo Fountain	In classroom 015	WF-05172021-010307	2/18/2022	FT-FY22-01182022-010307-A	<1	FT-FY22-01182022-010307-B	<1
WS- 010308	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom 015	WF-09212021-010308	2/18/2022	FT-FY22-01182022-010308-A	<1	FT-FY22-01182022-010308-B	<1
WS- 010309	5/17/2021	5/17/2022	Ground Floor	Health Suite	In health suite 013	WF-05172021-010309	2/18/2022	FT-FY22-01182022-010309-A	<1	FT-FY22-01182022-010309-B	<1
WS- 010310	9/21/2021	9/21/2022	Ground Floor	Classroom Faucet	in classroom 012	WF-09212021-010310	2/18/2022	FT-FY22-01182022-010310-A	<1	FT-FY22-01182022-010310-B	<1
WS- 010314	5/17/2021	5/17/2022	Ground Floor	Break Room	In staff lounge	WF-05172021-010314	2/18/2022	FT-FY22-01182022-010314-A	<1	FT-FY22-01182022-010314-B	<1
WS- 010316	5/17/2021	5/17/2022	Ground Floor	Combo Fountain	In classroom 001	WF-05172021-010316	2/18/2022	FT-FY22-01182022-010316-A	<1	FT-FY22-01182022-010316-B	<1
WS- 010317	9/21/2021	9/21/2022	Ground Floor	Combo Faucet	In classroom 001	WF-09212021-010317	2/18/2022	FT-FY22-01182022-010317-A	<1	FT-FY22-01182022-010317-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010311	2/9/2022	2/9/2023	Ground Floor	Food Prep Sink	In kitchen	WF-02092022-010311	2/18/2022	FT-FY22-01182022-010311-A	<1	FT-FY22-01182022-010311-B	<1