



# Simon ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010293	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to room 105	WF-05012019-010293	10/25/2019	FT-FY20-102019-010293-A	<1	FT-FY20-102019-010293-B	<1
WS- 010294	5/1/2019	5/1/2020	1	Cooler	In hallway adjacent to room 116	WF-05012019-010294	10/25/2019	FT-FY20-102019-010294-A	<1	FT-FY20-102019-010294-B	<1
WS- 010295	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 115	WF-10092019-010295	10/25/2019	FT-FY20-102019-010295-A	<1	FT-FY20-102019-010295-B	<1
WS- 010296	5/1/2019	5/1/2020	1	Combo Fountain	In classroom 115	WF-05012019-010296	10/25/2019	FT-FY20-102019-010296-A	<1	FT-FY20-102019-010296-B	<1
WS- 010299	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to room 211	WF-05012019-010299	10/25/2019	FT-FY20-102019-010299-A	<1	FT-FY20-102019-010299-B	<1
WS- 010300	5/1/2019	5/1/2020	2	Cooler	In hallway adjacent to room 205	WF-05012019-010300	10/25/2019	FT-FY20-102019-010300-A	<1	FT-FY20-102019-010300-B	<1
WS- 010302	5/1/2019	5/1/2020	3	Cooler	In hallway adjacent to room 305	WF-05012019-010302	10/25/2019	FT-FY20-102019-010302-A	<1	FT-FY20-102019-010302-B	<1
WS- 010303	5/1/2019	5/1/2020	3	Cooler	In hallway adjacent to room 309	WF-05012019-010303	10/25/2019	FT-FY20-102019-010303-A	<1	FT-FY20-102019-010303-B	<1
WS- 010304	5/1/2019	5/1/2020	Ground Floor	Cooler	In hallway adjacent to room 013	WF-05012019-010304	10/25/2019	FT-FY20-102019-010304-A	<1	FT-FY20-102019-010304-B	<1
WS- 010305	10/9/2019	10/9/2020	Ground Floor	Combo Faucet	In classroom 014	WF-10092019-010305	10/25/2019	FT-FY20-102019-010305-A	4.1	FT-FY20-102019-010305-B	<1
WS- 010306	5/1/2019	5/1/2020	Ground Floor	Combo Fountain	In classroom 014	WF-05012019-010306	10/25/2019	FT-FY20-102019-010306-A	<1	FT-FY20-102019-010306-B	<1
WS- 010309	5/1/2019	5/1/2020	Ground Floor	Health Suite	In health suite 013	WF-05012019-010309	10/25/2019	FT-FY20-102019-010309-A	<1	FT-FY20-102019-010309-B	<1
WS- 010310	10/9/2019	10/9/2020	Ground Floor	Classroom Faucet	In classroom 012	WF-10092019-010310	10/25/2019	FT-FY20-102019-010310-A	<1	FT-FY20-102019-010310-B	<1
WS- 010313	5/1/2019	5/1/2020	Ground Floor	Cooler	In hallway adjacent to room 003	WF-05012019-010313	10/25/2019	FT-FY20-102019-010313-A	<1	FT-FY20-102019-010313-B	<1
WS- 010314	5/1/2019	5/1/2020	Ground Floor	Break Room	In staff lounge	WF-05012019-010314	10/25/2019	FT-FY20-102019-010314-A	<1	FT-FY20-102019-010314-B	<1
WS- 010316	5/1/2019	5/1/2020	Ground Floor	Combo Fountain	In classroom 001	WF-05012019-010316	10/25/2019	FT-FY20-102019-010316-A	<1	FT-FY20-102019-010316-B	<1
WS- 010317	10/9/2019	10/9/2020	Ground Floor	Combo Faucet	In classroom 001	WF-10092019-010317	10/25/2019	FT-FY20-102019-010317-A	3.2	FT-FY20-102019-010317-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010311	6/25/2019	6/25/2020	Ground Floor	Food Prep Sink	In kitchen	WF-06252019-010311	10/25/2019	FT-FY20-102019-010311-A	<1	FT-FY20-102019-010311-B	<1