



# Simon Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010293	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 105	WF-05092022-010293	10/27/2022	FT-FY23-10102022-010293-A	<1	FT-FY23-10102022-010293-B	<1
WS- 010294	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 116	WF-05092022-010294	10/27/2022	FT-FY23-10102022-010294-A	<1	FT-FY23-10102022-010294-B	<1
WS- 010295	9/13/2022	9/13/2023	1	Combo Faucet	In classroom 115	WF-09132022-010295	10/27/2022	FT-FY23-10102022-010295-A	<1	FT-FY23-10102022-010295-B	<1
WS- 010296	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 115	WF-05092022-010296	10/27/2022	FT-FY23-10102022-010296-A	<1	FT-FY23-10102022-010296-B	<1
WS- 010297	9/13/2022	9/13/2023	1	Combo Faucet	In classroom 114	WF-09132022-010297	10/27/2022	FT-FY23-10102022-010297-A	<1	FT-FY23-10102022-010297-B	<1
WS- 010298	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 114	WF-05092022-010298	10/27/2022	FT-FY23-10102022-010298-A	<1	FT-FY23-10102022-010298-B	<1
WS- 010299	5/9/2022	5/9/2023	2	Cooler	In hallway adjacent to room 211	WF-05092022-010299	10/27/2022	FT-FY23-10102022-010299-A	<1	FT-FY23-10102022-010299-B	<1
WS- 010300	5/9/2022	5/9/2023	2	Cooler	In hallway adjacent to room 205	WF-05092022-010300	10/27/2022	FT-FY23-10102022-010300-A	<1	FT-FY23-10102022-010300-B	<1
WS- 010302	5/9/2022	5/9/2023	3	Cooler	In hallway adjacent to room 305	WF-05092022-010302	10/27/2022	FT-FY23-10102022-010302-A	<1	FT-FY23-10102022-010302-B	<1
WS- 010303	5/9/2022	5/9/2023	3	Cooler	In hallway adjacent to room 309	WF-05092022-010303	10/27/2022	FT-FY23-10102022-010303-A	<1	FT-FY23-10102022-010303-B	<1
WS- 010304	5/9/2022	5/9/2023	Ground Floor	Cooler	In hallway adjacent to room 013	WF-05092022-010304	10/27/2022	FT-FY23-10102022-010304-A	<1	FT-FY23-10102022-010304-B	<1
WS- 010305	9/13/2022	9/13/2023	Ground Floor	Combo Faucet	In classroom 014	WF-09132022-010305	10/27/2022	FT-FY23-10102022-010305-A	<1	FT-FY23-10102022-010305-B	<1
WS- 010307	5/9/2022	5/9/2023	Ground Floor	Combo Fountain	In classroom 015	WF-05092022-010307	10/27/2022	FT-FY23-10102022-010307-A	<1	FT-FY23-10102022-010307-B	<1
WS- 010308	9/13/2022	9/13/2023	Ground Floor	Combo Faucet	In classroom 015	WF-09132022-010308	10/27/2022	FT-FY23-10102022-010308-A	<1	FT-FY23-10102022-010308-B	<1
WS- 010309	5/9/2022	5/9/2023	Ground Floor	Health Suite	In health suite 013	WF-05092022-010309	10/27/2022	FT-FY23-10102022-010309-A	<1	FT-FY23-10102022-010309-B	<1
WS- 010310	9/13/2022	9/13/2023	Ground Floor	Classroom Faucet	In classroom 012	WF-09132022-010310	10/27/2022	FT-FY23-10102022-010310-A	<1	FT-FY23-10102022-010310-B	<1
WS- 010313	5/9/2022	5/9/2023	Ground Floor	Cooler	In hallway adjacent to room 003	WF-05092022-010313	10/27/2022	FT-FY23-10102022-010313-A	<1	FT-FY23-10102022-010313-B	<1
WS- 010314	5/9/2022	5/9/2023	Ground Floor	Break Room	In staff lounge	WF-05092022-010314	10/27/2022	FT-FY23-10102022-010314-A	<1	FT-FY23-10102022-010314-B	<1
WS- 010316	5/9/2022	5/9/2023	Ground Floor	Combo Fountain	In classroom 001	WF-05092022-010316	10/27/2022	FT-FY23-10102022-010316-A	<1	FT-FY23-10102022-010316-B	<1
WS- 010317	9/13/2022	9/13/2023	Ground Floor	Combo Faucet	In classroom 001	WF-09132022-010317	10/27/2022	FT-FY23-10102022-010317-A	<1	FT-FY23-10102022-010317-B	<1
WS- 010487	5/9/2022	5/9/2023	Ground Floor	Bottle Filler	In hallway adjacent to room 003	WF-05092022-010487	10/27/2022	FT-FY23-10102022-010487-A	<1	FT-FY23-10102022-010487-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010311	2/9/2022	2/9/2023	Ground Floor	Food Prep Sink	In kitchen	WF-02092022-010311	10/27/2022	FT-FY23-10102022-010311-A	<1	FT-FY23-10102022-010311-B	<1