



# SIMON ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	SIMON ELEMENTARY SCHOOL	WS- 010314	12/30/2016	Ground Floor	Break Room	In staff lounge	FT-102016-010314-A	< 1	FT-102016-010314-B	< 1
2	SIMON ELEMENTARY SCHOOL	WS- 010297	12/30/2016	1	Combo Faucet	In classroom 114	FT-122016-010297-A	< 1	FT-122016-010297-B	< 1
3	SIMON ELEMENTARY SCHOOL	WS- 010295	12/30/2016	1	Combo Faucet	In classroom 115	FT-122016-010295-A	< 1	FT-122016-010295-B	< 1
4	SIMON ELEMENTARY SCHOOL	WS- 010308	12/30/2016	Ground Floor	Combo Faucet	In classroom 015	FT-122016-010308-A	< 1	FT-122016-010308-B	< 1
5	SIMON ELEMENTARY SCHOOL	WS- 010310	12/30/2016	Ground Floor	Classroom Faucet	in classroom 012	FT-112016-010310-A	< 1	FT-112016-010310-B	< 1
6	SIMON ELEMENTARY SCHOOL	WS- 010317	12/30/2016	Ground Floor	Combo Faucet	In classroom 001	FT-112016-010317-A	< 1	FT-112016-010317-B	< 1
7	SIMON ELEMENTARY SCHOOL	WS- 010305	12/30/2016	Ground Floor	Combo Faucet	In classroom 014	FT-112016-010305-A	< 1	FT-112016-010305-B	< 1

**Note :**

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb