



Simon ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010293	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 105	WF-05072018-010293	10/26/2018	FT-FY19-102018-010293-A	< 1	FT-FY19-102018-010293-B	< 1
WS- 010294	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 116	WF-05072018-010294	10/26/2018	FT-FY19-102018-010294-A	< 1	FT-FY19-102018-010294-B	< 1
WS- 010295	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 115	WF-10152018-010295	10/26/2018	FT-FY19-102018-010295-A	< 1	FT-FY19-102018-010295-B	< 1
WS- 010296	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 115	WF-05072018-010296	10/26/2018	FT-FY19-102018-010296-A	< 1	FT-FY19-102018-010296-B	< 1
WS- 010297	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 114	WF-10152018-010297	10/26/2018	FT-FY19-102018-010297-A	< 1	FT-FY19-102018-010297-B	< 1
WS- 010298	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 114	WF-05072018-010298	10/26/2018	FT-FY19-102018-010298-A	< 1	FT-FY19-102018-010298-B	< 1
WS- 010299	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room 211	WF-05072018-010299	10/26/2018	FT-FY19-102018-010299-A	< 1	FT-FY19-102018-010299-B	< 1
WS- 010300	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room 205	WF-05072018-010300	10/26/2018	FT-FY19-102018-010300-A	< 1	FT-FY19-102018-010300-B	1.6
WS- 010302	5/7/2018	5/7/2019	3	Cooler	In hallway adjacent to room 305	WF-05072018-010302	10/26/2018	FT-FY19-102018-010302-A	< 1	FT-FY19-102018-010302-B	< 1
WS- 010303	5/7/2018	5/7/2019	3	Cooler	In hallway adjacent to room 309	WF-05072018-010303	10/26/2018	FT-FY19-102018-010303-A	< 1	FT-FY19-102018-010303-B	< 1
WS- 010304	5/7/2018	5/7/2019	Ground Floor	Cooler	In hallway adjacent to room 013	WF-05072018-010304	10/26/2018	FT-FY19-102018-010304-A	< 1	FT-FY19-102018-010304-B	< 1
WS- 010305	10/15/2018	10/15/2019	Ground Floor	Combo Faucet	In classroom 014	WF-10152018-010305	10/26/2018	FT-FY19-102018-010305-A	< 1	FT-FY19-102018-010305-B	< 1
WS- 010306	5/7/2018	5/7/2019	Ground Floor	Combo Fountain	In classroom 014	WF-05072018-010306	10/26/2018	FT-FY19-102018-010306-A	< 1	FT-FY19-102018-010306-B	< 1
WS- 010307	5/7/2018	5/7/2019	Ground Floor	Combo Fountain	In classroom 015	WF-05072018-010307	10/26/2018	FT-FY19-102018-010307-A	< 1	FT-FY19-102018-010307-B	< 1
WS- 010308	10/15/2018	10/15/2019	Ground Floor	Combo Faucet	In classroom 015	WF-10152018-010308	10/26/2018	FT-FY19-102018-010308-A	< 1	FT-FY19-102018-010308-B	< 1
WS- 010309	5/7/2018	5/7/2019	Ground Floor	Health Suite	In health suite 013	WF-05072018-010309	10/26/2018	FT-FY19-102018-010309-A	< 1	FT-FY19-102018-010309-B	< 1
WS- 010310	10/15/2018	10/15/2019	Ground Floor	Classroom Faucet	In classroom 012	WF-10152018-010310	10/26/2018	FT-FY19-102018-010310-A	< 1	FT-FY19-102018-010310-B	< 1
WS- 010313	5/7/2018	5/7/2019	Ground Floor	Cooler	In hallway adjacent to room 003	WF-05072018-010313	10/26/2018	FT-FY19-102018-010313-A	< 1	FT-FY19-102018-010313-B	< 1
WS- 010314	5/7/2018	5/7/2019	Ground Floor	Break Room	In staff lounge	WF-05072018-010314	10/26/2018	FT-FY19-102018-010314-A	< 1	FT-FY19-102018-010314-B	< 1
WS- 010316	5/7/2018	5/7/2019	Ground Floor	Combo Fountain	In classroom 001	WF-05072018-010316	10/26/2018	FT-FY19-102018-010316-A	< 1	FT-FY19-102018-010316-B	< 1
WS- 010317	10/15/2018	10/15/2019	Ground Floor	Combo Faucet	In classroom 001	WF-10152018-010317	10/26/2018	FT-FY19-102018-010317-A	< 1	FT-FY19-102018-010317-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010311	Ground Floor	Food Prep Sink	In kitchen	10/26/2018	FT-FY19-102018-010311-A	< 1	FT-FY19-102018-010311-B	< 1