



Smothers Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016000	5/22/2023	5/22/2024	1	Bottle Filler	In gym	WF-05222023-016000	1/15/2024	FT-FY24-11272023-016000-A	<1	FT-FY24-11272023-016000-B	<1
WS-016001	5/22/2023	5/22/2024	1	Cooler	In gym High Left	WF-05222023-016001	1/15/2024	FT-FY24-11272023-016001-A	<1	FT-FY24-11272023-016001-B	<1
WS-016002	5/22/2023	5/22/2024	1	Cooler	In gym Low Right	WF-05222023-016002	1/15/2024	FT-FY24-11272023-016002-A	<1	FT-FY24-11272023-016002-B	<1
WS-016003	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 127	WF-08152023-016003	1/15/2024	FT-FY24-11272023-016003-A	<1	FT-FY24-11272023-016003-B	<1
WS-016004	5/22/2023	5/22/2024	1	Combo Fountain	In classroom 127	WF-05222023-016004	1/15/2024	FT-FY24-11272023-016004-A	1.8	FT-FY24-11272023-016004-B	<1
WS-016005	5/22/2023	5/22/2024	1	Bottle Filler	In hallway adjacent to elevator	WF-05222023-016005	1/15/2024	FT-FY24-11272023-016005-A	<1	FT-FY24-11272023-016005-B	<1
WS-016006	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to elevator High Left	WF-05222023-016006	1/15/2024	FT-FY24-11272023-016006-A	<1	FT-FY24-11272023-016006-B	<1
WS-016007	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to elevator Low Right	WF-05222023-016007	1/15/2024	FT-FY24-11272023-016007-A	<1	FT-FY24-11272023-016007-B	<1
WS-016008	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 123	WF-08152023-016008	1/15/2024	FT-FY24-11272023-016008-A	<1	FT-FY24-11272023-016008-B	<1
WS-016009	5/22/2023	5/22/2024	1	Combo Fountain	In classroom 123	WF-05222023-016009	1/15/2024	FT-FY24-11272023-016009-A	<1	FT-FY24-11272023-016009-B	<1
WS-016014	5/22/2023	5/22/2024	1	Bottle Filler	In cafeteria	WF-05222023-016014	1/15/2024	FT-FY24-11272023-016014-A	<1	FT-FY24-11272023-016014-B	<1
WS-016015	5/22/2023	5/22/2024	1	Cooler	In cafeteria High Left	WF-05222023-016015	1/15/2024	FT-FY24-11272023-016015-A	<1	FT-FY24-11272023-016015-B	<1
WS-016016	5/22/2023	5/22/2024	1	Cooler	In cafeteria Low Right	WF-05222023-016016	1/15/2024	FT-FY24-11272023-016016-A	<1	FT-FY24-11272023-016016-B	<1
WS-016017	5/22/2023	5/22/2024	1	Bottle Filler	In hallway adjacent to room 121	WF-05222023-016017	1/15/2024	FT-FY24-11272023-016017-A	<1	FT-FY24-11272023-016017-B	<1
WS-016018	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to room 121 High Left	WF-05222023-016018	1/15/2024	FT-FY24-11272023-016018-A	<1	FT-FY24-11272023-016018-B	<1
WS-016019	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to room 121 Low Right	WF-05222023-016019	1/15/2024	FT-FY24-11272023-016019-A	<1	FT-FY24-11272023-016019-B	<1
WS-016020	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 121	WF-08152023-016020	1/15/2024	FT-FY24-11272023-016020-A	<1	FT-FY24-11272023-016020-B	<1
WS-016021	5/22/2023	5/22/2024	1	Combo Fountain	In classroom 121	WF-05222023-016021	1/15/2024	FT-FY24-11272023-016021-A	<1	FT-FY24-11272023-016021-B	<1
WS-016022	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 116	WF-08152023-016022	1/15/2024	FT-FY24-11272023-016022-A	<1	FT-FY24-11272023-016022-B	<1
WS-016023	5/22/2023	5/22/2024	1	Combo Fountain	In classroom 116	WF-05222023-016023	1/15/2024	FT-FY24-11272023-016023-A	<1	FT-FY24-11272023-016023-B	<1
WS-016024	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 117	WF-08152023-016024	1/15/2024	FT-FY24-11272023-016024-A	<1	FT-FY24-11272023-016024-B	<1
WS-016025	5/22/2023	5/22/2024	1	Combo Fountain	In classroom 117	WF-05222023-016025	1/15/2024	FT-FY24-11272023-016025-A	<1	FT-FY24-11272023-016025-B	<1
WS-016027	5/22/2023	5/22/2024	1	Health Suite	In health suite treatment area 109	WF-05222023-016027	1/15/2024	FT-FY24-11272023-016027-A	<1	FT-FY24-11272023-016027-B	<1
WS-016028	5/22/2023	5/22/2024	1	Bottle Filler	In hallway adjacent to room 116	WF-05222023-016028	1/15/2024	FT-FY24-11272023-016028-A	<1	FT-FY24-11272023-016028-B	<1
WS-016029	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to room 116 High Left	WF-05222023-016029	1/15/2024	FT-FY24-11272023-016029-A	<1	FT-FY24-11272023-016029-B	<1
WS-016030	5/22/2023	5/22/2024	1	Cooler	In hallway adjacent to room 116 Low Right	WF-05222023-016030	1/15/2024	FT-FY24-11272023-016030-A	<1	FT-FY24-11272023-016030-B	<1
WS-016032	5/22/2023	5/22/2024	2	Break Room	In lactation suite 223	WF-05222023-016032	1/15/2024	FT-FY24-11272023-016032-A	<1	FT-FY24-11272023-016032-B	<1
WS-016033	5/22/2023	5/22/2024	2	Bottle Filler	In hallway adjacent to the elevator	WF-05222023-016033	1/15/2024	FT-FY24-11272023-016033-A	<1	FT-FY24-11272023-016033-B	<1
WS-016034	5/22/2023	5/22/2024	2	Cooler	In hallway adjacent to the elevator High Left	WF-05222023-016034	1/15/2024	FT-FY24-11272023-016034-A	<1	FT-FY24-11272023-016034-B	<1
WS-016035	5/22/2023	5/22/2024	2	Cooler	In hallway adjacent to the elevator Low Right	WF-05222023-016035	1/15/2024	FT-FY24-11272023-016035-A	<1	FT-FY24-11272023-016035-B	<1
WS-016043	5/22/2023	5/22/2024	2	Combo Fountain	In classroom 214	WF-05222023-016043	1/15/2024	FT-FY24-11272023-016043-A	<1	FT-FY24-11272023-016043-B	<1
WS-016046	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 208	WF-08152023-016046	1/15/2024	FT-FY24-11272023-016046-A	<1	FT-FY24-11272023-016046-B	<1
WS-016047	5/22/2023	5/22/2024	2	Combo Fountain	In classroom 208	WF-05222023-016047	1/15/2024	FT-FY24-11272023-016047-A	<1	FT-FY24-11272023-016047-B	<1
WS-016048	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 209	WF-08152023-016048	1/15/2024	FT-FY24-11272023-016048-A	<1	FT-FY24-11272023-016048-B	<1
WS-016049	5/22/2023	5/22/2024	2	Combo Fountain	In classroom 209	WF-05222023-016049	1/15/2024	FT-FY24-11272023-016049-A	<1	FT-FY24-11272023-016049-B	<1

WS-016050	5/22/2023	5/22/2024	2	Break Room	In teacher collaboration room 211	WF-05222023-016050	1/15/2024	FT-FY24-11272023-016050-A	<1	FT-FY24-11272023-016050-B	<1	
WS-016051	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 212	WF-08152023-016051	1/15/2024	FT-FY24-11272023-016051-A	1.3	FT-FY24-11272023-016051-B	<1	
WS-016052	5/22/2023	5/22/2024	2	Combo Fountain	In classroom 212	WF-05222023-016052	1/15/2024	FT-FY24-11272023-016052-A	<1	FT-FY24-11272023-016052-B	<1	
WS-016053	5/22/2023	5/22/2024	2	Bottle Filler	In hallway adjacent to room 212	WF-05222023-016053	1/15/2024	FT-FY24-11272023-016053-A	<1	FT-FY24-11272023-016053-B	<1	
WS-016054	5/22/2023	5/22/2024	2	Cooler	In hallway adjacent to room 212	High Left	WF-05222023-016054	1/15/2024	FT-FY24-11272023-016054-A	<1	FT-FY24-11272023-016054-B	<1
WS-016055	5/22/2023	5/22/2024	2	Cooler	In hallway adjacent to room 212	Low Right	WF-05222023-016055	1/15/2024	FT-FY24-11272023-016055-A	<1	FT-FY24-11272023-016055-B	<1
WS-016057	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 342	WF-05222023-016057	1/15/2024	FT-FY24-11272023-016057-A	<1	FT-FY24-11272023-016057-B	<1	
WS-016058	5/22/2023	5/22/2024	3	Break Room	In staff lounge 329	WF-05222023-016058	1/15/2024	FT-FY24-11272023-016058-A	<1	FT-FY24-11272023-016058-B	<1	
WS-016059	5/22/2023	5/22/2024	3	Combo Fountain	In staff lounge 329	WF-05222023-016059	1/15/2024	FT-FY24-11272023-016059-A	<1	FT-FY24-11272023-016059-B	<1	
WS-016060	5/22/2023	5/22/2024	3	Break Room	In teacher collaboration room 338	WF-05222023-016060	1/15/2024	FT-FY24-11272023-016060-A	<1	FT-FY24-11272023-016060-B	<1	
WS-016061	5/22/2023	5/22/2024	3	Combo Fountain	In teacher collaboration room 338	WF-05222023-016061	1/15/2024	FT-FY24-11272023-016061-A	<1	FT-FY24-11272023-016061-B	<1	
WS-016063	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 336	WF-05222023-016063	1/15/2024	FT-FY24-11272023-016063-A	<1	FT-FY24-11272023-016063-B	<1	
WS-016069	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 332	WF-05222023-016069	1/15/2024	FT-FY24-11272023-016069-A	<1	FT-FY24-11272023-016069-B	<1	
WS-016071	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 317	WF-05222023-016071	1/15/2024	FT-FY24-11272023-016071-A	<1	FT-FY24-11272023-016071-B	<1	
WS-016073	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 316	WF-05222023-016073	1/15/2024	FT-FY24-11272023-016073-A	<1	FT-FY24-11272023-016073-B	<1	
WS-016074	5/22/2023	5/22/2024	3	Break Room	In teacher collaboration room 302	WF-05222023-016074	1/15/2024	FT-FY24-11272023-016074-A	<1	FT-FY24-11272023-016074-B	<1	
WS-016077	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 310	WF-05222023-016077	1/15/2024	FT-FY24-11272023-016077-A	<1	FT-FY24-11272023-016077-B	<1	
WS-016082	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 311	WF-05222023-016082	1/15/2024	FT-FY24-11272023-016082-A	<1	FT-FY24-11272023-016082-B	<1	
WS-016084	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 314	WF-05222023-016084	1/15/2024	FT-FY24-11272023-016084-A	1.2	FT-FY24-11272023-016084-B	<1	
WS-016086	5/22/2023	5/22/2024	3	Combo Fountain	In classroom 315	WF-05222023-016086	1/15/2024	FT-FY24-11272023-016086-A	<1	FT-FY24-11272023-016086-B	<1	
WS-016884	8/24/2023	8/24/2024	4	Bottle Filler	On rooftop playground adjacent to room 402 storage	WF-08242023-016884	1/15/2024	FT-FY24-11272023-016884-A	<1	FT-FY24-11272023-016884-B	<1	
WS-016885	8/24/2023	8/24/2024	4	Cooler	On rooftop playground adjacent to room 402 storage	High Left	WF-08242023-016885	1/15/2024	FT-FY24-11272023-016885-A	<1	FT-FY24-11272023-016885-B	<1
WS-016886	8/24/2023	8/24/2024	4	Cooler	On rooftop playground adjacent to room 402 storage	Low Right	WF-08242023-016886	1/15/2024	FT-FY24-11272023-016886-A	<1	FT-FY24-11272023-016886-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016010	1/23/2023	1/23/2024	1	Food Prep Sink	In kitchen 1st clockwise from entry	WF-01232023-016010	1/15/2024	FT-FY24-11272023-016010-A	<1	FT-FY24-11272023-016010-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016045	5/22/2023	5/22/2024	2	Combo Fountain	In classroom 213	WF-05222023-016045	1/15/2024	FT-FY24-11272023-016045-A	10.0	FT-FY24-11272023-016045-B	<1

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016045	1/17/2024	1/17/2025	2	Combo Fountain	In classroom 213	WF-01172024-016045	1/25/2024	FT-FY24-01182024-016045-A	<1	FT-FY24-01182024-016045-B	<1