



SOUSA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011101	Other	1	In room B-137 parent center	WT-042916-11118- A	8.38	WT-042916-11118- B	8.12				
2 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011100	Classroom	3	In room B302	WT-042916-11117- A	130	WT-042916-11117- B	7.58	Filter will be installed and then retested			
3 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011099	Classroom	3	In room B304 in northwall	WT-042916-11116- A	< 1	WT-042916-11116- B	< 1				
4 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011098	Fountain	3	In room B-304 north wall	WT-042916-11115- A	< 1	WT-042916-11115- B	< 1				
5 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011097	Classroom	3	In room B-304 north wall	WT-042916-11114- A	29.5	WT-042916-11114- B	11.4	Filter will be installed and then retested			
6 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011096	Fountain	3	In room B304 east wall	WT-042916-11113- A	4.33	WT-042916-11113- B	< 1				
7 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011095	Classroom	3	In room B304	WT-042916-11112- A	34	WT-042916-11112- B	7.39	Filter will be installed and then retested			
8 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011094	Fountain	3	In room B-304 south wall	WT-042916-11111- A	2.75	WT-042916-11111- B	< 1				
9 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011093	Classroom	3	In room B-304 south wall	WT-042916-11110- A	26.3	WT-042916-11110- B	42.2	Filter will be installed and then retested			
10 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011092	Fountain	3	In room B-304 south wall right mid	WT-042916-11109- A	< 1	WT-042916-11109- B	< 1				
11 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011091	Classroom	3	In room B-304 south wall right mid	WT-042916-11108- A	201	WT-042916-11108- B	< 1	Filter will be installed and then retested			
12 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011090	Fountain	3	In room B-304 south wall left mid	WT-042916-11107- A	< 1	WT-042916-11107- B	< 1				
13 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011089	Classroom	3	In room B-304 south wall mid left	WT-042916-11106- A	15.7	WT-042916-11106- B	< 1	Filter will be installed and then retested			
14 SOUSA MIDDLE SCHOOL	5/12/2016	WS-011088	Fountain	3	In room B-304 south wall	WT-042916-11105- A	< 1	WT-042916-11105- B	< 1				
15 SOUSA MIDDLE SCHOOL	5/12/2016	WS-011087	Classroom	3	In room B-304	WT-042916-11104- A	18.1	WT-042916-11104- B	< 1	Filter will be installed and then retested			
16 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011086	Classroom	3	In room B-304	WT-042916-11103- A	7.77	WT-042916-11103- B	1.04				
17 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011085	Cooler	3	In hallway adjacent to room C-301	WT-042916-11102- A	< 1	WT-042916-11102- B	< 1				
18 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011084	Fountain	3	In room A-309 sixth fountain clockwise from entry door	WT-042916-11101- A	< 1	WT-042916-11101- B	< 1				
19 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011083	Classroom	3	In room A-309 eight sink clockwise from entry door	WT-042916-11100- A	15.5	WT-042916-11100- B	< 1	Filter will be installed and then retested			
20 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011082	Fountain	3	In room A-309 fifth fountain clockwise from entry door	WT-042916-11099- A	< 1	WT-042916-11099- B	< 1				
21 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011081	Classroom	2	In room A-309 seventh sink clockwise from entry door	WT-042916-11098- A	23.2	WT-042916-11098- B	7.82	Filter will be installed and then retested			
22 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011080	Fountain	3	In room A-309 fourth fountain clockwise from entry door	WT-042916-11097- A	24.6	WT-042916-11097- B	2.14	Filter will be installed and then retested			
23 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011079	Fountain	3	In room A-309 third fountain clockwise from entry door	WT-042916-11096- A	2.45	WT-042916-11096- B	< 1				
24 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011078	Classroom	3	In room A-309 sixth sink clockwise from entry door	WT-042916-11095- A	90.9	WT-042916-11095- B	25.6	Filter will be installed and then retested			
25 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011077	Fountain	3	In room A-309 second fountain clockwise from entry door	WT-042916-11094- A	< 1	WT-042916-11094- B	< 1				



SOUSA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
26	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011076	Classroom	3	In room A-309 fifth sink clockwise from entry door Right	WT-042916-11093- A	26.5	WT-042916-11093- B	4.92	Filter will be installed and then retested		
27	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011075	Fountain	3	In room A-309 first fountain clockwise from entry door Right	WT-042916-11092- A	1.81	WT-042916-11092- B	< 1			
28	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011074	Classroom	3	In room A-309 forth sink clockwise from entry door Mid	WT-042916-11091- A	63.7	WT-042916-11091- B	2.73	Filter will be installed and then retested		
29	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011073	Classroom	3	In room A-309 third sink clockwise from entry door	WT-042916-11090- A	16	WT-042916-11090- B	< 1	Filter will be installed and then retested		
30	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011072	Classroom	3	In room A-309 second sink clockwise from entry door Left	WT-042916-11089- A	39.5	WT-042916-11089- B	< 1	Filter will be installed and then retested		
31	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011071	Classroom	3	In room A309 first sink clockwise from entry door	WT-042916-11088- A	36.8	WT-042916-11088- B	< 1	Filter will be installed and then retested		
32	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011070	Cooler	3	In hallway across from room A-302 High	WT-042916-11087- A	< 1	WT-042916-11087- B	< 1			
33	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011069	Cooler	3	In hallway adjacent room A302 Low	WT-042916-11086- A	< 1	WT-042916-11086- B	< 1			
34	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011068	Break Room	3	In room B314 teachers lounge	WT-042916-11085- A	< 1	WT-042916-11085- B	< 1			
35	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011067	Classroom	3	In room B316 art room Right	WT-042916-11084- A	< 1	WT-042916-11084- B	< 1			
36	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011066	Classroom	3	In room B-316 Left	WT-042916-11083- A	< 1	WT-042916-11083- B	< 1			
37	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011065	Other	2	In library room B-219	WT-042916-11082- A	1.06	WT-042916-11082- B	< 1			
38	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011064	Classroom	2	In room B-203 OT/PT	WT-042916-11081- A	< 1	WT-042916-11081- B	< 1			
39	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011063	Cooler	2	In hallway across from room A-202 Low	WT-042916-11080- A	< 1	WT-042916-11080- B	< 1			
40	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011062	Cooler	2	In hallway adjacent room A202 High	WT-042916-11079- A	< 1	WT-042916-11079- B	< 1			
41	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011061	Fountain	2	In room A209 West wall Right	WT-042916-11078- A	< 1	WT-042916-11078- B	< 1			
42	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011060	Classroom	2	In room A209 west wall Right	WT-042916-11077- A	3.34	WT-042916-11077- B	< 1			
43	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011059	Fountain	2	In room A209 west wall right/mid Right	WT-042916-11076- A	5.32	WT-042916-11076- B	4.19			
44	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011058	Classroom	2	In room A209 west wall right/mid Right	WT-042916-11075- A	22.6	WT-042916-11075- B	< 1	Filter will be installed and then retested		
45	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011057	Fountain	2	In room A-209 west wall mid Mid	WT-042916-11074- A	2.22	WT-042916-11074- B	< 1			
46	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011056	Classroom	2	In room A-209 west wall mid Mid	WT-042916-11073- A	39.6	WT-042916-11073- B	3.72	Filter will be installed and then retested		
47	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011055	Fountain	2	In room A-209 west wall Left	WT-042916-11072- A	< 1	WT-042916-11072- B	< 1			
48	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011054	Classroom	2	In room A-209 west wall Left	WT-042916-11071- A	44.2	WT-042916-11071- B	1.42	Filter will be installed and then retested		
49	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011053	Fountain	2	In room A-209 east wall Right	WT-042916-11070- A	< 1	WT-042916-11070- B	< 1			
50	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011052	Classroom	2	In room A-209 east wall Right	WT-042916-11069- A	1.99	WT-042916-11069- B	1.97			
51	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011051	Fountain	2	In room A-209 Mid	WT-042916-11068- A	< 1	WT-042916-11068- B	< 1			
52	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011050	Classroom	2	In room A-209 east wall Mid	WT-042916-11067- A	49.7	WT-042916-11067- B	4.42	Filter will be installed and then retested		
53	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011049	Classroom	2	In room A209 east wall Left	WT-042916-11066- A	4.83	WT-042916-11066- B	1.27			
54	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011048	Classroom	2	In room A209 south wall	WT-042916-11065- A	53	WT-042916-11065- B	3.1	Filter will be installed and then retested		
55	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011047	Classroom	2	In science prep room B202	WT-042916-11064- A	< 1	WT-042916-11064- B	< 1			



SOUSA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
56	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011046	Classroom	2	In classroom B204 north wall Right	WT-042916-11063- A	51.7	WT-042916-11063- B	2.98	Filter will be installed and then retested		
57	SOUSA MIDDLE SCHOOL	5/12/2016	WS-011045	Fountain	2	In room B-204 north wall Mid	WT-042916-11062- A	< 1	WT-042916-11062- B	< 1			
58	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011044	Classroom	2	In room B-204 north wall Mid	WT-042916-11061- A	5.04	WT-042916-11061- B	1.83			
59	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011043	Fountain	2	In classroom B204 north wall Left	WT-042916-11060- A	< 1	WT-042916-11060- B	< 1			
60	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011042	Classroom	2	In classroom B204 north wall Left	WT-042916-11059- A	3.2	WT-042916-11059- B	< 1			
61	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011041	Fountain	2	In room B-204 Right	WT-042916-11058- A	1.4	WT-042916-11058- B	< 1			
62	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011040	Classroom	2	In room B-204 Right	WT-042916-11057- A	54.5	WT-042916-11057- B	10.7	Filter will be installed and then retested		
63	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011039	Fountain	2	In classroom B204 south wall middle right	WT-042916-11056- A	1.35	WT-042916-11056- B	< 1			
64	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011038	Classroom	2	In classroom B204 south wall middle right	WT-042916-11055- A	403	WT-042916-11055- B	12.1	Filter will be installed and then retested		
65	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011037	Fountain	2	In room B-204 south wall Mid	WT-042916-11054- A	< 1	WT-042916-11054- B	< 1			
66	SOUSA MIDDLE SCHOOL	5/14/2016	WS-011036	Classroom	2	In classroom B204 south wall	WT-042916-11053- A	4.35	WT-042916-11053- B	< 1			
67	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011035	Fountain	2	In room B-204 south wall Left	WT-042916-11052- A	< 1	WT-042916-11052- B	< 1			
68	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011034	Classroom	2	In room B-204 south wall Left	WT-042916-11051- A	16.9	WT-042916-11051- B	< 1	Filter will be installed and then retested		
69	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011033	Classroom	2	In classroom B204 east wall	WT-042916-11050- A	205	WT-042916-11050- B	23	Filter will be installed and then retested		
70	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011032	Cooler	2	In hallway adjacent to C201 High	WT-042916-11049- A	< 1	WT-042916-11049- B	< 1			
71	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011031	Cooler	2	In hallway adjacent to room C-201	WT-042916-11048- A	< 1	WT-042916-11048- B	< 1			
72	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011030	Kitchen	Basement	In kitchen south wall Right	WT-042916-11047- A	1.97	WT-042916-11047- B	< 1			
73	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011029	Kitchen	Basement	In south wall Mid	WT-042916-11046- A	< 1	WT-042916-11046- B	< 1			
74	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011028	Kitchen	Basement	In south wall Left	WT-042916-11045- A	< 1	WT-042916-11045- B	< 1			
75	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011027	Kitchen	Basement	In kitchen north wall sink Left	WT-042916-11044- A	< 1	WT-042916-11044- B	< 1			
76	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011026	Kitchen	Basement	In kitchen sprayer north wall Right	WT-042916-11043- A	< 1	WT-042916-11043- B	< 1			
77	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011025	Kitchen	Basement	In ice machine in kitchen	WT-042916-11042- A	< 1	WT-042916-11042- B	< 1			
78	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011024	Cooler	1	In girl locker room D119 High	WT-042916-11041- A	< 1	WT-042916-11041- B	< 1			
79	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011023	Cooler	1	In girls locker room D-119 Low	WT-042916-11040- A	< 1	WT-042916-11040- B	< 1			
80	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011022	Cooler	1	In boys locker room D107 High	WT-042916-11039- A	< 1	WT-042916-11039- B	< 1			
81	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011021	Cooler	1	In boys locker room D-107 Low	WT-042916-11038- A	< 1	WT-042916-11038- B	< 1			
82	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011020	Cooler	1	In hallway adjacent to auditorium backstage High	WT-042916-11037- A	< 1	WT-042916-11037- B	< 1			
83	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011019	Cooler	1	In hallway way across from backstage D-101 Low	WT-042916-11036- A	< 1	WT-042916-11036- B	< 1			
84	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011018	Cooler	1	In hallway adjacent to gym D111 High	WT-042916-11035- A	< 1	WT-042916-11035- B	< 1			
85	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011017	Cooler	1	Adjacent to gym D-111 Low	WT-042916-11034- A	< 1	WT-042916-11034- B	< 1			
86	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011016	Cooler	1	In hallway adjacent to room 101-C High	WT-042916-11033- A	< 1	WT-042916-11033- B	< 1			
87	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011015	Cooler	1	In hallway adjacent to room C101 Low	WT-042916-11032- A	< 1	WT-042916-11032- B	< 1			
88	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011014	Classroom	1	In classroom B104 east wall	WT-042916-11031- A	101	WT-042916-11031- B	2.64	Filter will be installed and then retested		
89	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011013	Classroom	1	In room B104 Right	WT-042916-11030- A	6.09	WT-042916-11030- B	< 1			
90	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011012	Fountain	1	In room B104 Mid	WT-042916-11029- A	< 1	WT-042916-11029- B	< 1			
91	SOUSA MIDDLE SCHOOL	5/13/2016	WS-011011	Classroom	1	In room B104 Mid	WT-042916-11028- A	35.2	WT-042916-11028- B	3.98	Filter will be installed and then retested		
92	SOUSA MIDDLE SCHOOL	5/14/2016	WS-011010	Fountain	1	In room 104-8 Left	WT-042916-11027- A	< 1	WT-042916-11027- B	< 1			



SOUSA LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
93 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011009	Classroom	1	In room 104-B north wall	WT-042916-11026- A	109.4	WT-042916-11026- B	37.6	Filter will be installed and then retested			
94 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011008	Fountain	1	In classroom B104 south wall	WT-042916-11025- A	8.6	WT-042916-11025- B	2.08				
95 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011007	Fountain	1	In classroom B104 south wall	WT-042916-11024- A	97.3	WT-042916-11024- B	4.72	Filter will be installed and then retested			
96 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011006	Fountain	1	In room 104-B mid right	WT-042916-11023- A	26.1	WT-042916-11023- B	< 1	Filter will be installed and then retested			
97 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011005	Classroom	1	In room 104-B south wall middle right	WT-042916-11022- A	3.52	WT-042916-11022- B	1.26				
98 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011004	Fountain	1	In classroom B104 south wall middle left	WT-042916-11021- A	< 1	WT-042916-11021- B	< 1				
99 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011003	Classroom	1	In classroom B104 south wall middle left	WT-042916-11020- A	7.98	WT-042916-11020- B	2.55				
100 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011002	Fountain	1	In room 104-B south wall	WT-042916-11019- A	1.51	WT-042916-11019- B	< 1				
101 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011001	Classroom	1	In room 104-B south wall	WT-042916-11018- A	27.9	WT-042916-11018- B	< 1	Filter will be installed and then retested			
102 SOUSA MIDDLE SCHOOL	5/13/2016	WS-011000	Classroom	1	In room B102	WT-042916-11017- A	4.85	WT-042916-11017- B	2.07				
103 SOUSA MIDDLE SCHOOL	5/13/2016	WS-010999	Classroom	1	In room A109	WT-042916-11016- A	< 1	WT-042916-11016- B	< 1				
104 SOUSA MIDDLE SCHOOL	5/13/2016	WS-010998	Classroom	1	In room A109	WT-042916-11015- A	120	WT-042916-11015- B	< 1	Filter will be installed and then retested			
105 SOUSA MIDDLE SCHOOL	5/13/2016	WS-010997	Fountain	1	In classroom A109 east wall middle	WT-042916-11014- A	< 1	WT-042916-11014- B	< 1				
106 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009657	Classroom	1	In classroom A109 east wall	WT-042916-9674- A	< 1	WT-042916-9674- B	< 1				
107 SOUSA MIDDLE SCHOOL	5/14/2016	WS-009656	Fountain	1	In classroom A109 east wall middle right	WT-042916-9673- A	5.13	WT-042916-9673- B	< 1				
108 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009655	Classroom	1	In classroom A109 east wall middle left	WT-042916-9672- A	1.47	WT-042916-9672- B	< 1				
109 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009654	Fountain	1	In classroom A109 east wall	WT-042916-9671- A	1.16	WT-042916-9671- B	< 1				
110 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009653	Classroom	1	In classroom A109 east wall	WT-042916-9670- A	7.09	WT-042916-9670- B	< 1				
111 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009652	Fountain	1	In room 109-A west wall	WT-042916-9669- A	< 1	WT-042916-9669- B	< 1				
112 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009651	Classroom	1	In room 109-A west wall	WT-042916-9668- A	7.58	WT-042916-9668- B	< 1				
113 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009650	Fountain	1	In room 109-A west wall	WT-042916-9667- A	1.29	WT-042916-9667- B	< 1				
114 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009649	Classroom	1	In room 109-A west wall	WT-042916-9666- A	11.9	WT-042916-9666- B	1.06				
115 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009648	Classroom	1	In room A-109 west wall	WT-042916-9665- A	2.22	WT-042916-9665- B	< 1				
116 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009647	Classroom	1	In room room A109	WT-042916-9664- A	40.6	WT-042916-9664- B	7.87	Filter will be installed and then retested			
117 SOUSA MIDDLE SCHOOL	5/14/2016	WS-009646	Health Suite	1	In health suite room B122	WT-042916-9663- A	< 1	WT-042916-9663- B	< 1				
118 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009645	Cooler	1	In hallway adjacent to health suite	WT-042916-9662- A	< 1	WT-042916-9662- B	< 1				
119 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009644	Cooler	1	In hallway adjacent to health suite	WT-042916-9661- A	< 1	WT-042916-9661- B	< 1				
120 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009643	Cooler	1	In hallway adjacent to room A102	WT-042916-9660- A	< 1	WT-042916-9660- B	< 1				
121 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009642	Cooler	1	In hallway adjacent to room A102	WT-042916-9659- A	< 1	WT-042916-9659- B	< 1				
122 SOUSA MIDDLE SCHOOL	5/13/2016	WS-009641	Utility	Ground Floor	In boiler room	WT-042916-9658- A	31	WT-042916-9658- B	14.4	Non-drinking water source - Not accessible to children (boilers)			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.