



Sousa Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009642	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to room A102	Low Left	WF-06172020-009642	4/22/2021	FT-FY21-042021-009642-A	<1	FT-FY21-042021-009642-B	<1
WS- 009643	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to room A102	High Right	WF-06172020-009643	4/22/2021	FT-FY21-042021-009643-A	<1	FT-FY21-042021-009643-B	<1
WS- 009644	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to room B122	High Right	WF-06172020-009644	4/22/2021	FT-FY21-042021-009644-A	<1	FT-FY21-042021-009644-B	<1
WS- 009645	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to room B122	Low Left	WF-06172020-009645	4/22/2021	FT-FY21-042021-009645-A	<1	FT-FY21-042021-009645-B	<1
WS- 009646	6/17/2020	6/17/2021	1	Health Suite	In health suite B122		WF-06172020-009646	4/22/2021	FT-FY21-042021-009646-A	<1	FT-FY21-042021-009646-B	<1
WS- 010987	6/17/2020	6/17/2021	1	Break Room	In mailroom B130		WF-06172020-010987	4/22/2021	FT-FY21-042021-010987-A	<1	FT-FY21-042021-010987-B	<1
WS- 010988	6/17/2020	6/17/2021	1	Health Suite	In health suite B122 in restroom		WF-06172020-010988	4/22/2021	FT-FY21-042021-010988-A	<1	FT-FY21-042021-010988-B	<1
WS- 011017	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to gym D111	Low Left	WF-06172020-011017	4/22/2021	FT-FY21-042021-011017-A	<1	FT-FY21-042021-011017-B	<1
WS- 011018	6/17/2020	6/17/2021	1	Cooler	In hallway adjacent to gym D111	High Right	WF-06172020-011018	4/22/2021	FT-FY21-042021-011018-A	<1	FT-FY21-042021-011018-B	<1
WS- 011019	6/17/2020	6/17/2021	1	Cooler	In hallway across from backstage D101	Low Left	WF-06172020-011019	4/22/2021	FT-FY21-042021-011019-A	<1	FT-FY21-042021-011019-B	<1
WS- 011020	6/17/2020	6/17/2021	1	Cooler	In hallway across from backstage D101	High Right	WF-06172020-011020	4/22/2021	FT-FY21-042021-011020-A	<1	FT-FY21-042021-011020-B	<1
WS- 011021	6/17/2020	6/17/2021	1	Cooler	In boys' locker room D107	Low Left	WF-06172020-011021	4/22/2021	FT-FY21-042021-011021-A	<1	FT-FY21-042021-011021-B	<1
WS- 011022	6/17/2020	6/17/2021	1	Cooler	In boys' locker room D107	High Right	WF-06172020-011022	4/22/2021	FT-FY21-042021-011022-A	<1	FT-FY21-042021-011022-B	<1
WS- 011023	6/17/2020	6/17/2021	1	Cooler	In girls' locker room D119	Low Left	WF-06172020-011023	4/22/2021	FT-FY21-042021-011023-A	<1	FT-FY21-042021-011023-B	<1
WS- 011024	6/17/2020	6/17/2021	1	Cooler	In girls' locker room D119	High Right	WF-06172020-011024	4/22/2021	FT-FY21-042021-011024-A	<1	FT-FY21-042021-011024-B	<1
WS- 011025	6/17/2020	6/17/2021	Basement	Ice Maker	In kitchen (ice maker)		WF-06172020-011025	4/22/2021	FT-FY21-042021-011025-A	<1	FT-FY21-042021-011025-B	<1
WS- 011031	6/17/2020	6/17/2021	2	Cooler	In hallway adjacent to room C201	High Left	WF-06172020-011031	4/22/2021	FT-FY21-042021-011031-A	<1	FT-FY21-042021-011031-B	<1
WS- 011032	6/17/2020	6/17/2021	2	Cooler	In hallway adjacent to room C201	High Right	WF-06172020-011032	4/22/2021	FT-FY21-042021-011032-A	<1	FT-FY21-042021-011032-B	<1
WS- 011068	6/17/2020	6/17/2021	3	Break Room	In staff lounge B314		WF-06172020-011068	4/22/2021	FT-FY21-042021-011068-A	<1	FT-FY21-042021-011068-B	<1
WS- 011069	6/17/2020	6/17/2021	3	Cooler	In hallway adjacent to room A302	Low Left	WF-06172020-011069	4/22/2021	FT-FY21-042021-011069-A	<1	FT-FY21-042021-011069-B	<1
WS- 011070	6/17/2020	6/17/2021	3	Cooler	In hallway adjacent to room A302	High Right	WF-06172020-011070	4/22/2021	FT-FY21-042021-011070-A	<1	FT-FY21-042021-011070-B	<1
WS- 011085	6/17/2020	6/17/2021	3	Cooler	In hallway adjacent to room C301		WF-06172020-011085	4/22/2021	FT-FY21-042021-011085-A	<1	FT-FY21-042021-011085-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011027	2/22/2021	2/22/2022	Basement	Food Prep Sink	In kitchen on north wall	Left	WF-02222021-011027	4/22/2021	FT-FY21-042021-011027-A	<1	FT-FY21-042021-011027-B	<1