



Sousa MS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009642	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room A102	Low	Left	WF-05072018-009642	12/26/2018	FT-FY19-122018-009642-A	<1	FT-FY19-122018-009642-B	<1
WS- 009643	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room A102	High	Right	WF-05072018-009643	12/26/2018	FT-FY19-122018-009643-A	<1	FT-FY19-122018-009643-B	<1
WS- 009644	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room B122	High	Right	WF-05072018-009644	12/26/2018	FT-FY19-122018-009644-A	<1	FT-FY19-122018-009644-B	<1
WS- 009645	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room B122	Low	Left	WF-05072018-009645	12/26/2018	FT-FY19-122018-009645-A	<1	FT-FY19-122018-009645-B	<1
WS- 009646	5/7/2018	5/7/2019	1	Health Suite	In health suite B122			WF-05072018-009646	12/26/2018	FT-FY19-122018-009646-A	<1	FT-FY19-122018-009646-B	<1
WS- 010987	12/12/2018	12/12/2019	1	Break Room	In mailroom B130			WF-12122018-010987	12/26/2018	FT-FY19-122018-010987-A	<1	FT-FY19-122018-010987-B	<1
WS- 010988	5/7/2018	5/7/2019	1	Health Suite	In health suite B122 in restroom			WF-05072018-010988	12/26/2018	FT-FY19-122018-010988-A	<1	FT-FY19-122018-010988-B	<1
WS- 011015	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room C101	Low	Left	WF-05072018-011015	12/26/2018	FT-FY19-122018-011015-A	<1	FT-FY19-122018-011015-B	<1
WS- 011016	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room C101	High	Right	WF-05072018-011016	12/26/2018	FT-FY19-122018-011016-A	<1	FT-FY19-122018-011016-B	<1
WS- 011017	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to gym D111	Low	Left	WF-05072018-011017	12/26/2018	FT-FY19-122018-011017-A	<1	FT-FY19-122018-011017-B	<1
WS- 011018	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to gym D111	High	Right	WF-05072018-011018	12/26/2018	FT-FY19-122018-011018-A	<1	FT-FY19-122018-011018-B	<1
WS- 011019	5/7/2018	5/7/2019	1	Cooler	In hallway across from backstage D101	Low	Left	WF-05072018-011019	12/26/2018	FT-FY19-122018-011019-A	<1	FT-FY19-122018-011019-B	<1
WS- 011020	5/7/2018	5/7/2019	1	Cooler	In hallway across from backstage D101	High	Right	WF-05072018-011020	12/26/2018	FT-FY19-122018-011020-A	<1	FT-FY19-122018-011020-B	<1
WS- 011021	5/7/2018	5/7/2019	1	Cooler	In boys' locker room D107	Low	Left	WF-05072018-011021	12/26/2018	FT-FY19-122018-011021-A	<1	FT-FY19-122018-011021-B	<1
WS- 011022	5/7/2018	5/7/2019	1	Cooler	In boys' locker room D107	High	Right	WF-05072018-011022	12/26/2018	FT-FY19-122018-011022-A	<1	FT-FY19-122018-011022-B	<1
WS- 011023	5/7/2018	5/7/2019	1	Cooler	In girls' locker room D119	Low	Left	WF-05072018-011023	12/26/2018	FT-FY19-122018-011023-A	<1	FT-FY19-122018-011023-B	<1
WS- 011024	5/7/2018	5/7/2019	1	Cooler	In girls' locker room D119	High	Right	WF-05072018-011024	12/26/2018	FT-FY19-122018-011024-A	<1	FT-FY19-122018-011024-B	<1
WS- 011031	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room C201	High	Left	WF-05072018-011031	12/26/2018	FT-FY19-122018-011031-A	<1	FT-FY19-122018-011031-B	<1
WS- 011032	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room C201	High	Right	WF-05072018-011032	12/26/2018	FT-FY19-122018-011032-A	<1	FT-FY19-122018-011032-B	<1
WS- 011062	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room A202	High	Right	WF-05072018-011062	12/26/2018	FT-FY19-122018-011062-A	<1	FT-FY19-122018-011062-B	<1
WS- 011063	5/7/2018	5/7/2019	2	Cooler	In hallway adjacent to room A202	Low	Left	WF-05072018-011063	12/26/2018	FT-FY19-122018-011063-A	<1	FT-FY19-122018-011063-B	<1
WS- 011068	5/7/2018	5/7/2019	3	Break Room	In staff lounge B314			WF-05072018-011068	12/26/2018	FT-FY19-122018-011068-A	<1	FT-FY19-122018-011068-B	<1
WS- 011069	5/7/2018	5/7/2019	3	Cooler	In hallway adjacent to room A302	Low	Left	WF-05072018-011069	12/26/2018	FT-FY19-122018-011069-A	<1	FT-FY19-122018-011069-B	<1
WS- 011070	5/7/2018	5/7/2019	3	Cooler	In hallway adjacent to room A302	High	Right	WF-05072018-011070	12/26/2018	FT-FY19-122018-011070-A	<1	FT-FY19-122018-011070-B	<1
WS- 011085	5/7/2018	5/7/2019	3	Cooler	In hallway adjacent to room C301			WF-05072018-011085	12/26/2018	FT-FY19-122018-011085-A	<1	FT-FY19-122018-011085-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011027	Basement	Food Prep Sink	In kitchen on north wall		Left	12/26/2018	FT-FY19-122018-011027-A	<1	FT-FY19-122018-011027-B	<1