



Southeast Tennis and Learning Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005648	3/15/2024	3/15/2025	1	Cooler	In hallway adjacent to girls' restroom	WF-03152024-005648	4/1/2024	FT-FY24-03202024-005648-A	<1	FT-FY24-03202024-005648-B	<1
WS-005649	3/15/2024	3/15/2025	1	Ice Maker	In kitchen (ice maker)	WF-03152024-005649	4/1/2024	FT-FY24-03202024-005649-A	<1	FT-FY24-03202024-005649-B	<1
WS-005650	12/5/2023	12/5/2024	1	Food Prep Sink	In kitchen	WF-12052023-005650	4/1/2024	FT-FY24-03202024-005650-A	<1	FT-FY24-03202024-005650-B	<1
WS-005651	3/15/2024	3/15/2025	1	Cooler	In hallway adjacent to staff restroom	WF-03152024-005651	4/1/2024	FT-FY24-03202024-005651-A	<1	FT-FY24-03202024-005651-B	<1
WS-005652	3/15/2024	3/15/2025	1	Cooler	In hallway adjacent to staff restroom	WF-03152024-005652	4/1/2024	FT-FY24-03202024-005652-A	<1	FT-FY24-03202024-005652-B	<1