



Southeast Tennis and Learning Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005648	4/1/2021	4/1/2022	1	Cooler	In hallway adjacent to girls' restroom	WF-04012021-005648	3/15/2022	FT-FY22-02212022-005648-A	<1	FT-FY22-02212022-005648-B	<1
WS- 005649	4/1/2021	4/1/2022	1	Ice Maker	In kitchen (ice maker)	WF-04012021-005649	3/15/2022	FT-FY22-02212022-005649-A	<1	FT-FY22-02212022-005649-B	<1
WS- 005651	4/1/2021	4/1/2022	1	Cooler	In hallway adjacent to staff restroom Low	WF-04012021-005651	3/15/2022	FT-FY22-02212022-005651-A	<1	FT-FY22-02212022-005651-B	<1
WS- 005652	4/1/2021	4/1/2022	1	Cooler	In hallway adjacent to staff restroom High	WF-04012021-005652	3/15/2022	FT-FY22-02212022-005652-A	<1	FT-FY22-02212022-005652-B	<1