



SOUTHEAST TENNIS & LEARNING CENTER LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SOUTHEAST TENNIS & LEARNING CENTER	WS- 005648	9/22/2016	1	Cooler	In hallway adjacent to girls' restroom	FT-82016-005648-A	< 1	FT-82016-005648-B	< 1
2	SOUTHEAST TENNIS & LEARNING CENTER	WS- 005649	9/22/2016	1	Ice Maker	In kitchen (ice maker)	FT-82016-005649-A	< 1	FT-82016-005649-B	< 1
3	SOUTHEAST TENNIS & LEARNING CENTER	WS- 005650	9/22/2016	1	Food Prep Sink	In kitchen	FT-82016-005650-A	< 1	FT-82016-005650-B	< 1
4	SOUTHEAST TENNIS & LEARNING CENTER	WS- 005651	9/22/2016	1	Cooler	In hallway adjacent to staff restroom Low	FT-82016-005651-A	< 1	FT-82016-005651-B	< 1
5	SOUTHEAST TENNIS & LEARNING CENTER	WS- 005652	9/22/2016	1	Cooler	In hallway adjacent to staff restroom High	FT-82016-005652-A	< 1	FT-82016-005652-B	< 1