



Stanton Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002535	4/13/2021	4/13/2022	1	Health Suite	In health suite 101	WF-04132021-002535	2/20/2022	FT-FY22-01182022-002535-A	<1	FT-FY22-01182022-002535-B	<1	
WS- 002536	4/13/2021	4/13/2022	1	Break Room	In break room 130F	WF-04132021-002536	2/20/2022	FT-FY22-01182022-002536-A	<1	FT-FY22-01182022-002536-B	<1	
WS- 009848	4/13/2021	4/13/2022	Basement	Cooler	In hallway adjacent to cafeteria	High Left	WF-04132021-009848	2/20/2022	FT-FY22-01182022-009848-A	<1	FT-FY22-01182022-009848-B	<1
WS- 009849	4/13/2021	4/13/2022	Basement	Cooler	In hallway adjacent to cafeteria	Low Right	WF-04132021-009849	2/20/2022	FT-FY22-01182022-009849-A	<1	FT-FY22-01182022-009849-B	<1
WS- 009850	4/13/2021	4/13/2022	Basement	Cooler	In cafeteria		WF-04132021-009850	2/20/2022	FT-FY22-01182022-009850-A	<1	FT-FY22-01182022-009850-B	<1
WS- 009853	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 102		WF-09142021-009853	2/20/2022	FT-FY22-01182022-009853-A	<1	FT-FY22-01182022-009853-B	<1
WS- 009854	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 106		WF-09142021-009854	2/20/2022	FT-FY22-01182022-009854-A	<1	FT-FY22-01182022-009854-B	<1
WS- 009855	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 116		WF-09142021-009855	2/20/2022	FT-FY22-01182022-009855-A	<1	FT-FY22-01182022-009855-B	<1
WS- 009856	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 120		WF-09142021-009856	2/20/2022	FT-FY22-01182022-009856-A	<1	FT-FY22-01182022-009856-B	<1
WS- 009857	4/13/2021	4/13/2022	1	Cooler	In hallway across from room 116	High Left	WF-04132021-009857	2/20/2022	FT-FY22-01182022-009857-A	<1	FT-FY22-01182022-009857-B	<1
WS- 009858	4/13/2021	4/13/2022	1	Cooler	In hallway across from room 116	Low Right	WF-04132021-009858	2/20/2022	FT-FY22-01182022-009858-A	<1	FT-FY22-01182022-009858-B	<1
WS- 009859	4/13/2021	4/13/2022	1	Cooler	In hallway across from room 106	High Left	WF-04132021-009859	2/20/2022	FT-FY22-01182022-009859-A	<1	FT-FY22-01182022-009859-B	<1
WS- 009860	4/13/2021	4/13/2022	1	Cooler	In hallway across from room 106	Low Right	WF-04132021-009860	2/20/2022	FT-FY22-01182022-009860-A	<1	FT-FY22-01182022-009860-B	<1
WS- 009861	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 131	Low Left	WF-09142021-009861	2/20/2022	FT-FY22-01182022-009861-A	<1	FT-FY22-01182022-009861-B	<1
WS- 009862	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 131	High Right	WF-09142021-009862	2/20/2022	FT-FY22-01182022-009862-A	<1	FT-FY22-01182022-009862-B	<1
WS- 009863	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 132	High Left	WF-09142021-009863	2/20/2022	FT-FY22-01182022-009863-A	<1	FT-FY22-01182022-009863-B	<1
WS- 009864	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 132	Low Right	WF-09142021-009864	2/20/2022	FT-FY22-01182022-009864-A	<1	FT-FY22-01182022-009864-B	<1
WS- 009865	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 133	Low Left	WF-09142021-009865	2/20/2022	FT-FY22-01182022-009865-A	<1	FT-FY22-01182022-009865-B	<1
WS- 009866	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 133	High Right	WF-09142021-009866	2/20/2022	FT-FY22-01182022-009866-A	<1	FT-FY22-01182022-009866-B	<1
WS- 009867	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 134	High Left	WF-09142021-009867	2/20/2022	FT-FY22-01182022-009867-A	<1	FT-FY22-01182022-009867-B	<1
WS- 009868	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 134	Low Right	WF-09142021-009868	2/20/2022	FT-FY22-01182022-009868-A	<1	FT-FY22-01182022-009868-B	<1
WS- 009869	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 135	Low Left	WF-09142021-009869	2/20/2022	FT-FY22-01182022-009869-A	<1	FT-FY22-01182022-009869-B	<1
WS- 009870	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 135	High Right	WF-09142021-009870	2/20/2022	FT-FY22-01182022-009870-A	<1	FT-FY22-01182022-009870-B	<1
WS- 009871	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 136	High Left	WF-09142021-009871	2/20/2022	FT-FY22-01182022-009871-A	<1	FT-FY22-01182022-009871-B	<1
WS- 009872	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 136	Low Right	WF-09142021-009872	2/20/2022	FT-FY22-01182022-009872-A	<1	FT-FY22-01182022-009872-B	<1
WS- 009873	4/13/2021	4/13/2022	2	Break Room	In teacher workroom 223		WF-04132021-009873	2/20/2022	FT-FY22-01182022-009873-A	<1	FT-FY22-01182022-009873-B	<1
WS- 009874	9/14/2021	9/14/2022	2	Classroom Faucet	In classroom 207	Left	WF-09142021-009874	2/20/2022	FT-FY22-01182022-009874-A	<1	FT-FY22-01182022-009874-B	<1
WS- 009875	9/14/2021	9/14/2022	2	Classroom Faucet	In classroom 207	Right	WF-09142021-009875	2/20/2022	FT-FY22-01182022-009875-A	<1	FT-FY22-01182022-009875-B	<1
WS- 009876	4/13/2021	4/13/2022	2	Cooler	In hallway across from room 207	High Left	WF-04132021-009876	2/20/2022	FT-FY22-01182022-009876-A	<1	FT-FY22-01182022-009876-B	<1
WS- 009877	4/13/2021	4/13/2022	2	Cooler	In hallway across from room 207	Low Right	WF-04132021-009877	2/20/2022	FT-FY22-01182022-009877-A	<1	FT-FY22-01182022-009877-B	<1
WS- 009878	4/13/2021	4/13/2022	2	Cooler	In hallway across from room 214	High Left	WF-04132021-009878	2/20/2022	FT-FY22-01182022-009878-A	<1	FT-FY22-01182022-009878-B	<1
WS- 009879	4/13/2021	4/13/2022	2	Cooler	In hallway across from room 214	Low Right	WF-04132021-009879	2/20/2022	FT-FY22-01182022-009879-A	<1	FT-FY22-01182022-009879-B	<1
WS- 009880	4/13/2021	4/13/2022	3	Cooler	In hallway across from room 307	High Left	WF-04132021-009880	2/20/2022	FT-FY22-01182022-009880-A	<1	FT-FY22-01182022-009880-B	<1
WS- 009881	4/13/2021	4/13/2022	3	Cooler	In hallway across from room 307	Low Right	WF-04132021-009881	2/20/2022	FT-FY22-01182022-009881-A	<1	FT-FY22-01182022-009881-B	<1
WS- 009882	4/13/2021	4/13/2022	3	Break Room	In staff lounge 312		WF-04132021-009882	2/20/2022	FT-FY22-01182022-009882-A	<1	FT-FY22-01182022-009882-B	<1

WS- 009883	4/13/2021	4/13/2022	3	Cooler	In hallway across from room 315	High Left	WF-04132021-009883	2/20/2022	FT-FY22-01182022-009883-A	<1	FT-FY22-01182022-009883-B	<1
WS- 009884	4/13/2021	4/13/2022	3	Cooler	In hallway across from room 315	Low Right	WF-04132021-009884	2/20/2022	FT-FY22-01182022-009884-A	<1	FT-FY22-01182022-009884-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009851	1/10/2022	1/10/2023	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-01102022-009851	2/20/2022	FT-FY22-01182022-009851-A	<1	FT-FY22-01182022-009851-B	<1