



Stanton Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002535	5/12/2020	5/12/2021	1	Health Suite	In health suite 101	WF-05122020-002535	1/18/2021	FT-FY21-012021-002535-A	<1	FT-FY21-012021-002535-B	<1
WS-002536	5/12/2020	5/12/2021	1	Break Room	In break room 130F	WF-05122020-002536	1/18/2021	FT-FY21-012021-002536-A	1.7	FT-FY21-012021-002536-B	<1
WS-009848	5/12/2020	5/12/2021	Basement	Cooler	In hallway adjacent to cafeteria High Left	WF-05122020-009848	1/18/2021	FT-FY21-012021-009848-A	<1	FT-FY21-012021-009848-B	<1
WS-009849	5/12/2020	5/12/2021	Basement	Cooler	In hallway adjacent to cafeteria Low Right	WF-05122020-009849	1/18/2021	FT-FY21-012021-009849-A	<1	FT-FY21-012021-009849-B	<1
WS-009850	5/12/2020	5/12/2021	Basement	Cooler	In cafeteria	WF-05122020-009850	1/18/2021	FT-FY21-012021-009850-A	<1	FT-FY21-012021-009850-B	<1
WS-009853	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 102	WF-09222020-009853	1/18/2021	FT-FY21-012021-009853-A	<1	FT-FY21-012021-009853-B	<1
WS-009854	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 106	WF-09222020-009854	1/18/2021	FT-FY21-012021-009854-A	<1	FT-FY21-012021-009854-B	<1
WS-009855	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 116	WF-09222020-009855	1/18/2021	FT-FY21-012021-009855-A	<1	FT-FY21-012021-009855-B	<1
WS-009856	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 120	WF-09222020-009856	1/18/2021	FT-FY21-012021-009856-A	<1	FT-FY21-012021-009856-B	<1
WS-009857	5/12/2020	5/12/2021	1	Cooler	In hallway across from room 116 High Left	WF-05122020-009857	1/18/2021	FT-FY21-012021-009857-A	<1	FT-FY21-012021-009857-B	<1
WS-009858	5/12/2020	5/12/2021	1	Cooler	In hallway across from room 116 Low Right	WF-05122020-009858	1/18/2021	FT-FY21-012021-009858-A	<1	FT-FY21-012021-009858-B	<1
WS-009859	5/12/2020	5/12/2021	1	Cooler	In hallway across from room 106 High Left	WF-05122020-009859	1/18/2021	FT-FY21-012021-009859-A	<1	FT-FY21-012021-009859-B	<1
WS-009860	5/12/2020	5/12/2021	1	Cooler	In hallway across from room 106 Low Right	WF-05122020-009860	1/18/2021	FT-FY21-012021-009860-A	<1	FT-FY21-012021-009860-B	<1
WS-009861	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 131 Low Left	WF-09222020-009861	1/18/2021	FT-FY21-012021-009861-A	1.7	FT-FY21-012021-009861-B	<1
WS-009862	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 131 High Right	WF-09222020-009862	1/18/2021	FT-FY21-012021-009862-A	<1	FT-FY21-012021-009862-B	<1
WS-009863	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 132 High Left	WF-09222020-009863	1/18/2021	FT-FY21-012021-009863-A	<1	FT-FY21-012021-009863-B	<1
WS-009864	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 132 Low Right	WF-09222020-009864	1/18/2021	FT-FY21-012021-009864-A	<1	FT-FY21-012021-009864-B	<1
WS-009865	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 133 Low Left	WF-09222020-009865	1/18/2021	FT-FY21-012021-009865-A	4.3	FT-FY21-012021-009865-B	<1
WS-009867	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 134 High Left	WF-09222020-009867	1/18/2021	FT-FY21-012021-009867-A	<1	FT-FY21-012021-009867-B	<1
WS-009868	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 134 Low Right	WF-09222020-009868	1/18/2021	FT-FY21-012021-009868-A	2.3	FT-FY21-012021-009868-B	<1
WS-009869	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 135 Low Left	WF-09222020-009869	1/18/2021	FT-FY21-012021-009869-A	2.4	FT-FY21-012021-009869-B	<1
WS-009870	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 135 High Right	WF-09222020-009870	1/18/2021	FT-FY21-012021-009870-A	1.8	FT-FY21-012021-009870-B	<1
WS-009871	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 136 High Left	WF-09222020-009871	1/18/2021	FT-FY21-012021-009871-A	<1	FT-FY21-012021-009871-B	<1
WS-009872	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 136 Low Right	WF-09222020-009872	1/18/2021	FT-FY21-012021-009872-A	<1	FT-FY21-012021-009872-B	<1
WS-009873	5/12/2020	5/12/2021	2	Break Room	In teacher workroom 223	WF-05122020-009873	1/18/2021	FT-FY21-012021-009873-A	<1	FT-FY21-012021-009873-B	<1
WS-009874	9/22/2020	9/22/2021	2	Classroom Faucet	In classroom 207 Left	WF-09222020-009874	1/18/2021	FT-FY21-012021-009874-A	<1	FT-FY21-012021-009874-B	<1
WS-009875	9/22/2020	9/22/2021	2	Classroom Faucet	In classroom 207 Right	WF-09222020-009875	1/18/2021	FT-FY21-012021-009875-A	<1	FT-FY21-012021-009875-B	<1
WS-009876	5/12/2020	5/12/2021	2	Cooler	In hallway across from room 207 High Left	WF-05122020-009876	1/18/2021	FT-FY21-012021-009876-A	<1	FT-FY21-012021-009876-B	<1
WS-009877	5/12/2020	5/12/2021	2	Cooler	In hallway across from room 207 Low Right	WF-05122020-009877	1/18/2021	FT-FY21-012021-009877-A	<1	FT-FY21-012021-009877-B	<1
WS-009878	5/12/2020	5/12/2021	2	Cooler	In hallway across from room 214 High Left	WF-05122020-009878	1/18/2021	FT-FY21-012021-009878-A	<1	FT-FY21-012021-009878-B	<1
WS-009879	5/12/2020	5/12/2021	2	Cooler	In hallway across from room 214 Low Right	WF-05122020-009879	1/18/2021	FT-FY21-012021-009879-A	<1	FT-FY21-012021-009879-B	<1
WS-009880	5/12/2020	5/12/2021	3	Cooler	In hallway across from room 307 High Left	WF-05122020-009880	1/18/2021	FT-FY21-012021-009880-A	<1	FT-FY21-012021-009880-B	<1

WS- 009881	5/12/2020	5/12/2021	3	Cooler	In hallway across from room 307	Low	Right	WF-05122020-009881	1/18/2021	FT-FY21-012021-009881-A	<1	FT-FY21-012021-009881-B	<1
WS- 009882	5/12/2020	5/12/2021	3	Break Room	In staff lounge 312			WF-05122020-009882	1/18/2021	FT-FY21-012021-009882-A	<1	FT-FY21-012021-009882-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009851	2/27/2020	2/27/2021	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-02272020-009851	1/18/2021	FT-FY21-012021-009851-A	<1	FT-FY21-012021-009851-B	<1	

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation														
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 009866	9/22/2020	9/22/2021	1	Classroom Faucet	In classroom 133		High	Right	WF-09222020-009866	1/18/2021	FT-FY21-012021-009866-A	7.4	FT-FY21-012021-009866-B	<1