



Stanton Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002536	4/4/2022	4/4/2023	1	Break Room	In break room 130F	WF-04042022-002536	11/7/2022	FT-FY23-10102022-002536-A	<1	FT-FY23-10102022-002536-B	<1	
WS- 009848	4/4/2022	4/4/2023	Basement	Cooler	In hallway adjacent to cafeteria	High Left	WF-04042022-009848	11/7/2022	FT-FY23-10102022-009848-A	<1	FT-FY23-10102022-009848-B	<1
WS- 009849	4/4/2022	4/4/2023	Basement	Cooler	In hallway adjacent to cafeteria	Low Right	WF-04042022-009849	11/7/2022	FT-FY23-10102022-009849-A	<1	FT-FY23-10102022-009849-B	<1
WS- 009850	4/4/2022	4/4/2023	Basement	Cooler	In cafeteria		WF-04042022-009850	11/7/2022	FT-FY23-10102022-009850-A	<1	FT-FY23-10102022-009850-B	<1
WS- 009853	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 102		WF-09062022-009853	11/7/2022	FT-FY23-10102022-009853-A	<1	FT-FY23-10102022-009853-B	<1
WS- 009854	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 106		WF-09062022-009854	11/7/2022	FT-FY23-10102022-009854-A	<1	FT-FY23-10102022-009854-B	<1
WS- 009856	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 120		WF-09062022-009856	11/7/2022	FT-FY23-10102022-009856-A	<1	FT-FY23-10102022-009856-B	<1
WS- 009857	4/4/2022	4/4/2023	1	Cooler	In hallway across from room 116	High Left	WF-04042022-009857	11/7/2022	FT-FY23-10102022-009857-A	<1	FT-FY23-10102022-009857-B	<1
WS- 009858	4/4/2022	4/4/2023	1	Cooler	In hallway across from room 116	Low Right	WF-04042022-009858	11/7/2022	FT-FY23-10102022-009858-A	<1	FT-FY23-10102022-009858-B	<1
WS- 009859	4/4/2022	4/4/2023	1	Cooler	In hallway across from room 106	High Left	WF-04042022-009859	11/7/2022	FT-FY23-10102022-009859-A	<1	FT-FY23-10102022-009859-B	<1
WS- 009860	4/4/2022	4/4/2023	1	Cooler	In hallway across from room 106	Low Right	WF-04042022-009860	11/7/2022	FT-FY23-10102022-009860-A	<1	FT-FY23-10102022-009860-B	<1
WS- 009861	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 131	Low Left	WF-09062022-009861	11/7/2022	FT-FY23-10102022-009861-A	<1	FT-FY23-10102022-009861-B	<1
WS- 009862	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 131	High Right	WF-09062022-009862	11/7/2022	FT-FY23-10102022-009862-A	<1	FT-FY23-10102022-009862-B	<1
WS- 009863	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 132	High Left	WF-09062022-009863	11/7/2022	FT-FY23-10102022-009863-A	<1	FT-FY23-10102022-009863-B	<1
WS- 009864	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 132	Low Right	WF-09062022-009864	11/7/2022	FT-FY23-10102022-009864-A	<1	FT-FY23-10102022-009864-B	<1
WS- 009865	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 133	Low Left	WF-09062022-009865	11/7/2022	FT-FY23-10102022-009865-A	<1	FT-FY23-10102022-009865-B	<1
WS- 009866	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 133	High Right	WF-09062022-009866	11/7/2022	FT-FY23-10102022-009866-A	<1	FT-FY23-10102022-009866-B	<1
WS- 009867	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 134	High Left	WF-09062022-009867	11/7/2022	FT-FY23-10102022-009867-A	<1	FT-FY23-10102022-009867-B	<1
WS- 009868	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 134	Low Right	WF-09062022-009868	11/7/2022	FT-FY23-10102022-009868-A	<1	FT-FY23-10102022-009868-B	<1
WS- 009869	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 135	Low Left	WF-09062022-009869	11/7/2022	FT-FY23-10102022-009869-A	<1	FT-FY23-10102022-009869-B	<1
WS- 009871	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 136	High Left	WF-09062022-009871	11/7/2022	FT-FY23-10102022-009871-A	<1	FT-FY23-10102022-009871-B	<1
WS- 009872	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 136	Low Right	WF-09062022-009872	11/7/2022	FT-FY23-10102022-009872-A	<1	FT-FY23-10102022-009872-B	<1
WS- 009873	4/4/2022	4/4/2023	2	Break Room	In teacher workroom 223		WF-04042022-009873	11/7/2022	FT-FY23-10102022-009873-A	<1	FT-FY23-10102022-009873-B	<1
WS- 009874	9/6/2022	9/6/2023	2	Classroom Faucet	In classroom 207	Left	WF-09062022-009874	11/7/2022	FT-FY23-10102022-009874-A	<1	FT-FY23-10102022-009874-B	<1
WS- 009875	9/6/2022	9/6/2023	2	Classroom Faucet	In classroom 207	Right	WF-09062022-009875	11/7/2022	FT-FY23-10102022-009875-A	<1	FT-FY23-10102022-009875-B	<1
WS- 009877	4/4/2022	4/4/2023	2	Cooler	In hallway across from room 207	Low Right	WF-04042022-009877	11/7/2022	FT-FY23-10102022-009877-A	<1	FT-FY23-10102022-009877-B	<1
WS- 009878	4/4/2022	4/4/2023	2	Cooler	In hallway across from room 214	High Left	WF-04042022-009878	11/7/2022	FT-FY23-10102022-009878-A	<1	FT-FY23-10102022-009878-B	<1
WS- 009879	4/4/2022	4/4/2023	2	Cooler	In hallway across from room 214	Low Right	WF-04042022-009879	11/7/2022	FT-FY23-10102022-009879-A	<1	FT-FY23-10102022-009879-B	<1
WS- 009880	4/4/2022	4/4/2023	3	Cooler	In hallway across from room 307	High Left	WF-04042022-009880	11/7/2022	FT-FY23-10102022-009880-A	<1	FT-FY23-10102022-009880-B	<1
WS- 009881	4/4/2022	4/4/2023	3	Cooler	In hallway across from room 307	Low Right	WF-04042022-009881	11/7/2022	FT-FY23-10102022-009881-A	<1	FT-FY23-10102022-009881-B	<1
WS- 009882	4/4/2022	4/4/2023	3	Break Room	In staff lounge 312		WF-04042022-009882	11/7/2022	FT-FY23-10102022-009882-A	<1	FT-FY23-10102022-009882-B	<1
WS- 009884	4/4/2022	4/4/2023	3	Cooler	In hallway across from room 315	Low Right	WF-04042022-009884	11/7/2022	FT-FY23-10102022-009884-A	<1	FT-FY23-10102022-009884-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009851	1/10/2022	1/10/2023	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-01102022-009851	11/7/2022	FT-FY23-10102022-009851-A	<1	FT-FY23-10102022-009851-B	<1