



Stanton ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002535	5/20/2019	5/20/2020	1	Health Suite	In health suite 101	WF-05202019-002535	11/8/2019	FT-FY20-102019-002535-A	<1	FT-FY20-102019-002535-B	<1	
WS- 002536	5/20/2019	5/20/2020	1	Break Room	In break room 130F	WF-05202019-002536	11/8/2019	FT-FY20-102019-002536-A	<1	FT-FY20-102019-002536-B	<1	
WS- 009848	5/20/2019	5/20/2020	Basement	Cooler	In hallway adjacent to cafeteria	High Left	WF-05202019-009848	11/8/2019	FT-FY20-102019-009848-A	<1	FT-FY20-102019-009848-B	<1
WS- 009849	5/20/2019	5/20/2020	Basement	Cooler	In hallway adjacent to cafeteria	Low Right	WF-05202019-009849	11/8/2019	FT-FY20-102019-009849-A	<1	FT-FY20-102019-009849-B	<1
WS- 009850	5/20/2019	5/20/2020	Basement	Cooler	In cafeteria		WF-05202019-009850	11/8/2019	FT-FY20-102019-009850-A	<1	FT-FY20-102019-009850-B	<1
WS- 009853	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 102		WF-09302019-009853	11/8/2019	FT-FY20-102019-009853-A	<1	FT-FY20-102019-009853-B	<1
WS- 009854	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 106		WF-09302019-009854	11/8/2019	FT-FY20-102019-009854-A	<1	FT-FY20-102019-009854-B	<1
WS- 009855	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 116		WF-09302019-009855	11/8/2019	FT-FY20-102019-009855-A	<1	FT-FY20-102019-009855-B	<1
WS- 009856	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 120		WF-09302019-009856	11/8/2019	FT-FY20-102019-009856-A	<1	FT-FY20-102019-009856-B	<1
WS- 009859	5/20/2019	5/20/2020	1	Cooler	In hallway across from room 106	High Left	WF-05202019-009859	11/8/2019	FT-FY20-102019-009859-A	<1	FT-FY20-102019-009859-B	<1
WS- 009860	5/20/2019	5/20/2020	1	Cooler	In hallway across from room 106	Low Right	WF-05202019-009860	11/8/2019	FT-FY20-102019-009860-A	<1	FT-FY20-102019-009860-B	<1
WS- 009861	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 131	Low Left	WF-09302019-009861	11/8/2019	FT-FY20-102019-009861-A	<1	FT-FY20-102019-009861-B	<1
WS- 009862	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 131	High Right	WF-09302019-009862	11/8/2019	FT-FY20-102019-009862-A	<1	FT-FY20-102019-009862-B	<1
WS- 009863	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 132	High Left	WF-09302019-009863	11/8/2019	FT-FY20-102019-009863-A	<1	FT-FY20-102019-009863-B	<1
WS- 009864	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 132	Low Right	WF-09302019-009864	11/8/2019	FT-FY20-102019-009864-A	<1	FT-FY20-102019-009864-B	<1
WS- 009865	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 133	Low Left	WF-09302019-009865	11/8/2019	FT-FY20-102019-009865-A	<1	FT-FY20-102019-009865-B	<1
WS- 009867	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 134	High Left	WF-09302019-009867	11/8/2019	FT-FY20-102019-009867-A	<1	FT-FY20-102019-009867-B	<1
WS- 009868	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 134	Low Right	WF-09302019-009868	11/8/2019	FT-FY20-102019-009868-A	<1	FT-FY20-102019-009868-B	<1
WS- 009869	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 135	Low Left	WF-09302019-009869	11/8/2019	FT-FY20-102019-009869-A	1.1	FT-FY20-102019-009869-B	<1
WS- 009870	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 135	High Right	WF-09302019-009870	11/8/2019	FT-FY20-102019-009870-A	<1	FT-FY20-102019-009870-B	<1
WS- 009871	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 136	High Left	WF-09302019-009871	11/8/2019	FT-FY20-102019-009871-A	<1	FT-FY20-102019-009871-B	<1
WS- 009872	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 136	Low Right	WF-09302019-009872	11/8/2019	FT-FY20-102019-009872-A	<1	FT-FY20-102019-009872-B	<1
WS- 009873	5/20/2019	5/20/2020	2	Break Room	In teacher workroom 223		WF-05202019-009873	11/8/2019	FT-FY20-102019-009873-A	<1	FT-FY20-102019-009873-B	<1
WS- 009874	9/30/2019	9/30/2020	2	Classroom Faucet	In classroom 207	Left	WF-09302019-009874	11/8/2019	FT-FY20-102019-009874-A	<1	FT-FY20-102019-009874-B	<1
WS- 009875	9/30/2019	9/30/2020	2	Classroom Faucet	In classroom 207	Right	WF-09302019-009875	11/8/2019	FT-FY20-102019-009875-A	<1	FT-FY20-102019-009875-B	<1
WS- 009876	5/20/2019	5/20/2020	2	Cooler	In hallway across from room 207	High Left	WF-05202019-009876	11/8/2019	FT-FY20-102019-009876-A	<1	FT-FY20-102019-009876-B	<1
WS- 009877	5/20/2019	5/20/2020	2	Cooler	In hallway across from room 207	Low Right	WF-05202019-009877	11/8/2019	FT-FY20-102019-009877-A	<1	FT-FY20-102019-009877-B	<1
WS- 009878	5/20/2019	5/20/2020	2	Cooler	In hallway across from room 214	High Left	WF-05202019-009878	11/8/2019	FT-FY20-102019-009878-A	<1	FT-FY20-102019-009878-B	<1
WS- 009879	5/20/2019	5/20/2020	2	Cooler	In hallway across from room 214	Low Right	WF-05202019-009879	11/8/2019	FT-FY20-102019-009879-A	<1	FT-FY20-102019-009879-B	<1
WS- 009880	5/20/2019	5/20/2020	3	Cooler	In hallway across from room 307	High Left	WF-05202019-009880	11/8/2019	FT-FY20-102019-009880-A	<1	FT-FY20-102019-009880-B	<1
WS- 009881	5/20/2019	5/20/2020	3	Cooler	In hallway across from room 307	Low Right	WF-05202019-009881	11/8/2019	FT-FY20-102019-009881-A	<1	FT-FY20-102019-009881-B	<1
WS- 009882	5/20/2019	5/20/2020	3	Break Room	In staff lounge 312		WF-05202019-009882	11/8/2019	FT-FY20-102019-009882-A	<1	FT-FY20-102019-009882-B	<1
WS- 009883	5/20/2019	5/20/2020	3	Cooler	In hallway across from room 315	High Left	WF-05202019-009883	11/8/2019	FT-FY20-102019-009883-A	<1	FT-FY20-102019-009883-B	<1

WS- 009884	5/20/2019	5/20/2020	3	Cooler	In hallway across from room 315	Low Right	WF-05202019-009884	11/8/2019	FT-FY20-102019-009884-A	<1	FT-FY20-102019-009884-B	<1
------------	-----------	-----------	---	--------	---------------------------------	-----------	--------------------	-----------	-------------------------	----	-------------------------	----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009851	7/2/2019	7/2/2020	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-07022019-009851	11/8/2019	FT-FY20-102019-009851-A	<1	FT-FY20-102019-009851-B	<1

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009866	9/30/2019	9/30/2020	1	Classroom Faucet	In classroom 133	High Right	WF-09302019-009866	11/8/2019	FT-FY20-102019-009866-A	6	FT-FY20-102019-009866-B	<1