



Stanton Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002535	7/11/2023	7/11/2024	1	Health Suite	In health suite 101	WF-07112023-002535	11/29/2023	FT-FY24-10102023-002535-A	<1	FT-FY24-10102023-002535-B	<1	
WS- 002536	7/11/2023	7/11/2024	1	Break Room	In break room 130F	WF-07112023-002536	11/29/2023	FT-FY24-10102023-002536-A	<1	FT-FY24-10102023-002536-B	<1	
WS- 009850	7/11/2023	7/11/2024	Basement	Cooler	In cafeteria	WF-07112023-009850	11/29/2023	FT-FY24-10102023-009850-A	<1	FT-FY24-10102023-009850-B	<1	
WS- 009853	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 102	WF-08282023-009853	11/29/2023	FT-FY24-10102023-009853-A	<1	FT-FY24-10102023-009853-B	<1	
WS- 009854	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 106	WF-08282023-009854	11/29/2023	FT-FY24-10102023-009854-A	1.2	FT-FY24-10102023-009854-B	<1	
WS- 009855	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 116	WF-08282023-009855	11/29/2023	FT-FY24-10102023-009855-A	2.5	FT-FY24-10102023-009855-B	<1	
WS- 009856	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 120	WF-08282023-009856	11/29/2023	FT-FY24-10102023-009856-A	<1	FT-FY24-10102023-009856-B	<1	
WS- 009857	7/11/2023	7/11/2024	1	Cooler	In hallway across from room 116	High Left	WF-07112023-009857	11/29/2023	FT-FY24-10102023-009857-A	<1	FT-FY24-10102023-009857-B	<1
WS- 009858	7/11/2023	7/11/2024	1	Cooler	In hallway across from room 116	Low Right	WF-07112023-009858	11/29/2023	FT-FY24-10102023-009858-A	<1	FT-FY24-10102023-009858-B	<1
WS- 009859	7/11/2023	7/11/2024	1	Cooler	In hallway across from room 106	High Left	WF-07112023-009859	11/29/2023	FT-FY24-10102023-009859-A	<1	FT-FY24-10102023-009859-B	<1
WS- 009860	7/11/2023	7/11/2024	1	Cooler	In hallway across from room 106	Low Right	WF-07112023-009860	11/29/2023	FT-FY24-10102023-009860-A	<1	FT-FY24-10102023-009860-B	<1
WS- 009861	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 131	Low Left	WF-08282023-009861	11/29/2023	FT-FY24-10102023-009861-A	<1	FT-FY24-10102023-009861-B	<1
WS- 009862	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 131	High Right	WF-08282023-009862	11/29/2023	FT-FY24-10102023-009862-A	4.1	FT-FY24-10102023-009862-B	<1
WS- 009863	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 132	High Left	WF-08282023-009863	11/29/2023	FT-FY24-10102023-009863-A	1.6	FT-FY24-10102023-009863-B	<1
WS- 009864	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 132	Low Right	WF-08282023-009864	11/29/2023	FT-FY24-10102023-009864-A	1.0	FT-FY24-10102023-009864-B	<1
WS- 009865	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 133	Low Left	WF-08282023-009865	11/29/2023	FT-FY24-10102023-009865-A	2.0	FT-FY24-10102023-009865-B	<1
WS- 009867	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 134	High Left	WF-08282023-009867	11/29/2023	FT-FY24-10102023-009867-A	1.7	FT-FY24-10102023-009867-B	<1
WS- 009868	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 134	Low Right	WF-08282023-009868	11/29/2023	FT-FY24-10102023-009868-A	3.2	FT-FY24-10102023-009868-B	<1
WS- 009869	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 135	Low Left	WF-08282023-009869	11/29/2023	FT-FY24-10102023-009869-A	3.1	FT-FY24-10102023-009869-B	<1
WS- 009870	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 135	High Right	WF-08282023-009870	11/29/2023	FT-FY24-10102023-009870-A	2.6	FT-FY24-10102023-009870-B	<1
WS- 009871	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 136	High Left	WF-08282023-009871	11/29/2023	FT-FY24-10102023-009871-A	2.7	FT-FY24-10102023-009871-B	<1
WS- 009872	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 136	Low Right	WF-08282023-009872	11/29/2023	FT-FY24-10102023-009872-A	2.2	FT-FY24-10102023-009872-B	<1
WS- 009873	7/11/2023	7/11/2024	2	Break Room	In teacher workroom 223		WF-07112023-009873	11/29/2023	FT-FY24-10102023-009873-A	<1	FT-FY24-10102023-009873-B	<1
WS- 009874	8/28/2023	8/28/2024	2	Classroom Faucet	In classroom 207	Left	WF-08282023-009874	11/29/2023	FT-FY24-10102023-009874-A	1.1	FT-FY24-10102023-009874-B	<1
WS- 009875	8/28/2023	8/28/2024	2	Classroom Faucet	In classroom 207	Right	WF-08282023-009875	11/29/2023	FT-FY24-10102023-009875-A	1.5	FT-FY24-10102023-009875-B	<1
WS- 009876	7/11/2023	7/11/2024	2	Cooler	In hallway across from room 207	High Left	WF-07112023-009876	11/29/2023	FT-FY24-10102023-009876-A	<1	FT-FY24-10102023-009876-B	<1
WS- 009877	7/11/2023	7/11/2024	2	Cooler	In hallway across from room 207	Low Right	WF-07112023-009877	11/29/2023	FT-FY24-10102023-009877-A	<1	FT-FY24-10102023-009877-B	<1
WS- 009878	7/11/2023	7/11/2024	2	Cooler	In hallway across from room 214	High Left	WF-07112023-009878	11/29/2023	FT-FY24-10102023-009878-A	<1	FT-FY24-10102023-009878-B	<1
WS- 009879	7/11/2023	7/11/2024	2	Cooler	In hallway across from room 214	Low Right	WF-07112023-009879	11/29/2023	FT-FY24-10102023-009879-A	<1	FT-FY24-10102023-009879-B	<1
WS- 009880	7/11/2023	7/11/2024	3	Cooler	In hallway across from room 307	High Left	WF-07112023-009880	11/29/2023	FT-FY24-10102023-009880-A	<1	FT-FY24-10102023-009880-B	<1
WS- 009881	7/11/2023	7/11/2024	3	Cooler	In hallway across from room 307	Low Right	WF-07112023-009881	11/29/2023	FT-FY24-10102023-009881-A	<1	FT-FY24-10102023-009881-B	1.5
WS- 009882	7/11/2023	7/11/2024	3	Break Room	In staff lounge 312		WF-07112023-009882	11/29/2023	FT-FY24-10102023-009882-A	<1	FT-FY24-10102023-009882-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009851	12/21/2022	12/21/2023	Basement	Food Prep Sink	In kitchen first clockwise from entry door	WF-12212022-009851	11/29/2023	FT-FY24-10102023-009851-A	<1	FT-FY24-10102023-009851-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009866	8/28/2023	8/28/2024	1	Classroom Faucet	In classroom 133 High Right	WF-08282023-009866	11/29/2023	FT-FY24-10102023-009866-A	5.8	FT-FY24-10102023-009866-B	2.6

First Re-test (After Plumbing Check)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009866	12/1/2023	12/1/2024	1	Classroom Faucet	In classroom 133 High Right	WF-12012023-009866	12/11/2023	FT-FY24-12052023-009866-A	2.6	FT-FY24-12052023-009866-B	<1